

FMO STAFF USE - Inspection Date: \_\_\_\_\_ Inspection Time: \_\_\_\_\_ Staff: \_\_\_\_\_

**Your  
Seattle  
Fire Department**



### APPLICATION FOR TEMPORARY PERMIT

**Code 2601**

**Floor Finishing > 350 Square Feet**

**Permit Fee: \$ 288**

\_\_\_\_\_/\_\_\_\_\_  
**Date Issued                      Permit Expiration Date**

TO BE COMPLETED BY PERMIT APPLICANT (PLEASE PRINT)

FIRM NAME		
MAILING ADDRESS		SUITE
CITY	STATE	ZIP
OPERATION ADDRESS		
CONTACT PERSON		PHONE NUMBER (    )

**Payment must accompany all applications. Please include a check made payable to the CITY OF SEATTLE.**

Permit applications may be submitted in person weekdays from 8:00 a.m. to 4:30 p.m., or mailed to:

Seattle Fire Department  
Fire Marshal's Office – Permits  
220 Third Ave S, 2<sup>nd</sup> Floor  
Seattle, WA 98104-2608

To pay with a Visa or Master Card, email this completed application to us,  
**and then visit [www.seattle.gov/fire/permits](http://www.seattle.gov/fire/permits) to make a payment.**  
Tel: (206) 386-1450  
E-mail: [permits@seattle.gov](mailto:permits@seattle.gov)

**Call 206-386-1450, at least 24 hours prior to needed inspection time to arrange for an appointment.**

Permission is hereby granted to: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Special permit conditions:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

<b>FMO USE:</b>	<b>APPROVED BY:</b>
Check No.: _____	Inspector: _____ SFD ID# _____
Receipt No.: _____	Date: _____
Application ID#: _____	

# Seattle Fire Department

## Permit Conditions

2601

### Floor Finishing > 350 Square Feet

1. **2410.1 Scope.** Floor surfacing and finishing operations exceeding 350 square feet (33 m<sup>2</sup>) and using Class I or II liquids shall comply with Sections 2410.2 through 2410.5.
2. **2410.3 Business operation.** Floor surfacing and finishing operations shall not be conducted while an establishment is open to the public.
3. **2403.2.2 Open flames and sparks.** Open flames and spark-producing devices shall not be located in flammable vapor areas and shall not be located within 20 feet (6096 mm) of such areas unless separated by a permanent partition.
4. **2403.2.6 Smoking prohibited.** Smoking shall be prohibited in flammable vapor areas and hazardous materials storage rooms associated with flammable finish processes. “No Smoking” signs complying with Section 310 shall be conspicuously posted in such areas.
5. **2403.2.3 Hot surfaces.** Heated surfaces having a temperature sufficient to ignite vapors shall not be located in flammable vapor areas. Space-heating appliances, steam pipes or hot surfaces in a flammable vapor area shall be located such that they are not subject to accumulation of deposits of combustible residues.
6. **2410.4 Ignition sources.** The power shall be shut down to all electrical sources of ignition within the flammable vapor area, unless those devices are classified for use in Class I, Division 1 hazardous locations.
7. **2410.5 Ventilation.** To prevent the accumulation of flammable vapors, mechanical ventilation at a minimum rate of 1 cubic foot per minute per square foot [0.00508 m<sup>3</sup> / (s • m<sup>2</sup>)] of area being finished shall be provided. Such exhaust shall be by approved temporary or portable means. Vapors shall be exhausted to the exterior of the building
8. **2410.2 Mechanical system operation.** Heating, ventilation and air-conditioning systems shall not be operated during resurfacing or refinishing operations or within 4 hours of the application of flammable or *combustible liquids*.
9. **2403.2.4 Equipment enclosures.** Equipment or apparatus that is capable of producing sparks or particles of hot metal that would fall into a flammable vapor area shall be totally enclosed.
10. **2403.2.7 Welding warning signs.** Welding, cutting and similar spark-producing operations shall not be conducted in or adjacent to flammable vapor areas or dipping or coating operations unless precautions have been taken to provide safety. Conspicuous signs with the following warning shall be posted in the vicinity of flammable vapor areas, dipping operations and paint storage rooms:

# Seattle Fire Department

## Permit Conditions

2601

### Floor Finishing > 350 Square Feet

11. **2403.4 Operations and maintenance.** Flammable vapor areas, exhaust fan blades and exhaust ducts shall be kept free from the accumulation of deposits of combustible residues. Where excessive residue accumulates in such areas, spraying operations shall be discontinued until conditions are corrected.
12. **2403.4.1 Tools.** Scrapers, spuds and other tools used for cleaning purposes shall be constructed of non-sparking materials.
13. **2403.4.2 Residue.** Residues removed during cleaning and debris contaminated with residue shall be immediately removed from the premises and properly disposed.
14. **2403.4.3 Waste cans.** Approved metal waste cans equipped with self-closing lids shall be provided wherever rags or waste are impregnated with finishing material. Such rags and waste shall be deposited therein immediately after being utilized. The contents of waste cans shall be properly disposed of not less than once daily and at the end of each shift.