

Seattle Fire Department

Permit Conditions

107SE

Event Name / Dates / Address:

Ceremonial Fireworks

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. Receipts for fireworks purchased under this permit must be attached to this permit. (SFC 105.3)
2. This permit is valid only on the date, time and location of the discharge listed on the application. (SFC 105.3)
3. This permit is valid only for the quantity and type of fireworks listed on the application. (SFC 105.3)
4. No aerial display, rockets, missiles or the like are allowed. (SFC 105.3)
5. Fireworks may only be purchased from a Washington State Licensed Fireworks Wholesaler. A list of licensed wholesalers is available at: <https://wsp.wa.gov/wp-content/uploads/2025/01/12.24-All-Wholesaler.pdf> (SFC 105.3)
6. Permit holder is authorized to purchase only the fireworks listed in the application that will be discharged under this permit. (SFC 105.3)
7. No storage of fireworks is allowed beyond 3 days prior to the date of discharge. (SFC 105.3)
8. If you have unused fireworks, you are to return them to a Washington State Licensed Fireworks Wholesaler or to the nearest Seattle Police Department Precinct no later than 3 days after the date on the permit. (SFC 105.3)
9. A competent adult (minimum age 18 years) must directly supervise the event. (SFC 105.3)
10. At least two pressurized water, Class 2-A extinguishers and two Class 10-BC extinguishers shall be provided, within 25 feet of where fireworks are used. The extinguishers shall be placed so that at least one is located on each opposing side of the performance. (SFC 105.3 & 906)
11. Spectators must be separated from the fireworks being fired by a minimum of 25 feet. There shall be no glowing or flaming particles within 15 feet of the audience. (SFC 105.3)
12. The area where fireworks are being fired must be completely free of combustible materials for a distance of 25 feet. (SFC 105.3)
13. Motor vehicles must be a minimum of 25 feet from the area of discharge. (SFC 105.3)
14. Fireworks being fired must be separated a minimum of 25 feet from any building or structure. (SFC 105.3)
15. During dry periods, the area where fireworks are being fired must be wet down prior to discharge. (SFC 105.3)

Seattle Fire Department Permit Conditions

107SE

Event Name / Dates / Address:

Ceremonial Fireworks

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.