

# Seattle Fire Department

## Permit Conditions

6101

### Annual Tank Decommissioning

#### NOTICE

**This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)**

1. The contractor must employ an ICC (International Code Council)-certified Underground Storage Tank Decommissioner to conduct or directly supervise all tank decommissioning work at the job site.
2. The contractor must submit a Seattle Fire Department Heating Oil Tank Decommissioning Permit Application to the Fire Prevention Division before conducting decommissioning the tank. A separate application must be submitted for each tank to be decommissioned.
3. The contractor shall not begin any tank decommissioning work at a job site until the permit application fee has been paid and the permit stamped "Approved To Proceed" has been issued by the Seattle Fire Department.
4. The Seattle Fire Department Decommissioning Report must be completed and signed by the ICC (International Code Council)--certified Decommissioner.
5. Within thirty (30) days of the date for tank capping, filling or removal indicated on the permit application, the Seattle Fire Department Decommissioning Report form must be returned to the Fire Prevention Division, 220 Third Avenue South, Seattle, WA 98104-2608 (Fax 206-386-9863)
6. The contractor shall comply with all Seattle Fire Code requirements for individual residential underground heating oil-decommissioning permits (Permit Code 6103).
7. The contractor shall provide the tank owner with a copy of the Seattle Fire Department permit, permit conditions and decommissioning report for that specific tank. A contractor's own letter of certification is not a substitute for a completed and signed Seattle Fire Department Decommissioning Report.