

Seattle Fire Department

Permit Conditions

7801.1

Event Name / Dates / Address:

Fireworks Use/Display/Special Effects Outdoor

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. All insurance requirements must be reviewed by and approved by the City of Seattle Office of Risk Management. (SFC 105.3)
2. Only those fireworks products listed on the attached product summary may be used. (SFC 105.3)
3. A secured/fenced perimeter must be established around [REDACTED]. The perimeter fence line must enclose an area extending approximately [REDACTED] in radius in all directions. The area within this fenced perimeter must be cleared of all persons prior to the fireworks display except for event staff organizers or security personnel. (SFC 105.3)
4. The Seattle Fire Department shall have a minimum [REDACTED] # observers in place and give final approval before the fireworks display can commence. (SFC 105.3)
5. [REDACTED] shall provide a minimum of [REDACTED] # water pressurized extinguishers in area during the display and extinguishers located such that they are within 75 feet of travel from any location. [REDACTED] shall also provide a minimum of [REDACTED] # [REDACTED] extinguishers located [REDACTED]. (SFC 105.3 & 906)
6. The discharge site must be secured, and access prohibited to all except for working pyrotechnic personnel. (SFC 105.3)
7. No shells and/or fireworks effects shall be shot directly over spectators. (SFC 5608.6)
8. This fireworks show must be coordinated, supervised and fired by a Washington State Licensed pyrotechnician. (SFC 105.3)
9. All necessary precautions shall be in place to ensure that fireworks products stay dry and do not become wet prior to firing. (SFC 105.3)
10. Security personnel shall be in place at all times to prevent unauthorized access to the storage area prior to loading and to the display area once the shells and fireworks products are moved into place. (NFPA 8.2.6)
11. All fireworks products must be kept in ready boxes or approved Department of Transportation (DOT) packaging until such time as they are loaded into the mortars or firing positions. (SFC 105.3)
12. The person designated by the permit holder as being responsible for overseeing the discharge of the fireworks/special effects shall maintain direct communications with a representative from the Fire Marshal's Office at all times. (NOTE: A cellular phone is acceptable as a means of communication to fulfill this requirement, however radio communications are the preferred method of communications utilized by the Seattle Fire Department.) (SFC 105.3 & NFPA 8.3.5)

Seattle Fire Department

Permit Conditions

7801.1

Event Name / Dates / Address:

Fireworks Use/Display/Special Effects Outdoor

13. The permit holder or his/her representative shall have a cell phone readily available to provide and to summon the Fire Department if needed. (SFC 105.3)
14. Fireworks will not be fired when wind speeds are 25 MPH sustained or 30 MPH gusts. The Seattle Fire Department reserves the right to revoke this permit at any time or on a moments notice if it deems it necessary due to weather conditions or concerns for public safety. (SFC 105.3)

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.