

Seattle Fire Department

Permit Conditions

7801.3

Event Name / Dates / Address:

Fireworks Barge Load/Unload

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. The following are the permit conditions for the preparation of the fireworks barge at 3546 W. Marginal Way SW (Island Barge and Tug). (SFC 105.3)
2. The fireworks barge may only be loaded at the above-designated address. (SFC 105.3)
3. The barge shall be situated at the above address so that it is no closer than 250 feet to any self-propelled vessel. (SFC 105.3)
4. There shall be no cutting or welding allowed within 250 feet of the fireworks barge or products. (SFC 105.3)
5. A charged fire hose shall be attached to the nearest water source and must be capable of reaching all points on the barge. At least two pressurized water, Class 2-A extinguishers and two Class 10-BC extinguishers shall be on site. (SFC 105.3)
6. There shall always be a cell phone available and capable of contacting 9-1-1 in the event of an emergency. (SFC 105.3)
7. Cones or barriers shall be positioned on the pier adjacent to the barge so that no cars/trucks can drive within 50 feet of the barge when the fireworks are present. (SFC 105.3)
8. There shall be **two ways** on and off the barge (i.e. ladders or gangways) to help with emergency egress or fire department access, in the event of a fireworks-related emergency. (SFC 105.3)
9. There must be 24-hour security on the barge when the fireworks are present. Security personnel may be utilized to provide security during hours of preparation. During non-preparation hours, a responsible adult must be stationed on the pier to prevent access to the barge by unauthorized individuals. (SFC 105.3)
10. No smoking within 100 feet of the barge when the fireworks are present. (SFC 105.3)
11. A safety monitor must be assigned during all hours of preparation. This individual shall have the sole responsibility of insuring that safe practices are adhered to and that there is no smoking going on in the vicinity of the barge. This individual must be a responsible adult and must have the authority to stop/prevent any observed unsafe practices. (SFC 105.3)

Seattle Fire Department

Permit Conditions

7801.3

Event Name / Dates / Address:

Fireworks Barge Load/Unload

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.