

Seattle Fire Department

Permit Conditions

7900

VIN: _____ License Plate State/#: _____ Inspector: _____

Flammable/Combustible Liquid Tank Vehicle

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. Tank vehicles shall be designed, constructed, equipped and maintained in accordance with NFPA 385 and SFC Section 5706.6.1.1 through 5706.6.1.11. (SFC 5706.6.1)
2. Certification shall be maintained for tank vehicles in accordance with DOTn 49 CFR, Parts 100-185. (SFC 5706.5.1.15)
3. Tank vehicles shall not be operated unless they are in proper repair and free of accumulation of grease, oil or other flammable substances, and leaks. (SFC 5706.6.1.1)
4. The tank vehicle shall have chock blocks not less than 5 inches by 5 inches by 12 inches in size and dished to fit the contour of the tires. (SFC 5706.5.1.16.2)
5. Signs prohibiting smoking or open flames within 25 feet of the vehicle or the point of refueling are prominently posted on the tank vehicle. (SFC 5706.2.8)
6. Spill cleanup supplies capable of absorbing 15 gallons of fuel, storm drain plug or cover kit, a nonwater absorbent containment boom, or a minimum 10-foot-long length with a 12-gallon absorbent capacity, a nonmetallic shovel and two 5 gallon buckets with lids are required on the vehicle. (SFC 5706.5.4.5)
7. Tank vehicles shall be equipped with a "fuel limit" switch such as a count-back switch, to limit the amount of a single fueling operation to not more than 500 gallons before resetting the limit switch. (SFC 5706.5.4.5)
8. Tank vehicles shall be equipped with a fire extinguisher having a minimum rating of 2-A:40-B:C and signage shall clearly indicate its location. (SFC 5706.6.4 & 5706.5.4.5)
9. The dispensing hose does not exceed 100 feet in length. (SFC 5706.2.8)
10. The dispensing nozzles and hoses shall be of an approved and listed type. (5706.2.8 & 5706.5.4.5)
11. The dispensing hose is properly placed on an approved reel or in a compartment provided before the tank vehicle is moved. (SFC 5706.2.8)
12. During loading, hatch covers shall be secured on all but the receiving compartment. (SFC 5706.6.1.6)
13. An external bond-wire connection or bond-wire integral with a hose shall be provided for the transferring of flammable liquids through open connections into underground tanks. (SFC 5706.6.1.8)
14. The fire code official and other appropriate authorities shall be notified when a reportable spill or unauthorized discharge occurs. (SFC 5706.5.4.5)