

Seattle Fire Department

Permit Conditions

7912-ODMF

Applicant/Business Name: _____

Inspector: _____

On-Demand Mobile Fueling Operator

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. On-Demand Mobile Fueling shall only be from fueling vehicles approved by the Fire Code Official. Each fueling vehicle shall have a separate permit. (SFC 105.5.20 (6))
2. On-Demand Mobile Fueling shall only be conducted at sites that have an operational permit issued by the Fire Code Official. (SFC 105.5.20(11) and 5707.1.1)
3. On-Demand Mobile Fueling, including the mobile fueling vehicle and point of connection of the vehicle being fueled, shall not occur on public streets, public ways, inside of buildings or on the roof or inside of any parking structure. (SFC 5707.4)
4. Mobile fueling operators shall have an *approved* written safety and emergency response plan that establishes policies and procedures for fire safety, spill prevention and control, personnel training, and compliance with other applicable requirements of this code. (SFC 5707.3.1)
5. Mobile fueling vehicles shall be operated only by designated personnel who are trained on proper fueling procedures and the safety and emergency response plan. Training records of operators shall be maintained. (SFC 5707.3.2)
6. Mobile fueling vehicles shall be constantly attended during fueling operations with brakes set and warning lights in operation. Mobile fueling vehicles shall not obstruct emergency vehicle access roads. (SFC 5707.6)
7. Mobile fueling vehicles shall be positioned in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an approved reel or in an approved compartment prior to moving the mobile fueling vehicle. (SFC 5707.6.1)
8. Operators shall place a drip pan or an absorbent pillow under the nozzle and each fuel fill opening prior to and during dispensing operations to catch drips. (SFC 5707.6.2)

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call 206-386-1450 or email permits@seattle.gov. Information also available at <https://www.seattle.gov/fire/business-services/permits#mobilefueling>, although that information may not be updated daily.

Seattle Fire Department

Permit Conditions

7912-ODMF

Applicant/Business Name: _____

Inspector: _____

On-Demand Mobile Fueling Operator

9. Safety cones or other visual barriers shall be employed as warning devices to highlight the vehicle fueling area. Signs prohibiting smoking or open flames within 25 feet shall be prominently posted in the vehicle fueling area. (SFC 5707.6.3)
10. The mobile fueling vehicle flasher lights shall be in operation while dispensing operations are in progress. (SFC 5707.6.4)
11. Safety cans and approved metal containers shall be secured to the mobile fueling vehicle except when in use. (SFC 5707.2.2(3))
12. Fueling a motor vehicle from tanks or containers mounted in a trailer connected to a mobile fueling vehicle is prohibited. (SFC 5707.2.2 (4))
13. Spills shall be reported in accordance with Section 5003.3.1. The person, firm or corporation responsible for an unauthorized discharge shall institute and complete all actions necessary to remedy the effects of such unauthorized discharge, whether sudden or gradual, without cost to the jurisdiction. Where deemed necessary by the fire code official, cleanup can be initiated by the fire department or by an authorized individual or firm. (SFC 5003.3.1.4 and 5707.6.6)
14. Nighttime mobile fueling shall only be made in areas deemed adequately lighted. (SFC 5707.6.5)

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call 206-386-1450 or email permits@seattle.gov. Information also available at <https://www.seattle.gov/fire/business-services/permits#mobilefueling>, although that information may not be updated daily.
