

# Seattle Fire Department

## Permit Conditions

7912

Site Address: \_\_\_\_\_

Inspector: \_\_\_\_\_

### Mobile Fleet Fueling Operator

#### NOTICE

**This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)**

1. Dispensing of fuel into vehicles is only allowed at locations which have been issued a mobile fleet fueling site permit issued by Seattle Fire Department. (SFC 105.5.20)
2. Fuel dispensing shall only be from tank vehicles complying the requirements of NFPA 385, state and federal requirements. Each tank vehicle shall operate under a current flammable liquids vehicle permit issued by Seattle Fire Department, and be equipped with No smoking or open flame signs, a 40:BC portable fire extinguisher and a spill kit. (SFC 5706.5.4.5)
3. Tank vehicles shall be equipped with a "fuel limit" switch or equivalent that limits the amount of a single fueling operation to no more than 500 gallons before the switch is required to be reset. A limit switch is not required if the operator carries a remote emergency shut-off device. (SFC 5706.5.4.5 (13))
4. Tank vehicle dispensing equipment shall be constantly attended and operated by properly trained individuals who have an emergency communications device in their possession at all times. (SFC 5706.5.4.5 (15))
5. Fuel dispensing shall be conducted in areas not accessible to the public or shall be limited to times when the public is not present. (SFC 5706.5.4.5 (5))
6. Fueling dispensing shall only take place during daylight hours, unless adequate lighting is available. (5706.4.5 (19))
7. Fueling dispensing shall be conducted at least from 15 feet from buildings, property lines, combustible storage, and storm drains that do not have approved oil interceptors, covers or an approved equivalent. (SFC 5706.5.4.5 (6))
8. Fueling dispensing shall be conducted at least 25 feet from any source of ignition. (SFC 5706.5.4.5 (17))
9. The engines of vehicles being fueled shall be shut off during fuel dispensing. (SFC 5706.5.4.5 (18))
10. The fuel dispensing hose shall not be driven over by vehicles. (SFC 5707.6.1)
11. The dispensing hose shall be extended no more than 100 ft. and the hose shall be listed and approved. The hose shall be properly placed on an approved reel or compartment prior to moving the tank vehicle. (SFC 5706.5.4.5)
12. Tank vehicles shall have the brakes set, chock blocks in place, and warning lights in operation. (SFC 5706.5.4.5 (21))

# Seattle Fire Department Permit Conditions

7912

Site Address: \_\_\_\_\_

Inspector: \_\_\_\_\_

## Mobile Fleet Fueling Operator

13. Motor vehicle fuel tanks shall not be topped off. (SFC 5706.5.4.5 (22))
14. Drip pans or an absorbent pillow shall be placed under each fuel fill opening prior to and during dispensing operations. (SFC 5706.5.4.5 (25))
15. A written spill response plan shall be developed by the owner of the fleet fueling tanker vehicles with appropriate training provided to each tanker operator. The fire code official and other appropriate authorities shall be notified when a reportable spill or unauthorized discharge occurs. (SFC 5706.5.4.5 (2))