

# Seattle Fire Department

## Permit Conditions

**7913-ODMF**

Site Address: \_\_\_\_\_

Inspector: \_\_\_\_\_

### On-Demand Mobile Fueling Site

#### NOTICE

**This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)**

1. An operational permit is required to utilize a site for On-Demand Mobile Fueling operations. (SFC 105.5.20 and 5707.1.1)
2. The approval of the owner of the site shall be obtained to conduct On-Demand Mobile Fueling and documentation shall be provided to the fire code official. (SFC 105.1.1)
3. A site plan shall be developed and submitted for each location at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate: all buildings, structures, lot lines, property lines, electric car chargers, solar photovoltaic parking lot canopies, and appurtenances on site and their use or function; all uses adjacent to the lot lines of the site; fueling locations, the locations of all storm drain openings and adjacent waterways or wetlands; information regarding slope, natural drainage, curbing, impounding and how a spill will be kept on the site property; and the scale of the site plan. (SFC 5707.3.3)
4. Engaging in the dispensing of fuel into vehicles at this location shall only be conducted by an On-Demand mobile fueling company who has a valid On-Demand mobile fueling operational permit issued by the fire code official. (SFC 105.5.20)
5. Mobile Fueling on an approved site shall only be from fueling vehicles approved by the fire code official. Each fueling vehicle shall have a separate permit. (SFC 105.5.20 and 5707.1.1)
6. The mobile fueling operation, including the mobile fueling vehicle and the point of connection of the vehicle being fueled, shall not occur on public streets, public ways or inside buildings. Mobile Fueling on the roof level of parking structures or other buildings is prohibited. (SFC 5707.4)
7. Mobile fueling shall not occur within 20 feet of electrical equipment located within 18 inches of the ground unless such electrical equipment is rated for Class I, Division 2 hazardous locations in accordance with the Seattle Electrical Code and NFPA 70. (SFC 5707.4.3)
8. Mobile fueling shall not take place within 25 feet of buildings, lot lines, property lines or combustible storage.  
**Exceptions:**
  1. The fire code official shall be authorized to decrease the separation distance for dispensing from metal safety cans or other approved metal containers.
  2. The point of fueling shall not take place within 10 feet of buildings, lot lines, property lines, or combustible storage where the mobile fueling vehicle has and approve vapor recovery system or is servicing vehicles with onboard refueling vapor recovery. (SFC 5707.4.1)
9. Smoking, open flames and other sources of ignition shall be prohibited within 25 feet of fuel dispensing activities. Signs prohibiting smoking or open flames within 25 feet of the vehicle or the point of fueling shall be prominently posted on the mobile fueling vehicle. The engines of vehicles being fueled shall be shut off during fueling. (SFC 5707.4.2)