

Seattle Fire Department Permit Conditions

7913

Site Address: _____

Inspector: _____

Mobile Fleet Fueling Site

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. Dispensing of fuel into vehicles at this location shall only be conducted by a mobile fleet fueling company who has a valid mobile fleet fueling permit issued by Seattle Fire Department. (SFC 105.5.20)
2. Fuel dispensing shall only be from tank vehicles complying the requirements of NFPA 385, state and federal requirements. Each tank vehicle shall operate under a current flammable liquids vehicle permit issued by Seattle Fire Department, and be equipped with No smoking or open flame signs, a portable fire extinguisher and a spill kit. (SFC 5706.5.4.5)
3. Fuel dispensing shall be conducted in areas not accessible to the public or shall be limited to times when the public is not present. (SFC 5706.5.4.5 (5))
4. Fueling dispensing shall only take place during daylight hours, unless adequate lighting is available. (SFC 5706.5.4.5 (4))
5. Fueling dispensing shall be conducted at least from 15 feet from buildings, property lines, combustible storage, and storm drains that do not have approved oil interceptors, covers or an approved equivalent. (SFC 5706.5.4.5 (6))
6. Fueling dispensing shall be conducted at least 25 feet from any source of ignition. (SFC 5706.5.4.5 (17))
7. The engines of vehicles being fueled shall be shut off during fuel dispensing. (SFC 5706.5.4.5 (18))
8. The fuel dispensing hose shall not be driven over by vehicles. (SFC 5707.6.1)
9. Drip pans or an absorbent pillow shall be placed under each fuel fill opening prior to and during dispensing operations. (SFC 5706.5.4.5 (25))