

Seattle Fire Department

Permit Conditions

8020

Event Name / Dates / Address:

Flammable Liquids Temporary

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. All fuel must be stored in the approved depot area located [REDACTED]. This area shall be restricted from access by the public. (SFC 105.3)
2. A clear zone shall be maintained around the depot area. The clear zone shall be a minimum of 25 feet in width. The clear zone shall be maintained free of any and all obstructions and/or set up at all times. No unattended vehicles may park in this zone. (SFC 105.3)
3. Storage of combustible materials shall be prohibited within 50 feet of the depot area. (SFC 105.3)
4. The maximum total amount of fuel stored in the depot area shall not exceed 500 gallons. (SFC 105.3)
5. All refueling operations shall be conducted at the fuel depot. Refueling is prohibited in the show, in the building, or in any area accessible to the public. (SFC 105.3)
6. Demonstration vehicles shall only be operated in the demonstration area. (SFC 105.3)
7. A minimum of four (4) portable fire extinguishers with a minimum U. L. rating of "2A- 40BC". shall be readily available on site during refueling operations. Two (2) of the required fire extinguishers shall be located in the fuel depot. The remaining two (2) fire extinguishers shall be placed at the refueling location within 25 feet of the operation. (SFC 105.3)
8. Each fire extinguisher shall have a tag affixed to it verifying it has been serviced within 1 year from the date of the event. If the fire extinguisher has been purchased within the last year, the sales receipt from the date of the transaction shall be affixed to the fire extinguisher. (SFC 105.3 & 906)
9. Fuel spills and leaks shall be contained and cleaned up immediately. (SFC 105.3 & 5703.3)
10. LPG (Propane) cylinders shall not be permitted to be used or stored within 50 feet of the depot. (SFC 105.3)
11. Smoking shall not be permitted within 50 feet of the depot. (SFC 105.3 & 5003.7.1)
12. No Smoking signs shall be posted in conspicuous places inside and around the depot. (SFC 105.3 & 5003.7.1)
13. Staff shall be provided that are dedicated to strictly enforce the No Smoking policy. (SFC 105.3 & 5003.7.1)
14. SFD Fireguards must be present on-site while the depot is in use. (SFC 105.3 & 5003.7.1)

Seattle Fire Department Permit Conditions

8020

Event Name / Dates / Address:

Flammable Liquids Temporary

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.