

Seattle Fire Department

Permit Conditions

8205

Event Name / Dates / Address:

Flame Effects (All Fuel Types)

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. It is the responsibility of the permit holder to train all employees in the proper storage and handling of propane tanks and how to properly use a fire extinguisher in an emergency and to make them aware of the following permit conditions. (SFC 105.3)
2. Fuel is limited to amounts listed on the Effects & Consumables page of the permit package. Additional units must be stored outside of the building. (SFC 105.3)
3. Provide one (1) approved fire extinguisher per accumulator unit and/or special effect. The required fire extinguishers must each have a minimum U. L. rating of "2A- 40 BC". Required fire extinguishers must be serviced annually and must have a certification tag indicating recent testing and certification. (Newly purchased extinguishers must have the sales slip indicating the purchase date). (SFC 105.3 & 906)
4. All equipment must carry the approval of a nationally recognized testing agency (U.L., F.M., etc.). (SFC 6501.1)
5. All cylinders must be supported in an upright position with the container and the hoses protected from physical damage. (SFC 6109)
6. All cylinders must be equipped with a pressure regulating device intended for use with the gases contained in the cylinder. (SFC 6107)
7. When not in use the gas supply must be completely shut off and the valve protection caps in place. (SFC 6109.8)
8. No event spectators are allowed on site during special effects. (SFC 105.3)
9. Any curtains/drapery, scenery or stage props, which could be exposed to flame/sparks, must be flame proofed. (SFC 105.3, NFPA 701, CPAI-84, California State Fire Marshal Approval Certificate)

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.