

Seattle Fire Department

Permit Conditions

8208

Event Name / Dates / Address:

Temporary Vehicle Display

NOTICE

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)

1. It is the responsibility of the permit holder to train all employees how to properly use a fire extinguisher in an emergency and to make them aware of the following permit conditions. (SFC 105.3)
2. A fire extinguisher shall be readily available within 75 feet of travel. The required fire extinguisher must have a minimum U.L. rating of "2A - 40 BC". Required fire extinguishers must be service annually and must have a certification tag indicating the recent testing and certification. Newly purchased extinguishers must have the sales slip indicating the purchased date. (SFC 105.3)
3. Fuel in fuel tanks shall not exceed one-quarter tank or 5 gallons, whichever is less. (SFC 314.4.2.1)
4. Fuel tanks and fill opening shall be taped and closed or have a locking type gas cap. (SFC 105.3)
5. Fueling or defueling of vehicles shall not take place in the assembly area and/or while the public is present. (SFC 314.4.4)

NOTE: NO ADDITIONAL FUEL IS PERMITTED IN THE PUBLIC ASSEMBLY AREA.

6. Battery cables shall be disconnected and the ends of the cables taped. If the vehicle is electric only then the vehicle must be safeguarded at all times with no key on hand or phone app allowing the vehicle to move. (SFC 105.3 & 314.4.1)
7. A vehicle fuel load certificate shall be placed on the dash and visible to Fire Prevention Inspector. The certificate shall indicate the following:
 - a. Date
 - b. Contact person name (printed), signature, phone number
 - c. Fuel tank amount $\frac{1}{4}$ of the tank capacity or 5 gallons whichever is less.
 - d. Is the fuel tank opening locked and sealed (i.e. taped)
 - e. Battery cables are disconnected and the ends of the cables taped.
 - f. Make and license number (if so equipment) (SFC 105.3)
8. Batteries in electric vehicles shall be rendered inoperable by the removal of fuses or other approved methods but shall not be required to be disconnected. (SFC 105.3)
9. This permit is subject to a final field inspection. Any exception to the above conditions must be requested prior to the event and must have the approval of the Fire Prevention Division. (SFC 105.3)

Seattle Fire Department

Permit Conditions

8208

Event Name / Dates / Address:

Temporary Vehicle Display

ANY VARIATION FROM THESE WRITTEN CONDITIONS WHICH HAS NOT RECEIVED PRIOR APPROVAL FROM THE FIRE DEPARTMENT CONSTITUTES A VIOLATION OF THE SEATTLE FIRE CODE AND SHALL CAUSE THIS PERMIT TO BE INVALID. FIRE CODE VIOLATIONS ARE BOTH CRIMINAL AND CIVIL IN NATURE AND WILL BE DEALT WITH ACCORDINGLY.