

Building 47 Site Tour Q&A

May 9, 2019

Start: 3 p.m.

Kevin Bergsrud (SPR) asked if the sump pump space can be viewed to see the area under the gym and extending to the theater. Answer is no due to the presence of hazardous materials. The main electrical room can be viewed as the unexcavated area extending to the theater can be viewed.

SPR staff told attendees about removal of the exterior landing and stairs during renovations in 2002-2003.

Q: Are the boilers on today? (question asked when the tour is standing in the upper balcony)

A: SPR will be checking to see if the boilers are on. **(Update – HVAC team reported there is no boiler hook-up for the Building 47 Theater. Two gas heaters are located on the roof to heat the premises and those are temperature controlled. Perhaps the boilers found in the premises are decommissioned.)**

Q: Do the boilers provide both heating and hot water? (concern about turning off boiler and loss/less hot water for domestic use)

A: Please see answer above.

Announced that next open houses are scheduled for 5/23 and 5/30 at 10 a.m.

Tour End: 3:50 p.m.