Water Supply Operating Board

Water Supply

October 6, 2016

Paul Faulds Water Resources Manager



Water Supply

Water Management Challenges Commissioning Morse Lake Pump Plant

Seattle Seattle Utilities







Last Update: 10/02/2016 Calendar Year 2016 Cedar River Instream Flows Measured at USGS Stream Gage No. 12117600



Calendar Year 2016

24-hr Consumption, 7-Day Moving Average

Through September 26, 2016 300 275 250 225 200 175 150 125 100 75 50 25 0 Dec ö Feb Mar Aug Sep ۶ مال Apr Мау μ ö 3 Ending Date for Week -WY 2016 -WY 2015 ——Average WY 1999-2014 Average WY 1994-2000 — Average WY 1999-2008 -Average WY 1985-1991

Notes: A. 7-day moving average is calculated using data from the day of and the previous 6 days. All Data is Provisional and Subject to Change

Flood Memt. **3 Transition Periods** 饧 **Typical Reservoir Inflow and Seattle Precipitation** 1000 7 Flood Flood Mgmt. Waiting for Rain Refill 900 Dec 6 Nov 800 Jan 5 700 SeaTac Precip (in) 600 Feb Inflow (cfs) Ma 500 Oct 400 Apr 300 Sept 2 May Jun 200 Aug Jul 1 100 0 0 SeaTac Precip (in) -Median Cedar Reservoir Inflow (cfs) _

Masonry Dam and Reservoir









SF Tolt Dam and Reservoir



Water Supply Challenges with Commissioning New Pump Plant

Max operating level is 1552 ft. with 2 ft. buffer to 1554 ft. to account for wave action.

Challenges:

- Contractor likely starts to demob plant around elevation 1551 +.
- Water Resources tasked with trying to maintain a reservoir elevation (flood pocket) of 1548 ft. to 1552 for commissioning.
- SOP do not release water from storage in anticipation of high precipitation events because weather forecasts in fall are dynamic, models are inconsistent, forecasts are poor.
- SOP backfill to near peak flow of event in the lower Cedar River, which can take a week or more to recover a flood pocket.
- Minimize turbidity so Landsburg can divert water to Lake Youngs.
- Stay below scour redd scour thresholds.
- Maintain flows to benefit sockeye hatchery broodstock collection.
- Keep sustained flows near minimum to prevent Chinook from spawning high on the river margins.

Chester Morse Reservoir #1400 Probabilistic Simulation



End

Background materials follow if needed



Masonry Dam Controls

- Passive
 - Service Spillway (Flood Invert at 1557 ft., flow ~4000 cfs at 1568 ft.)
 - Opening Service Spillway this week for flood mgt.
- Active
 - Hydro Generation (~700 cfs max)
 - SCL reports only one generator is in service
 - Second generator is planned to be in service soon
 - Release Valve (bypasses hydro ~700 cfs)
 - R-Gates Spillway (3 gates, inverts at 1538 ft., closed most of time, capable of ~75,000 cfs)
 - Turnbuckle repairs and debris removal planned for next week with Masonry Pool is at EL 1523.

Tolt Reservoir – Outlet Controls

- Morning glory Spillway (Ring Gate)
 - Sep 30th to May 1st lower to 1762 ft. for flood mgt.
 - The Ring Gate has been exercised and lowered for flood mgt
 - May 1st to Sep 30th raise to 1765 ft., for refill
 - Capacity approx. 12,300 cfs
- Spill Valve
 - 600 cfs max, can not discharge while water discharging over Ring Gate.
 - Valve 15 maintenance work complete, ready for service.
- Discharge to Treatment plant
 - Approximately 50 to 60 cfs
 - Additional 120 cfs to River
 - Valve 25 maintenance work complete, ready for service
- Fish Flow
 - 50 to 60 cfs