

SDOT Noise Variance Compliance Assessment Report #119

Reporting Date Range:	7/29/13 – 8/4/13
------------------------------	------------------

Project Summary

Variance # and Type:	3011335, Major Public Project Construction Variance
Variance Holder:	Seattle Department of Transportation
Project Name:	Mercer Corridor Improvements Project, East Phase
Contractor:	Gary Merlino Construction Company
Sound Monitoring Firm:	The Greenbusch Group, Inc.

Assessment Summary

Hourly sound level data was reviewed in accordance with the established protocol to determine the variance exceedances identified herein.

Number of Exceedances:	Courtyard Marriott (8/1/13 – 8/4/13)		
	0 (NONE)		
Number of Noise Complaints:	Project Hotline	DPD Hotline	DPD E-mail
	0 (NONE)	0 (NONE)	0 (NONE)

Variance Exceedance Details (All Sound Levels Hourly L₀₁)

Date:	N/A	Hourly Period:	N/A
Commercial Sound Level Limit:	85 dBA	Measured Sound Level:	<85 dBA
Duration Residential Sound Levels from Site Emissions Were Above 85 dBA			N/A

No noise exceedances were measured during this reporting period.

Noise Complaint Details

Date:	N/A	Complaint #:	N/A	Time:	N/A
Complainant:	N/A			Location:	N/A
Complaint Associated with Noise Source Resulting in Exceedance?					N/A

No nighttime noise complaints were received during this reporting period.

General Notes and Observations:

Two routine site visits were conducted during this reporting period. The first took place on Thursday (8/1) at 10:00 p.m. The second site visit took place on Sunday (8/4) at 10:30 p.m. All observed activities were compliant with Variance conditions during the Thursday site visit, night work had concluded prior to the Sunday site visit.

Completed by:	Justin B. Morgan	Date:	8/7/13
----------------------	------------------	--------------	--------