SDOT Noise Variance
Compliance Assessment Report #102

Reporting Date Range:	4/1/13 – 4/7/13

Project Summary

Variance # and Type:	3011335, Major Public Project Construction Variance
Variance Holder:	Seattle Department of Transportation
Project Name:	Mercer Corridor Improvements Project, East Phase
Contractor:	Gary Merlino Construction Company
Sound Monitoring Firm:	The Greenbusch Group, Inc.

Assessment Summary

Hourly sound level data was reviewed in accordance with the established protocol to determine the variance exceedances identified herein.

Number of Exceedances:	**Residence Inn (04/02/13 – 04/05/13)**		
	0 (NONE)		
Number of Noise Complaints:	**Project Hotline**	**DPD Hotline**	**DPD E-mail**
	0 (NONE)	0 (NONE)	0 (NONE)

Variance Exceedance Details (All Sound Levels Hourly L_{01})

Date:	N/A	**Hourly Period:**	N/A
Commercial Sound Level Limit:	85 dBA	**Measured Sound Level:**	<85 dBA
Duration Residential Sound Levels from Site Emissions Were Above 85 dBA			N/A

No noise exceedances were measured during this reporting period.

Noise Complaint Details

Date:	N/A	**Complaint #:**	N/A	**Time:**	N/A
Complainant:	N/A			**Location:**	N/A
Complaint Associated with Noise Source Resulting in Exceedance?					N/A

No nighttime noise complaints were received during this reporting period.

General Notes and Observations:

Sound monitoring was conducted during nighttime work hours to assess compliance with Variance limits by measuring sound levels at the nearest noise sensitive receivers. Nighttime construction activities included gas line installation on Valley Street and signage work on Mercer Street.

A routine site visit was conducted Monday 4/1 at 10:00 p.m., all observed activities were compliant with Variance conditions.

Completed by:	Justin B. Morgan & Adam C. Jenkins, PE(OR), INCE Bd. Cert	**Date:**	4/10/13