

SDOT Noise Variance Compliance Assessment Report #112

Reporting Date Range:	6/10/13 – 6/16/13
------------------------------	-------------------

Project Summary

Variance # and Type:	3011335, Major Public Project Construction Variance
Variance Holder:	Seattle Department of Transportation
Project Name:	Mercer Corridor Improvements Project, East Phase
Contractor:	Gary Merlino Construction Company
Sound Monitoring Firm:	The Greenbusch Group, Inc.

Assessment Summary

Hourly sound level data was reviewed in accordance with the established protocol to determine the variance exceedances identified herein.

Number of Exceedances:	No monitoring performed		
	N/A		
Number of Noise Complaints:	Project Hotline	DPD Hotline	DPD E-mail
	0 (NONE)	0 (NONE)	0 (NONE)

Variance Exceedance Details (All Sound Levels Hourly L₀₁)

Date:	N/A	Hourly Period:	N/A
Commercial Sound Level Limit:	85 dBA	Measured Sound Level:	N/A
Duration Residential Sound Levels from Site Emissions Were Above 85 dBA			N/A

No noise monitoring was conducted during this reporting period.

Noise Complaint Details

Date:	N/A	Complaint #:	N/A	Time:	N/A
Complainant:	N/A			Location:	N/A
Complaint Associated with Noise Source Resulting in Exceedance?					N/A

No nighttime noise complaints were received during this reporting period.

General Notes and Observations:

A routine site visit was conducted on Thursday (6/13) at 10:30 p.m. Work was being done at 9th and Broad, Westlake and Broad and Boren and Valley Street. All observed activities were compliant with Variance conditions.

Completed by:	Justin B. Morgan	Date:	6/19/13
----------------------	------------------	--------------	---------