



NOTES THIS SHEET

- 1 PROVIDE NEW PANEL AND NEW FEEDER CONDUCTOR IN EXISTING CONDUIT. RECONNECT EXISTING BRANCH CIRCUITS TO REMAIN IN SERVICE. SEE SPECIAL NOTES, SHEET E001.
- 2 PROVIDE NEW FEEDER CONDUCTOR IN EXISTING CONDUIT TO EXISTING PANEL.
- 3 PROVIDE NEW PANEL AND NEW FEEDER CONDUCTOR IN NEW CONDUIT. RECONNECT BRANCH CIRCUITS.
- 4 PROVIDE NEW PANEL. FEED FROM EXISTING 50 AMP/2 POLE BREAKER IN MAIN SWITCHBOARD. CONNECT BRANCH CIRCUITS FROM MAIN SWITCHBOARD TO NEW PANEL AND PROVIDE AND INSTALL NEW BREAKERS AS REQUIRED.
- 5 PUSH BUTTON FOR ELEVATOR DOOR CONTROL.

DISCONNECT AND ABANDON RECEPTACLE AND SAUNA CIRCUITS IN THIS AREA. SEE SPECIAL NOTES, SHEET E001.

GROUND FLOOR POWER PLAN
SCALE: 1/8" = 1'-0"
NORTH



**CONSTRUCTION DOCUMENTS
BID SET**



3		
2	BID SET	12/11/02
1	PERMIT CORRECTIONS	7/15/02
NO.	REVISION - AS BUILT	DATE

REVIEWED: *J. Johnson* 11/5/03
PARK ENGINEER DATE

All work done in accordance with the City of Seattle Standard Plans and Specifications in effect on the date shown above, and supplemented by Special Provisions.



17928 BOTHELL EVERETT HWY SE, SUITE H
BOTHELL, WASHINGTON 98012
(425) 481-7735 FAX (425) 481-7692

CONTACT: FRANK STARR
JOB NUMBER: 023261

**SAND POINT
MAGNUSON PARK
COMMUNITY RECREATION CENTER
BUILDING 47**

GROUND FLOOR POWER PLAN		
XXX		
DESIGNED	FHS	DATE JULY 23, 2002
DRAWN	MDW	DESIGN REVIEW
CHECKED	LDB	
ORDINANCE NO.	119812 & 119887	
CONTRACT NO.	1616	SHEET 71 OF 76
SCALE	1/8" = 1'-0"	