



City of Seattle
Department of Planning & Development

2012 SBC Code Solution

SBC Section 1104
Accessible Route Within Type A Unit
Release Date: January 14, 2014
Page 1 of 1

The following interpretation, policy or code alternate is intended to provide guidance to staff for consistency of review and is subject to change without notice. Application of this interpretation, policy or code alternate to specific projects may vary.

Code Issue:

Is an accessible route required to all floors of a multi-story Type A unit?

Interpretation:

Yes. There are no exceptions to the general requirement from Section 1104.3 that all portions of a Type A unit, including mezzanines, be accessible.

For questions about whether this code solution applies to your project:

- *If you have submitted a permit application, contact the Building Code plan reviewer assigned to your application*
- *If you have not submitted an application, contact DPD Building Code Technical Support at 206-684-4630 or in person at the Applicant Services Center. Visit the Applicant Services Center website for more information about hours and location http://www.seattle.gov/dpd/Permits/Process_Overview/Location_Hours/default.asp*



Construction Review & Inspection Quality
Jonathan Siu, Principal Engineer