

CONTENTS

Abbreviations	xiii
---------------------	------

Executive Summary

Background.....	ES-1
Key Findings	ES-2
Seismicity and Seismic Hazards	ES-2
SPU's Water System Seismic Vulnerability	ES-2
Increasing the Seismic Resiliency of SPU's Water System	ES-2
Identification and Definition of Seismic Hazards.....	ES-3
Vertical Facility (Nonpipeline) Assessments.....	ES-5
Pipeline Assessments	ES-5
System Analysis.....	ES-7
Treated Water Storage.....	ES-9
Performance Goals, Mitigation Recommendations, and Cost Estimates	ES-9
Performance Goals	ES-9
Mitigation Strategies	ES-10
Seismic Design Standards for New Water System Assets	ES-11
Expected Response After Seismic Improvements.....	ES-12
Cost Estimates.....	ES-12

1. Introduction

1.1	Background.....	1-1
1.2	Study Objectives	1-1
1.3	Seismic Study Team Members	1-2
1.4	Study Approach	1-2
1.5	Report Structure	1-4

2. Regional Seismicity, Earthquake Scenarios, and Seismic Hazards

2.1	Seismicity of the Puget Sound Region	2-1
2.1.1	Cascadia Subduction Zone Interplate Earthquakes	2-1
2.1.2	Cascadia Subduction Zone Intraplate Earthquakes	2-2
2.1.3	Crustal/Shallow Earthquakes	2-3

CONTENTS


2.1.4	Evolution of the Seismological Understanding in the Pacific Northwest.....	2-3
2.2	Earthquake Scenarios.....	2-5
2.3	Ground-Shaking Intensity.....	2-6
2.4	Permanent Ground Displacement Hazards.....	2-7
2.4.1	Liquefaction	2-11
2.4.2	Landslides	2-13
2.4.3	Fault Rupture and Subsidence/Uplift.....	2-13
2.4.4	Tsunami and Seiche	2-19



CONTENTS

[REDACTED]

CONTENTS



5. Water System Post Earthquake Performance and Restoration

5.1	System Response Model	5-1
5.1.1	Model Choice and Format.....	5-1
5.1.2	Model Inputs and Assumptions	5-1
5.2	Direct Service Area Model Results.....	5-9
5.3	Water Service Restoration to the Direct Service Area	5-15
5.4	Wholesale Turnout Water Availability.....	5-19
5.4.1	General Vulnerability of Transmission Pipelines that Serve Wholesale Customers	5-19
5.4.2	Transmission System Hydraulic Modeling Results	5-20
5.5	Distribution System Storage Analysis.....	5-20
5.5.1	Storage Comparisons	5-23
5.5.2	Hydraulic Analysis	5-24
5.5.3	Baseline Analysis.....	5-24
5.5.4	20-Year and 50-Year Analysis	5-25
5.5.5	Other Factors.....	5-25
5.5.6	Recommendation.....	5-26

6. Seismic Mitigation Recommendations and Cost Estimates

6.1	Proposed Post-earthquake Performance Goals	6-1
6.1.1	SPU Water System Performance Goals for 2045.....	6-2
6.1.2	SPU Water System Performance Goals for 2075.....	6-2
6.1.3	Water Supply at Wholesale Meters	6-6
6.1.4	Fire Suppression Water–Water to Within 2,500 Feet of Any Point Within the City Via Seismic-Resistant Pipelines	6-6
6.1.5	Water Supply for Critical Retail Customers	6-6
6.1.6	Water Supply to the Direct Service Area	6-6
6.1.7	Emergency Water Supply	6-7
6.1.8	Water Potability.....	6-7
6.1.9	Life Safety and Property Damage	6-7

CONTENTS

6.2	Seismic Mitigation and Improvement Strategies.....	6-7
6.2.1	Transmission System Upgrades	6-8
6.2.2	Isolation and Control	6-12
6.2.3	Seismic Design Standards	6-14
6.2.4	Critical Vertical Facility Upgrades.....	6-14
6.3	Seismic Resiliency Improvement Program, Proposed Schedule, and Planning Level Cost Estimates	6-15
 7. Emergency Preparedness and Response Planning		
7.1	Post-earthquake Repair Resources	7-1
7.2	Earthquake-Specific Emergency Preparedness and Response Planning.....	7-7
7.3	Emergency Drinking Water	7-8
 8. Seismic Design Standards for New Facilities and Pipelines		
8.1	New Nonpipeline Facilities	8-1
8.2	Occupancy Category for Nonpipeline Facilities	8-1
8.3	Existing Facilities	8-2
8.4	Seismic Design Standards for New Buried Pipelines	8-2
8.4.1	Pipeline Classifications	8-2
8.4.2	Pipeline Standards Background	8-4
8.4.3	Proposed Standards for Incorporation Into SPU's Design Standards and Guidelines.....	8-5
 Appendix A – Facilities Evaluated by Reid Middleton		
 Appendix B – Hydraulic Modeling Results		
 Appendix C – Representative Water Utility Performance Goals		
 Appendix D – Draft SPU Seismic Standards for New Pipe		
 References		

CONTENTS


Figures

Executive Summary

Figure ES-1. Potential earthquake sources in the Pacific Northwest (USGS 2001)	ES-4
Figure ES-2. SPU water system earthquake hazards map	ES-6
Figure ES-3. Retail service area restoration estimates after catastrophic earthquakes	ES-8

2. Regional Seismicity, Earthquake Scenarios, and Seismic Hazards

Figure 2-1. Western Washington earthquake hazards (USGS 2001)	2-2
Figure 2-2. Tectonic plate block movement (Wells et al. 2000)	2-4
Figure 2-3. M7.0 SFZ peak ground accelerations.....	2-8
Figure 2-4. M9.0 CSZ peak ground accelerations	2-9
Figure 2-5. 2014 USGS probabilistic peak ground accelerations.....	2-10
Figure 2-6. SPU distribution and transmission area seismic hazards	2-12
Figure 2-7. M7.0 SFZ distribution pipelines liquefaction displacement estimates	2-14
Figure 2-8. M9.0 CSZ distribution pipelines liquefaction displacement estimates	2-15
Figure 2-9. M7.0 SFZ liquefaction probability of occurrence estimates.....	2-16
Figure 2-10. M9.0 CSZ liquefaction probability of occurrence estimates	2-17
Figure 2-11. Seattle Fault Zone (Map by Lettis Consultants International 2016a).....	2-18
Figure 2-12. Tsunami inundation map for Seattle from a Seattle Fault event (Walsh et al. 2003)	2-20



5. Water System Post Earthquake Performance and Restoration

Figure 5-1. SSRA model schematic	5-2
Figure 5-2. Water loss (gpm) at 60 psi for M7.0 SFZ scenario (north service area).....	5-4

CONTENTS

Figure 5-3. Water loss (gpm) at 60 psi for M7.0 SFZ scenario (north central direct service area)	5-5
Figure 5-4. Water loss (gpm) at 60 psi for M7.0 SFZ scenario (south central direct service area)	5-6
Figure 5-5. Water loss (gpm) at 60 psi for M7.0 SFZ scenario (southern direct service area)..	5-7
Figure 5-6. Fraction of direct service area (vertical axis) with water pressure versus time (horizontal axis) for M7.0 SFZ and M9.0 CSZ base cases	5-10
Figure 5-7. Fraction of direct service area with water pressure (vertical axis) versus time (horizontal axis) if the Cedar River transmission system could supply water to the direct service area	5-13
Figure 5-8. Fraction of direct service area with water pressure (vertical axis) versus time (horizontal axis) if the Tolt River transmission system could supply water to the direct service area	5-14
Figure 5-9. System restoration estimation curves for current SPU water system.....	5-18
Figure 5-10. Post-earthquake water availability after the M7.0 SFZ earthquake scenario (gray circles indicate zero water pressure at wholesale turnouts/nodes east of Seattle).....	5-22
Figure 5-11. Baseline hydraulic analysis (percentage of direct service area with water pressure on the vertical versus hours after the event).....	5-24
Figure 5-12. 20-year hydraulic model analysis (fraction of direct service area with water pressure on the vertical versus hours after the event)	5-25
Figure 5-13. 50-year hydraulic model analysis (fraction of direct service area with water pressure on the vertical versus hours after the event)	5-26

6. Seismic Mitigation Recommendations and Cost Estimates

Figure 6-1. Current estimated transmission pipeline seismic vulnerability for M7.0 SFZ and M9.0 CSZ and restoration time	6-9
Figure 6-2. Estimated transmission pipeline seismic vulnerability for M7.0 SFZ and M9.0 CSZ and restoration time in 2045.....	6-11
Figure 6-3. Estimated transmission pipeline seismic vulnerability for M7.0 SFZ and M9.0 CSZ and restoration time in 2075.....	6-13

8. Seismic Design Standards for New Facilities and Pipelines

Figure 8-1. SPU critical pipeline map	8-3
---	-----

CONTENTS


Tables

Executive Summary

Table ES-1. Recommended mitigation plan summary and order of magnitude cost estimates	ES-13
---	-------

1. Introduction

Table 1-1. Facilities not included in SPU's seismic study	1-5
---	-----



5. Water System Post Earthquake Performance and Restoration

Table 5-1. Hydraulic modeling cases	5-11
Table 5-2. Transmission pipeline repair time estimates.....	5-17
Table 5-3. SPU Major Distribution Reservoirs	5-21
Table 5-4. Storage comparison with other West Coast utilities.....	5-23

6. Seismic Mitigation Recommendations and Cost Estimates

Table 6-1. Proposed post-earthquake water system level of service goals for 2045 after M7.0 Seattle Fault Zone or M9.0 Cascadia Subduction Zone earthquake scenarios.....	6-3
Table 6-2. Proposed post-earthquake water system level of service goals for 2075 after M7.0 Seattle Fault Zone or M9.0 Cascadia Subduction Zone earthquake scenarios.....	6-4
Table 6-3. Preliminary mitigation schedule and planning level (order of magnitude) cost estimates	6-5

7. Emergency Preparedness and Response Planning

Table 7-1. Recommended transmission pipeline repair pipe	7-3
Table 7-2. Recommended distribution pipeline repair pipe	7-5