



EARLY DESIGN GUIDANCE OF THE EAST DESIGN REVIEW BOARD

Record Number: 3039544-EG

Address: 112 10<sup>th</sup> Ave E

Applicant: David Neiman, Neiman Taber Architects

Date of Meeting: Wednesday, August 24, 2022

Board Members Present: Gina Gage  
Michael Cannon  
Emily van Geldern  
Joe Reilly

Board Members Absent: Christopher Bendix


SDCI Staff Present: David Sachs

SITE & VICINITY

Site Zone: Midrise (M1)

Nearby Zones: (North) Neighborhood Commercial 2-75 (M1)  
(South) Midrise (M1)  
(East) Midrise (M1)  
(West) Neighborhood Commercial 3-75 (M1)

Lot Area: 37,637 sq. ft.



### **Current Development:**

The subject site occupies nearly a full block and is comprised of nine existing tax parcels currently developed with single-family residences built from 1901 to 1908. Irregular site geometry provides midblock street frontage on 10<sup>th</sup> Ave E to the west, 11<sup>th</sup> Ave E to the east, and E Denny Way to the south. The site slopes downward northeast to southwest approximately twelve feet. One Exceptional California bay laurel tree is present on the eastern side of the property.

### **Surrounding Development and Neighborhood Character:**

The subject site is located in the First Hill/Capitol Hill Urban Center. The neighborhood is largely comprised of single-family and multifamily residential uses, with larger-scale commercial and mixed-use structures present along the Broadway E commercial corridor one block to the west and 15<sup>th</sup> Ave E four blocks to the east. Neighborhood green space Cal Anderson Park is to the south of E Denny Way. Institutional buildings comprising the Seattle Central College campus are to the southwest along Broadway E. At the north end of the block, minor arterial E John St provides east-west circulation through the neighborhood and connectivity to other arterial streets.

The proximate vicinity is characterized by a residential character despite a mix of building scales and typologies. Architectural styles in the vicinity include historic, mid-century, and contemporary. Single-family residences are generally two- to three-stories in height with traditional features including recessed entries, pitched roof forms, a front stoop or porch, and lap siding. Multifamily residential structures range in height from four stories for older structures to eight stories for newer developments. Masonry materials are prevalent, with rhythmic fenestration patterns extending to the upper stories. Newer contemporary construction commonly is defined by rectilinear massing above defined single-level podiums and heavy glazing at the pedestrian level. The greater Capitol Hill neighborhood and adjacent non-arterial streets are adorned by tree-lined streets and greenspaces.

The area was rezoned from Lowrise 3 to Midrise (M1) on 4/19/19. The Capitol Hill neighborhood has experienced a growth trend in recent years in which midrise mixed-use developments are replacing lowrise structures in response to zoning changes intended to create housing. Multiple projects in the vicinity are currently under review or under construction for proposed development, including 1014 E John St, 218 10<sup>th</sup> Ave E, 222 10<sup>th</sup> Ave E, and 1800 E Olive Way.

### **Access:**

Vehicle access is proposed from 10<sup>th</sup> Ave E. Pedestrian access is proposed from 10<sup>th</sup> Ave E, 11<sup>th</sup> Ave E, and E Denny Way.

### **Environmentally Critical Areas:**

No mapped environmentally critical areas are located on the subject site.

## PROJECT DESCRIPTION

Design Review Early Design Guidance for an 8-story, 293-unit apartment building. Parking for 63 vehicles proposed.

The design packet includes information presented at the meeting, and is available online by entering the record number at this website:

<http://www.seattle.gov/DPD/aboutus/news/events/DesignReview/SearchPastReviews/default.aspx>

Any recording of the Board meeting is available in the project file. This meeting report summarizes the meeting and is not a meeting transcript.

The packet is also available to view in the file, by contacting the Public Resource Center at SDCl:

**Mailing Public Resource Center**

**Address:** 700 Fifth Ave., Suite 2000

P.O. Box 34019

Seattle, WA 98124-4019

**Email:** [PRC@seattle.gov](mailto:PRC@seattle.gov)

## EARLY DESIGN GUIDANCE August 24, 2022

### PUBLIC COMMENT

The following public comments were offered at this meeting:

- Supported Option C with entry courtyard, central lobby and large number of total units, 2<sup>nd</sup> preference would be Option A, and the 3<sup>rd</sup> would be Option B.
- Supported the departures required for Option C.
- Opined sensitivity to the loss of an exceptional tree but preferred more dense housing near transit instead of more trees removed elsewhere.
- Preferred Option 4 with the green space adjacent to Cal Anderson Park and allows for more distance between the building to the east, but supported Option C if there was a large open courtyard facing the park.
- Opined that this is a funky looking building due to the nature of the development site but thinks it meets the Capitol Hill Design Guidelines well, responds to context, and much needed housing in the community.
- Encouraged more vertical modulation and recesses in the architecture to help mitigate noise impacts from traffic.
- Opposed to the departures proposed and removal of the tree because it allows for a building of excessive size and is not in the best interest of the neighborhood.

Seattle Public Utilities Solid Waste offered the following comments.

- The preferred EDG design does not follow SPU solid waste guidance and recommendations.
- SPU does not support the use of uncompacted or detached compacted containers for this project due to the significant amount of solid waste estimated to be generated from this site.
- SPU strongly encourages the project to plan onsite roll-off garbage/recycle services.
- SPU requires turning studies that demonstrate trucks can back up to compactors with adequate clearance to protect private property.
- SPU strongly encourages on-floor solid waste services for all three waste streams - garbage, recycle, and food waste.

The Seattle Department of Transportation offered the following comments:

- Stated a 6" curb, minimum 6' sidewalk, and minimum 5.5' planting strip with street trees are required along each street frontage.
- Stated the existing street trees are required to be protected and retained.
- Conceptually supported the proposed location for vehicle access off 10<sup>th</sup> Ave E as it appears to have the least impact on the existing street trees.
- Strongly recommended moving the existing sidewalk on E Denny Way back approximately 2' to provide additional room for the existing street trees.
- Strongly recommended onsite solid waste staging and collection and supported departures that would allow it.

SDCI staff also summarized design related comments received in writing prior to the meeting:

- Suggested a less prominent car entry ramp.
- Preferred Option A which retains the Exceptional tree or Option C which replaces the Exceptional tree with a landscaped courtyard.
- Opined that Option C would lend a better street design by not having the waste garage and associated curb cut on 11<sup>th</sup> Ave E.
- Discouraged Option B as replacing the Exceptional tree with additional developable area doesn't seem like an appropriate trade off.
- Encouraged durable and high-quality exterior building materials, such as brick or metal instead of cement board, to complement the surrounding neighborhood context.
- Opposed to Options B and C as they propose removing the Exceptional tree.
- Several comments advocated for retaining the Exceptional tree.

SDCI received non-design related comments concerning housing demand, parking, density, housing affordability, and the permitting process.

One purpose of the design review process is for the Board and City to receive comments from the public that help to identify feedback and concerns about the site and design concept, identify applicable Seattle Design Guidelines and Neighborhood Design Guidelines of highest priority to the site and explore conceptual design, siting alternatives and eventual architectural

design. Concerns with off-street parking, traffic and construction impacts are reviewed as part of the environmental review conducted by SDCl and are not part of this review.

All public comments submitted in writing for this project can be viewed using the following link and entering the record number (3039544-EG): <http://web6.seattle.gov/dpd/edms/>

## **PRIORITIES & BOARD RECOMMENDATIONS**

After visiting the site, considering the analysis of the site and context provided by the proponents, and hearing public comment, the Design Review Board members provided the following siting and design guidance.

### **1. Massing Options and Exceptional Tree:**

- a. The Board acknowledged the complicated nature of the site with its conglomeration of many parcels and appreciated the applicant's proposed massing options and how they each addressed and incorporated the three street frontages, proposed practical internal connection, and considered the expression of the massing when viewed from various locations in the neighborhood. After much deliberation, the Board recommended the applicant continue to develop Option C with its single building approach while incorporating certain aspects of Option B, such as the clear break between the massing, continuous massing along the 11<sup>th</sup> Ave E street frontage, and implied modulation on all sides of the building. (CS2-A-2, CS2-B, CS2-C-3, CS2-D-1, CS2-D-5, CS2-2, PL1-2-a, DC2-A, DC2-E)
- b. The Board noted the large and imposing roofline proposed on Option C and stressed that the perceived visual breaks in the massing into three distinct parts silhouetted against the sky was critical to understanding the scale of the building in relationship to block and the three street frontages when viewed from the public right-of-way and Cal Anderson Park to the south. The Board acknowledged that completely severing the internal building connection at the center of the site would be problematic to the efficiency of the overall building while maintaining the single building plan. The Board, therefore, recommended that the applicant study ways to provide substantial recessed modulation and breaks in the upper levels. The Board also recommended incorporating large expanses of transparency and bridging elements, parapet modulation, and other architectural means to mitigate the perceived bulk of the building. (CS2-A-2, CS2-B, CS2-C-3, CS2-D-1, CS2-D-5, CS2-2, PL1-2-a, DC2-A, DC2-E)
- c. Moving forward, the Board recommended that the applicant incorporate the elevator and stair bulkheads into the design of the overall massing and to minimize their impact on the perceived height, bulk, and scale of the building. (DC2-A)
- d. The Board supported the incorporation of rooftop amenity decks to take advantage of views of Cal Anderson Park and the neighborhood. Moving forward, the Board recommended that rooftop decks be studied along with the overall massing modulation and articulation to help reinforce the overall architectural concept. (DC2-A)
- e. In response to public comment, the Board recommended that the applicant study the relationship of the massing and setbacks proposed on all sides of the proposed

development with those provided on adjacent sites to ensure that massing setbacks respond appropriately to the various side and rear yard conditions and address privacy concerns. Members of the public and the Board specifically highlighted the relationship between the west side of the development parcel fronting 11<sup>th</sup> Ave E and the adjacent parcel to the west fronting 10<sup>th</sup> Ave E as an area of concern. (DC2-D-5)

- a. Both members of the public and the Board were sympathetic to the retention of the Exceptional California Bay Laurel tree on 11<sup>th</sup> Ave E and appreciated how the massing of Option C responded by setting back the building massing to provide space around it and to incorporate it into the open space and residential amenity design. However, after some deliberation, the Board concluded that the retention of the tree adversely impacted how well the overall massing and ground level uses related to the 11<sup>th</sup> Ave E street frontage. The Board, therefore, supported the removal of the Exceptional tree so that more mass and ground level uses could be placed along the 11<sup>th</sup> Ave street frontage, better meeting the intent of the Design Guidelines. The Board also noted that if the Exceptional tree was removed, adequate amount of replacement tree canopy would be required. (DC2-A-1, CS2-B-2, CS2-C-2, PL3-A-4, DC3-1)

## **2. Context Analysis and Ground Level Uses:**

- a. The Board appreciated the applicant's extensive urban design analysis related to the development context included in the EDG packet, however, the Board was concerned that there was inadequate analysis of circulation patterns in the immediate neighborhood context to help explain the proposed access points, pathway connections, and ground level uses including lobbies, building services, and vehicle access. Moving forward, the Board recommended that the applicant further study circulation in and around the neighborhood, the right-of-way and access conditions across the street on 10<sup>th</sup> Ave, 11<sup>th</sup> Ave E and E Denny Way, and provide diagrams that show how this analysis impacted the site planning and ground level uses proposed on the three street frontages and within the site. (CS2-B, CS2-2, PL1, PL1-1, PL1-3)
- b. The Board appreciated that residential entrances were proposed on each street frontage in response to the various circulation paths around the site, however, the Board was concerned with the main residential courtyard and entrance being located off 11<sup>th</sup> Ave E, instead of from E Denny Way. The Board recommended that the applicant locate the main residential lobby, courtyard, and active amenity spaces on E Denny Way to better relate to Cal Anderson Park to the south. The Board also noted that any courtyards or semi-public spaces should be at grade. (PL1-1-a, PL1-1-b, PL3-B-4)
- c. The Board appreciated the townhouse style units proposed along 11<sup>th</sup> Ave E, as shown on page 74 of the EDG packet, and recommended that these units be retained moving forward as they provide a scaled use appropriate for the smaller scaled residential character on this street. (PL3-B-2, PL3-1-c, PL3-2)
- d. The Board appreciated the large centrally located interior and exterior amenity spaces proposed in Option C but noted that the ground level plan did not promote connectivity through the site from each of the residential entries. Moving forward,

the Board recommended that the applicant continue to develop the ground level plan and locate active amenity spaces throughout that would engage with exterior spaces while promoting residential circulation through the site. (DC1-A, DC3-A, DC3-B-1)

- e. In agreement with the public comments by Seattle Public Utilities, the Board recommended the applicant locate the solid waste room on 11<sup>th</sup> Ave E with direct access from the street to avoid solid waste staging in the right-of-way which would cause congestion on the narrow street during pick up. (DC1-B-1, DC1-2-a)
- f. Echoing comments submitted by the Seattle Department of Transportation, the Board supported the proposed vehicle access from 10<sup>th</sup> Ave E with the driveway located at the southern end of the street frontage as it allowed for the retention of the three existing street trees in the right-of-way. Moving forward, the Board recommended that the applicant further study the location of the driveway in conjunction with the circulation analysis recommended in item 2.a. to ensure that pedestrian safety is maintained along the street frontage, vehicle access across 10<sup>th</sup> Ave E is taken into consideration, and tree preservation goals are met. (DC1-B-1, DC1-2-a)
- g. The Board strongly supported the expanded planting strip along the E Denny Way right-of-way as requested by the Seattle Department of Transportation and shown in the EDG packet. The Board appreciated that this larger planting strip will promote the continued health of the existing street trees. (PL1-1-b)

### **3. Architectural Concept and Façade articulation:**

- a. The Board appreciated the applicant's analysis of façade articulation strategies found within the neighborhood which include those that treat the massing as one cohesive whole and those that break down the perceived height, bulk, and scale through a more fragmented articulation, as shown on page 21 of the EDG packet. The Board recommended that the applicant move forward with a more holistic architectural concept that creates visual difference between the three masses through façade articulation that relates to the scale of the neighborhood, the different street frontages, and the residential character of the immediate context. The Board specifically noted that the façade articulation shown on pages 72-73 appeared commercial in character and lacked the scale appropriate for a residential building in this neighborhood. (CS2-C-3, CS2-C-5, DC2, DC2-3)
- b. The Board noted that the residential entries, as depicted on pages 72-72, lacked secondary architectural features such as canopies, unique storefront and door designs, decorative lighting, and other elements typically used to help provide pedestrian scale and identifiability. Moving forward, the Board recommended that the applicant study the articulation of each residential entry and its outdoor space to include those elements that reinforce the residential nature of the building at ground level. (PL3-A, PL3-1-b, DC2-C)
- c. Moving forward, the Board recommended that the applicant use a material palette made up of high-quality materials that reinforce the overall architectural concept and provide scale and texture consistent with the materials found in the neighborhood. (DC2-B-1, DC2-C, DC2-D-2, DC4-A-1, DC2-C-3, CS3-A-1)

- d. In agreement with the applicant, the Board acknowledged that all façades will be visible from the street and from adjacent properties for some time. The Board recommended that the applicant take into consideration the relationship with Cal Anderson Park to the south, the views from each street frontage, and issues of proximity and privacy with adjacent properties. Moving forward, the Board requested perspectives and privacy studies showing how the façade design relates to the various conditions around it. (PL1-1-a, DC2-D-5)

## DEVELOPMENT STANDARD DEPARTURES

The Board's recommendation on the requested departures will be based on the departure's potential to help the project better meet these design guidelines priorities and achieve a better overall project design than could be achieved without the departures. The Board's recommendation will be reserved until the final Board meeting.

At the time of the Early Design Guidance meeting the following departures were requested:

1. **Setback and Separations (23.45.518.B):** The Code requires in MR zones a 15 feet setback from a rear lot line that does not abut an alley in MR zones. The applicant proposes a rear lot line setback of 11.68 feet.

The Board was divided in their preliminary support for the requested departure from rear lot line setback requirements. Those in favor, supported the proposed design rationale. Those in dissent, indicated their support at the Recommendation phase was tied to further development of the massing as it relates to 11<sup>th</sup> Ave E and an increase in the side lot line setback to the west as discussed within this report. If all recommendations and guidance in this report are resolved, the design with this departure has the potential to better meet the intent of Design Guideline PL1-1, Enhancing Open Space and PL1-4, Outdoor Uses and Activities.

2. **Structural Width (23.45.528.A):** The Code requires for lots greater than 9,000 square feet in MR zones that the width of a principal structure shall not exceed 150 feet. The applicant proposes a principal structure width of 236 feet.

The Board indicated preliminary support of this departure finding that the additional length allows for a more efficient single building approach to the complicated conglomeration of parcels. The success of the design relies on the clear articulation of the massing into 3 discernable parts and if all of the recommendations and guidance in this report are resolved, the design with this departure has the potential to better meet this intent of Design Guidelines PL1-1, Enhancing Open Space; DC3-1, Open Space Uses and Accessibility; CS2-C-3, Full Block Sites.

3. **Structural Depth (23.45.528.B):** The Code requires for lots greater than 9,000 square feet in MR zones that the depth of a principal structure shall not exceed 80 percent of

the depth of the lot (224.11 feet). The applicant proposes a principal structure that is 92.6 percent of the depth of the lot (259.66 feet).

The Board indicated preliminary support of this departure finding that the additional depth allows for a more efficient single building approach to the complicated conglomeration of parcels. The success of the design relies on the clear articulation of the massing into 3 discernable parts and if all of the recommendations and guidance in this report are resolved, the design with this departure has the potential to better meet this intent of Design Guidelines PL1-1, Enhancing Open Space; DC3-1, Open Space Uses and Accessibility; DC3-A, Building Open Space Relationship: Interior/Exterior Fit.

4. **Access Standards (23.54.030.G):** The Code requires for two way driveway less than 22 feet wide, a sight triangle on both sides of the of the driveway or easement shall be provided. The applicant proposes a 20 feet wide driveway with a sight triangle on the north side only.

The Board indicated preliminary support of this departure finding that the straight driveway adjacent to the property line gives higher priority to pedestrians along the street frontage and allows for less disturbance to the root zone of the nearest street tree to the north. The success of the design relies a clear understanding of the impact on the vehicle entry for the building across 10<sup>th</sup> Ave E and if all of the recommendations and guidance in this report are resolved, the design with this departure has the potential to better meet this intent of Design Guidelines PL1-1-b, Right of Way; DC1-2-a, Parking and Service Uses; D-6, Design for Personal Safety and Security; and E-1, Minimize Curb impacts.

## DESIGN REVIEW GUIDELINES

The Seattle Design Guidelines and Neighborhood Design Guidelines recognized by the Board as Priority Guidelines are identified above. All guidelines remain applicable and are summarized below. For the full text please visit the [Design Review website](#).

### CONTEXT & SITE

**CS1 Natural Systems and Site Features: Use natural systems/features of the site and its surroundings as a starting point for project design.**

#### CS1-A Energy Use

**CS1-A-1. Energy Choices:** At the earliest phase of project development, examine how energy choices may influence building form, siting, and orientation, and factor in the findings when making siting and design decisions.

#### CS1-B Sunlight and Natural Ventilation

**CS1-B-1. Sun and Wind:** Take advantage of solar exposure and natural ventilation. Use local wind patterns and solar gain to reduce the need for mechanical ventilation and heating where possible.

**CS1-B-2. Daylight and Shading:** Maximize daylight for interior and exterior spaces and minimize shading on adjacent sites through the placement and/or design of structures on site.

**CS1-B-3. Managing Solar Gain:** Manage direct sunlight falling on south and west facing facades through shading devices and existing or newly planted trees.

**CS1-C Topography**

**CS1-C-1. Land Form:** Use natural topography and desirable landforms to inform project design.

**CS1-C-2. Elevation Changes:** Use the existing site topography when locating structures and open spaces on the site.

**CS1-D Plants and Habitat**

**CS1-D-1. On-Site Features:** Incorporate on-site natural habitats and landscape elements into project design and connect those features to existing networks of open spaces and natural habitats wherever possible. Consider relocating significant trees and vegetation if retention is not feasible.

**CS1-D-2. Off-Site Features:** Provide opportunities through design to connect to off-site habitats such as riparian corridors or existing urban forest corridors. Promote continuous habitat, where possible, and increase interconnected corridors of urban forest and habitat where possible.

**CS1-E Water**

**CS1-E-1. Natural Water Features:** If the site includes any natural water features, consider ways to incorporate them into project design, where feasible.

**CS1-E-2. Adding Interest with Project Drainage:** Use project drainage systems as opportunities to add interest to the site through water-related design elements.

**Capitol Hill Supplemental Guidance:**

**CS1-1 Energy Choices**

**CS1-1-a. Influence the Building Form:** Consider how opportunities to provide and integrate high performance, regenerative design opportunities such as external direct heating/cooling systems and renewable energy generation, individual meters for each residential unit, and public sharing of energy can influence the building form. When possible, include sustainability measures/energy use that can be viewed from the public realm.

**CS1-1-b. Site Configuration:** Take advantage of site configuration to invest in new technologies to harvest onsite energy beyond minimum code requirements. Suggestions: photovoltaic arrays, wastewater heat recovery (plumbing heat waste), reverse cycle chiller to harvest heat energy from below-grade garage levels.

**CS1-2 Sunlight, Shade and Natural Ventilation**

**CS1-2-a. Passive Ventilation:** Provide passive ventilation through operable windows (in both residential units and commercial spaces) to reduce the need for mechanical ventilation, where possible.

**CS1-2-b. Consider Interior Spaces:** Encourage louvers, projecting sunshades, or other design details that provide shading (to reduce solar heat gain) while still optimizing daylight for interior spaces.

### **CS1-3 Topography**

**CS1-3-a. Step Facades:** Respond to local topography with stepping facades or floorplates so that commercial and/or shared residential entrances and ground floors roughly match the street grade.

**CS1-3-b. Pedestrian Amenities:** Include pedestrian amenities and open space that provide respite, such as seating, in areas adjacent to the public realm along steep slopes.

### **CS1-4 Plants and Habitat**

**CS1-4-a. Wildlife Corridors:** Enhance urban wildlife corridors by creating new habitat and/ or preserving or expanding existing habitats for insects and birds through design and plantings for green roofs, walls, and gardens.

**CS1-4-b. Enhance Habitat:** Encourage the use of pollinator friendly and other native/naturally growing plant species to enhance habitat for birds and insects. Use vertical layers of plants to provide habitat for a variety of species.

**CS1-4-c. Landscape Variation:** Encourage the use of diverse planting palettes to create variety in landscapes at the block and neighborhood level.

**CS1-4-d. Natural Wood:** Consider opportunities to incorporate natural wood elements such as snags and nurse logs, which provide habitat to invertebrates, into landscape design.

**CS1-4-e. Tree Canopy:** Maximize preservation of the area's existing tree canopy. Encourage the integration of any exceptional trees or heritage trees, or other mature plantings, into the project design. Mature street trees have a high value to the neighborhood. Protect the health and longevity of existing mature street trees when designing the footprint of a new building.

### **CS1-5 Water Features**

**CS1-5-a. Sustainability:** Consider sustainable design opportunities such as shared water systems for rainwater harvesting, greywater reuse, and blackwater processing/reuse. Reduce flows into the municipal stormwater system through stormwater management, green roofs and walls, and swales. Consider other functional solutions for sustainable water reuse and/or drainage that work well with the neighborhood's soil condition and topography.

**CS1-5-b. Irrigation:** Design landscapes that reduce potable water use for irrigation such as via the following strategies:

- Reuse captured stormwater, greywater, HVAC blowdown or condensate for irrigation.
- Specify plants, soils, and other features to be self-sustaining with natural precipitation only.
- Design planting zones so that plantings no longer require irrigation once established.

**CS2 Urban Pattern and Form: Strengthen the most desirable forms, characteristics, and patterns of the streets, block faces, and open spaces in the surrounding area.**

### **CS2-A Location in the City and Neighborhood**

**CS2-A-1. Sense of Place:** Emphasize attributes that give a distinctive sense of place. Design the building and open spaces to enhance areas where a strong identity already exists, and create a sense of place where the physical context is less established.

**CS2-A-2. Architectural Presence:** Evaluate the degree of visibility or architectural presence that is appropriate or desired given the context, and design accordingly.

**CS2-B Adjacent Sites, Streets, and Open Spaces**

**CS2-B-1. Site Characteristics:** Allow characteristics of sites to inform the design, especially where the street grid and topography create unusually shaped lots that can add distinction to the building massing.

**CS2-B-2. Connection to the Street:** Identify opportunities for the project to make a strong connection to the street and public realm.

**CS2-B-3. Character of Open Space:** Contribute to the character and proportion of surrounding open spaces.

**CS2-C Relationship to the Block**

**CS2-C-1. Corner Sites:** Corner sites can serve as gateways or focal points; both require careful detailing at the first three floors due to their high visibility from two or more streets and long distances.

**CS2-C-2. Mid-Block Sites:** Look to the uses and scales of adjacent buildings for clues about how to design a mid-block building. Continue a strong street-edge and respond to datum lines of adjacent buildings at the first three floors.

**CS2-C-3. Full Block Sites:** Break up long facades of full-block buildings to avoid a monolithic presence. Provide detail and human scale at street-level, and include repeating elements to add variety and rhythm to the façade and overall building design.

**CS2-D Height, Bulk, and Scale**

**CS2-D-1. Existing Development and Zoning:** Review the height, bulk, and scale of neighboring buildings as well as the scale of development anticipated by zoning for the area to determine an appropriate complement and/or transition.

**CS2-D-2. Existing Site Features:** Use changes in topography, site shape, and vegetation or structures to help make a successful fit with adjacent properties.

**CS2-D-3. Zone Transitions:** For projects located at the edge of different zones, provide an appropriate transition or complement to the adjacent zone(s). Projects should create a step in perceived height, bulk and scale between the anticipated development potential of the adjacent zone and the proposed development.

**CS2-D-4. Massing Choices:** Strive for a successful transition between zones where a project abuts a less intense zone.

**CS2-D-5. Respect for Adjacent Sites:** Respect adjacent properties with design and site planning to minimize disrupting the privacy of residents in adjacent buildings.

**Capitol Hill Supplemental Guidance:**

**CS2-1 Sense of Place; Distinctive Streets:** New buildings should support and enhance distinct corridors, nodes, open spaces, and places as they continue to grow. Buildings along distinct corridors should reinforce and activate the street edge. Buildings should also incorporate pedestrian scale materials, modulation, and façade detailing at the street level. The following design guidelines apply to all buildings along the respective street:

**CS2-1-a. Broadway:** Broadway, the largest and longest retail corridor in the CHUCV, includes smaller storefronts as well as larger-scale buildings of Seattle Central College. Broadway's 80-foot wide right-of-way accommodates transit, vehicles, bikes, and pedestrians. The gap created by light rail station construction weakened the corridor, but new development will return Broadway to a more continuous retail and pedestrian experience.

- Reinforce the character of Broadway as one of Capitol Hill's most prominent and vibrant shopping and public main streets. Encourage the design of pedestrian scaled, intimate storefronts on facades facing Broadway.
- Consider active pedestrian transition areas between the street level building façade and sidewalk for outdoor café seating and walk-up windows.
- Enhance visual connections and pedestrian flows to and from the Capitol Hill light rail station as well as the Seattle Central College campus.

**CS2-1-b. 12<sup>th</sup> Avenue:** 12th Avenue is the only retail corridor within the CHUCV that is not a designated principal pedestrian street. Thus, more residential uses occur at street level than in other corridors. Commercial zoning and retail activity end just north of Denny Way, and the street quickly assumes a residential character. The 12th Avenue Arts development, just outside the CHUCV, has brought new affordable housing, retail and cultural uses to the corridor, and created strong connection to the more prominent retail corridor on E Pine Street.

- Enhance the character and pedestrian experience along 12th Ave as it evolves into a mixed-use corridor between E Denny Way and E Olive St.

**CS2-1-c: 15<sup>th</sup> Avenue Corridor:** 15th Avenue E is known for its lively mix of locally-owned businesses, larger format grocery stores that serve multiple neighborhoods, and the Kaiser Permanente campus. Despite the street's narrow sidewalks, many businesses have outside seating or displays that add vitality to the street.

- Encourage façade detailing at the street level that contributes to the street's existing intimate retail character and variety of pedestrian scaled storefronts.
- Consider design approaches that visually integrate the street level façade with existing buildings. Use upper level setbacks to reinforce the street-scale retail character.
- Improve the walkability along 15th Ave while maintaining the street's positive intimate pedestrian character.
- On half block or full block developments break up long facades to avoid a monolithic presence and to add to the existing character of the corridor.
- Enhance visual connections and pedestrian flows to and through the Kaiser Permanente campus.

**CS2-1-d. E John Street/E Olive Way Corridor:** John Street/E Olive Way is a major east/west link between CHUCV, downtown and South Lake Union. The sloping, curving corridor is dotted with older buildings housing eclectic small-scale retail and restaurants, as well as newer, taller mixed-use buildings. The topography of the corridor offers views from the public right-of-way of downtown, Puget Sound, and the Olympic Mountains.

- Emphasize Olive Way as a commercial corridor and gateway to the neighborhood from Downtown.
- Encourage better east/west connections for pedestrians traveling to and from the Capitol Hill light rail station between Broadway and 15th Ave E.
- Encourage street level commercial activity and the addition of pedestrian amenities along the street edge between 13th Ave and 15th Ave.
- Enhance the walkability between Melrose Ave and Broadway with the addition of accessible open space and pedestrian amenities along this distinctive curving street edge.

**CS2-1-e. E Madison Street:** E Madison Street is a major retail and transit corridor. These three blocks within the CHUCV represents the highest elevation along the corridor as well as a break in the principal pedestrian street designation. This short stretch includes the iconic, green-built Bullitt Center, the revitalized McGilvra Place, two grocery stores (Trader Joe’s and Central Co-op), both pedestrian and auto-oriented retail, and a radio tower.

- Encourage a pedestrian orientation to complement adjacent blocks.
- Explore ways to celebrate this high point on Madison Street.

**CS2-1-f. Melrose Avenue:** Recognize and reinforce Melrose Avenue as the “front porch” of Capitol Hill. Encourage the addition of open space, bicycle, and pedestrian amenities along the street edge, and strengthen pedestrian connections to other parts of Capitol Hill and adjacent neighborhoods.

**CS2-1-g. Neighborhood Nodes:** Recognize and strengthen the small neighborhood commercial areas located at Summit Ave. E and E Mercer Street, and at Bellevue Ave and Bellevue Place which bring a unique sense of place to the large residential quarter.

**CS2-2 Response to Different Streets:** For buildings that are either located on a corner site or span the full block and “front” on two or more streets, each street frontage should receive individual and detailed site planning and architectural design treatments that complement any positive, respective, established streetscape character.

### **CS3 Architectural Context and Character: Contribute to the architectural character of the neighborhood.**

#### **CS3-A Emphasizing Positive Neighborhood Attributes**

**CS3-A-1. Fitting Old and New Together:** Create compatibility between new projects, and existing architectural context, including historic and modern designs, through building articulation, scale and proportion, roof forms, detailing, fenestration, and/or the use of complementary materials.

**CS3-A-2. Contemporary Design:** Explore how contemporary designs can contribute to the development of attractive new forms and architectural styles; as expressed through use of new materials or other means.

**CS3-A-3. Established Neighborhoods:** In existing neighborhoods with a well-defined architectural character, site and design new structures to complement or be compatible with the architectural style and siting patterns of neighborhood buildings.

**CS3-A-4. Evolving Neighborhoods:** In neighborhoods where architectural character is evolving or otherwise in transition, explore ways for new development to establish a positive and desirable context for others to build upon in the future.

**CS3-B Local History and Culture**

**CS3-B-1. Placemaking:** Explore the history of the site and neighborhood as a potential placemaking opportunity. Look for historical and cultural significance, using neighborhood groups and archives as resources.

**CS3-B-2. Historical/Cultural References:** Reuse existing structures on the site where feasible as a means of incorporating historical or cultural elements into the new project.

**Capitol Hill Supplemental Guidance:**

**CS3-1 Fitting Old and New Together**

**CS3-1-a. Reference Character Buildings:** In areas with observable patterns of traditional materials and architectural styles, design new contemporary buildings to reference the scale, proportion, fenestration pattern, massing, and/or materials of character buildings. Encourage the use of pedestrian scaled materials that complement and take cues from historic buildings but do not try to mimic or copy existing structures.

**CS3-1-b. Block and Neighborhood:** Foster the eclectic mix of architectural design and forms on the block and throughout the neighborhood. Encourage the use of new architectural concepts, as they emerge.

**CS3-2 Placemaking:** The Capitol Hill Neighborhood is a designated arts and cultural district. Art and culture should reflect the local history and values of the neighborhood and should be well integrated with future developments. Art should be designed for human delight and the celebration of culture, spirit, and place appropriate to its function. Capitol Hill strongly values the intact and positive examples of its physical heritage.

**CS3-2-a. Street-Facing Spaces:** Encourage and support street-facing cultural open and indoor spaces to provide flexible spaces for art performances and art installations and increase interaction with the street.

**CS3-2-b. Art Integration:** Encourage the integration of art into the building design and associated open space.

**CS3-2-c. Design Concept:** Consider engaging with a local artists or arts organization to develop a design concept rooted in the culture of Capitol Hill.

**CS3-3 Historical and Cultural References**

**CS3-3-a. Preservation:** Where possible, preserve and incorporate existing historical elements and character structures into project design, such as sites along Capitol Hill's commercial corridors, near designated landmarks, adjacent to notable Anhalt buildings or locations bordering the Harvard Belmont Historic District.

**CS3-3-b. Tell the Story:** Include interpretation (through visual art, signage, exhibits etc.) that tells the story of the neighborhood's history and culture to the general public in engaging ways.

**CS3-3-c. Cultural Elements:** Encourage the incorporation of historic and current cultural elements that express and explain how the neighborhood has transitioned over time including, but not limited to, LGBTQ community, Arts District, and EcoDistrict priorities.

## PUBLIC LIFE

### **PL1 Connectivity: Complement and contribute to the network of open spaces around the site and the connections among them.**

#### **PL1-A Network of Open Spaces**

**PL1-A-1. Enhancing Open Space:** Design the building and open spaces to positively contribute to a broader network of open spaces throughout the neighborhood.

**PL1-A-2. Adding to Public Life:** Seek opportunities to foster human interaction through an increase in the size and quality of project-related open space available for public life.

#### **PL1-B Walkways and Connections**

**PL1-B-1. Pedestrian Infrastructure:** Connect on-site pedestrian walkways with existing public and private pedestrian infrastructure, thereby supporting pedestrian connections within and outside the project.

**PL1-B-2. Pedestrian Volumes:** Provide ample space for pedestrian flow and circulation, particularly in areas where there is already heavy pedestrian traffic or where the project is expected to add or attract pedestrians to the area.

**PL1-B-3. Pedestrian Amenities:** Opportunities for creating lively, pedestrian oriented open spaces to enliven the area and attract interest and interaction with the site and building should be considered.

#### **PL1-C Outdoor Uses and Activities**

**PL1-C-1. Selecting Activity Areas:** Concentrate activity areas in places with sunny exposure, views across spaces, and in direct line with pedestrian routes.

**PL1-C-2. Informal Community Uses:** In addition to places for walking and sitting, consider including space for informal community use such as performances, farmer's markets, kiosks and community bulletin boards, cafes, or street vending.

**PL1-C-3. Year-Round Activity:** Where possible, include features in open spaces for activities beyond daylight hours and throughout the seasons of the year, especially in neighborhood centers where active open space will contribute vibrancy, economic health, and public safety.

### **Capitol Hill Supplemental Guidance:**

#### **PL1-1 Enhancing Open Space**

**PL1-1-a. Parks:** Design buildings facing a park or P-patch to enliven and enhance the safety of the open space. Orient entries, windows, balconies, decks and other amenity spaces to face the park. Design buildings facing Cal Anderson Park with active street level uses to support and reinforce its role as the "front yard" and civic square for Capitol Hill.

#### **PL1-1-b. Right-of-way – Enhance open space connections**

1. Greening: Create small pocket gardens within the adjacent street right-of-way (ROW) to enhance and energize the pedestrian experience. Consider locations that may be appropriate for growing food, serve an ecological function, or enhance any adjacent habitat corridors.
2. Design sidewalk ROW and private space adjacent to the ROW to prioritize both pedestrian circulation (comfort and safety), and environmental

sustainability. Use planters, seating, and landscape to provide an inviting, attractive, and safe streetscape for pedestrians while ensuring adequate space for pedestrian circulation. Special attention should be paid to Summit and Belmont (from E. Olive St. to E. Howell St.), on Bellevue (from E Loretta Place to E Harrison Street) and along the Melrose Promenade.

## **PL1-2 Adding to Public Life**

**PL1-2-a. Street Wall:** Maintain a continuous street wall along retail corridors to contribute to the area's pedestrian-oriented, urban character. Minor variations in the street wall such as recessed entries and inset window bays are acceptable if they help contribute to the pedestrian scale.

**PL1-2-b. Open Spaces:** On major retail streets, locate any large open spaces in the interior of the block, where it would not disrupt the continuity of retail street frontages and maintain the desired intensity of commercial activity in the area. Provide clear visual access to the interior open space from the public sidewalk.

## **PL1-3 Walkways and Connections**

**PL1-3-a. Through block connections:** On large project sites, consider using pedestrian connections to break up longer blocks and provide enhanced connectivity, particularly on sites near key public parks, the light rail station, or intersections where the street grid shifts. Use through-block pedestrian connections to add more permeability to retail corridors along 15th Ave E and Broadway. Design walkways with minimal grade changes and line the walkways with retail/business spaces, where possible.

**PL1-3-b. Pedestrian Volumes:** Provide ample pedestrian space along retail corridors and key pedestrian corridors that provide access to light rail facilities and the downtown core, such as E Olive Way, E John St., and E Denny Way. Use minor voluntary ground-level setbacks, structural setbacks, building overhangs, and high-quality hardscape finishes at the pedestrian level to ensure adequate space and durability for pedestrians, while maintaining the street wall and providing adequate space for sidewalk amenities that contribute to public life.

### **PL1-3-c. Pedestrian Amenities:**

1. Enhance the quality of the pedestrian environment through art and other placemaking features. Art should interpret or acknowledge specific ecological aspects of the site or location, provide site-specific wayfinding or "centering the viewer", provide a greater understanding of where the person is standing, and/or intend to delight passers-by and celebrate Capitol Hill's culture and spirit.
2. Provide functional pedestrian amenities such as benches (that enrich and enhance pedestrian flows). Amenities should be frequent and spaced at similar intervals as street trees. Where street trees are not possible due to underground utilities, benches and planters should be provided. Right-of-way improvements should be consistent with all City standards and reviews.

**PL1-4 Outdoor Uses and Activities:** Design any larger ground-level open spaces adjacent to the sidewalks for informal community events and gatherings, including: temporary art installations, live music and dance performances by community and social organizations, as well as independent artists. Provide features and amenities necessary to ensure that spaces are versatile and functional, such as power outlets, flexible seating, sight lines, acoustic materials,

and community poster or bulletin boards. Site spaces to allow visibility from the sidewalk without impeding pedestrian flow.

**PL2 Walkability: Create a safe and comfortable walking environment that is easy to navigate and well-connected to existing pedestrian walkways and features.**

**PL2-A Accessibility**

**PL2-A-1. Access for All:** Provide access for people of all abilities in a manner that is fully integrated into the project design. Design entries and other primary access points such that all visitors can be greeted and welcomed through the front door.

**PL2-A-2. Access Challenges:** Add features to assist pedestrians in navigating sloped sites, long blocks, or other challenges.

**PL2-B Safety and Security**

**PL2-B-1. Eyes on the Street:** Create a safe environment by providing lines of sight and encouraging natural surveillance.

**PL2-B-2. Lighting for Safety:** Provide lighting at sufficient lumen intensities and scales, including pathway illumination, pedestrian and entry lighting, and/or security lights.

**PL2-B-3. Street-Level Transparency:** Ensure transparency of street-level uses (for uses such as nonresidential uses or residential lobbies), where appropriate, by keeping views open into spaces behind walls or plantings, at corners, or along narrow passageways.

**PL2-C Weather Protection**

**PL2-C-1. Locations and Coverage:** Overhead weather protection is encouraged and should be located at or near uses that generate pedestrian activity such as entries, retail uses, and transit stops.

**PL2-C-2. Design Integration:** Integrate weather protection, gutters and downspouts into the design of the structure as a whole, and ensure that it also relates well to neighboring buildings in design, coverage, or other features.

**PL2-C-3. People-Friendly Spaces:** Create an artful and people-friendly space beneath building.

**PL2-D Wayfinding**

**PL2-D-1. Design as Wayfinding:** Use design features as a means of wayfinding wherever possible.

**Capitol Hill Supplemental Guidance:**

**PL2-1 Universal Access:** Design the public realm and shared private spaces to encourage intergenerational use and maximize accessibility for all people regardless of ability, background, age, and socioeconomic class. Incorporate universal design strategies to ensure that the common realm is accessible to all. Walkways should include adequate lighting, slip-resistant hardscape finishes, and terraces, benches, and other places of respite for pedestrians. This is especially important near light rail stations, in steeply-sloped areas, and along Denny, John, and other pedestrian corridors that connect to major employment centers.

**PL2-2 Inclusive Neighborhood:** Consider design features that visibly represent and promote the neighborhood's LGBT+ culture and identity, contribute to a more welcoming, supportive, and safe public realm, and remind everyone that Capitol Hill is an inclusive neighborhood.

**PL2-3 Weather Protection**

**PL2-3-a. Sidewalk Coverage:** When providing overhead weather protection, ensure the waterproof covering extends far enough over the sidewalk to provide adequate protection for pedestrian activity. Provide backslopes, drip edges and/or gutters to prevent rain runoff onto the middle of the sidewalk. Weather protection should extend all the way to the building edge without a gap between the coverage and the facade. In order to provide adequate protection from wind-driven rain, the lower edge of the overhead weather protection should be no more than 15 feet above the sidewalk.

**PL2-3-b. Residential Entries:** On less intense commercial streets, focus overhead weather protection around residential entries. Extend from the building far enough to provide shelter for 4-6 people to comfortably gather near common building entries.

**PL2-3-c. Tree Canopy:** Where narrow sidewalks create conflict between providing weather protection and tree canopy, indent canopy portions at trees. Prioritize tree canopy retention and new large tree plantings over full width weather protection that would impact or eliminate trees.

**PL2-3-d. Green Roofs:** In areas with good access to sunlight, consider using canopies as an opportunity to provide green roofs.

**PL2-3-e. Operable Awnings:** Optionally, consider using operable/retractable, but still durable, awnings that can be removed or reduced in good weather to allow greater sunlight to the street.

### **PL3 Street-Level Interaction: Encourage human interaction and activity at the street-level with clear connections to building entries and edges.**

#### **PL3-A Entries**

**PL3-A-1. Design Objectives:** Design primary entries to be obvious, identifiable, and distinctive with clear lines of sight and lobbies visually connected to the street.

**PL3-A-2. Common Entries:** Multi-story residential buildings need to provide privacy and security for residents but also be welcoming and identifiable to visitors.

**PL3-A-3. Individual Entries:** Ground-related housing should be scaled and detailed appropriately to provide for a more intimate type of entry.

**PL3-A-4. Ensemble of Elements:** Design the entry as a collection of coordinated elements including the door(s), overhead features, ground surface, landscaping, lighting, and other features.

#### **PL3-B Residential Edges**

**PL3-B-1. Security and Privacy:** Provide security and privacy for residential buildings through the use of a buffer or semi-private space between the development and the street or neighboring buildings.

**PL3-B-2. Ground-level Residential:** Privacy and security issues are particularly important in buildings with ground-level housing, both at entries and where windows are located overlooking the street.

**PL3-B-3. Buildings with Live/Work Uses:** Maintain active and transparent facades in the design of live/work residences. Design the first floor so it can be adapted to other commercial use as needed in the future.

**PL3-B-4. Interaction:** Provide opportunities for interaction among residents and neighbors.

### PL3-C Retail Edges

**PL3-C-1. Porous Edge:** Engage passersby with opportunities to interact visually with the building interior using glazing and transparency. Create multiple entries where possible and make a physical and visual connection between people on the sidewalk and retail activities in the building.

**PL3-C-2. Visibility:** Maximize visibility into the building interior and merchandise displays. Consider fully operational glazed wall-sized doors that can be completely opened to the street, increased height in lobbies, and/or special lighting for displays.

**PL3-C-3. Ancillary Activities:** Allow space for activities such as sidewalk vending, seating, and restaurant dining to occur. Consider setting structures back from the street or incorporating space in the project design into which retail uses can extend.

#### **Capitol Hill Supplemental Guidance:**

### PL3-1 Entries

**PL3-1-a. Commercial Areas:** In pedestrian-oriented commercial areas, provide frequent entrances, coupled entries, or other demarcation at regular intervals of 25-30 feet, to accommodate and encourage smaller retailers, community-oriented businesses, and flexible uses over time. Consider features such as shallow recesses at entries to add depth and pedestrian variety.

**PL3-1-b. Residential Buildings:** Identifiable common entries to residential buildings: Design primary entries to multi-family buildings to be an architectural focal point, using clear, pedestrian-scale signage, architectural enhancements such as heavy or contrasting trim, distinctive materials, large doors, canopies, and seating.

**PL3-1-c. Ground-Floor Units:** Individual entries to ground-related housing units:

1. Provide exterior access to all ground-floor residential units. This interior/exterior connection should occur frequently with entrances coupled or placed at regular intervals. Slightly raised stoops with direct entries to the street are preferred, particularly when alternate entries provide ADA accessibility.
2. Define entries to individual units with physical “threshold” features such as a canopy, fin walls, landscape, lighting, railings and/or transition in hardscape materials, to demarcate and bridge the boundary between public and private.

### PL3-2 Residential Edges

**PL3-2-a. Ground-Floor Units:** Design ground floor residences for security and privacy, while still contributing to an active streetscape. Use vegetation/landscape screening, modest setbacks, and/or vertical modulation to create a layered transition from the privacy of the house to the public space of the street and sidewalk. Avoid tall fences, fully obscuring barriers, and large setbacks (greater than 15 feet) that detract from the quality of the street-experience and reduce the number of eyes on the street. Use grading variation to provide a visual and physical transition between the street level and individual residential entrances.

**PL3-2-b. Windows:** Provide operable windows for ground-level units. Locate windows and/or translucent glass so that pedestrians on the sidewalk cannot see directly into the lower half of the ground floor space. Create a layered transition using landscape or window treatments to prevent direct eye contact between pedestrians and residents in

interior spaces, while still ensuring adequate natural lighting into units. Window shades that raise from the bottom and windows that open at the top are encouraged.

**PL3-2-c. Outdoor Spaces:** Provide stoops, porches, patios, and balconies to create opportunities for social interaction among residents and neighbors, particularly along the street-edge. Private outdoor spaces should be large enough to accommodate seating for 2-4 people, and clearly delineated using landscape. This space should be at the same level as the interior of the unit where feasible and should be designed for some privacy from adjacent units. Where possible, raise outdoor spaces slightly above sidewalk level.

**PL3-3 Live/Work Edges:** Design live-work units to provide truly flexible space that can successfully accommodate different commercial uses over time.

**PL3-3-a. Arts-Relation Use:** Support future arts-related use, such as artist studios, by providing arts-friendly features such as wall-sized operable/garage doors and high ceilings at the ground level.

**PL3-3-b. Location:** Where possible, locate live-work units on side streets, mid-block passages, and alleys, not on major pedestrian or retail corridors.

**PL3-3-c. Privacy Screening:** Consider including some level of adaptive privacy screening, such as landscape tubs, window films and window shades that raise from the bottom, while still emphasizing the high transparency and commercial needs of these spaces.

#### **PL3-4 Retail Edges**

**PL3-4-a. Permeable storefronts:** Design the ground floor retail edge to enhance street level activity and promote social mixing. Features may include large operable windows and doors, outdoor dining, and artistic detailing that provides visual interest. Design spaces to function year-round, including during the summertime when windows and doors will be open fairly frequently. Use clear/un-tinted glass, preserve oblique sightlines into retail spaces, and minimize mullions and the height of any stem walls. Consider setting the height of canopies at approximately 10 feet.

**PL3-4-b. Highly-Individualized:** Design retail frontages to contribute to the small-scale, pedestrian-oriented character of Capitol Hill retail. Provide an architectural framework that tenants can personalize and individualize with custom signs, window treatments, and programming. Use a variety of materials and architectural features to break up individual spaces while maintaining transparency.

### **PL4 Active Transportation: Incorporate design features that facilitate active forms of transportation such as walking, bicycling, and use of transit.**

#### **PL4-A Entry Locations and Relationships**

**PL4-A-1. Serving all Modes of Travel:** Provide safe and convenient access points for all modes of travel.

**PL4-A-2. Connections to All Modes:** Site the primary entry in a location that logically relates to building uses and clearly connects all major points of access.

#### **PL4-B Planning Ahead for Bicyclists**

**PL4-B-1. Early Planning:** Consider existing and future bicycle traffic to and through the site early in the process so that access and connections are integrated into the project along with other modes of travel.

**PL4-B-2. Bike Facilities:** Facilities such as bike racks and storage, bike share stations, shower facilities and lockers for bicyclists should be located to maximize convenience, security, and safety.

**PL4-B-3. Bike Connections:** Facilitate connections to bicycle trails and infrastructure around and beyond the project.

**PL4-C Planning Ahead For Transit**

**PL4-C-1. Influence on Project Design:** Identify how a transit stop (planned or built) adjacent to or near the site may influence project design, provide opportunities for placemaking.

**PL4-C-2. On-site Transit Stops:** If a transit stop is located onsite, design project-related pedestrian improvements and amenities so that they complement any amenities provided for transit riders.

**PL4-C-3. Transit Connections:** Where no transit stops are on or adjacent to the site, identify where the nearest transit stops and pedestrian routes are and include design features and connections within the project design as appropriate.

**Capitol Hill Supplemental Guidance:**

**PL4-1 Connections to All Modes:** For buildings along corridors that provide direct pedestrian access to light rail station entries and other key transit access points - including: Broadway, 15th, E John St, E Olive St, E Denny Way, E Howell St, E Nagle Place, and 10th Ave E below Thomas – locate primary entries to conveniently access transit and consider that secondary entries may also be required to maximize pedestrian access to transit.

**PL4-2 Planning Ahead for Bicyclists**

**PL4-2-a. Bicycle Parking:** Bicycle use and parking should be encouraged to promote a healthy and active neighborhood and to support local businesses. Bicycle parking should be plentiful and should be an approved design from the Seattle Department of Transportation’s bike parking program. The bicycle racks and bike share hardscape areas may also be an opportunity for placemaking, such as having a uniform color within the Capitol Hill EcoDistrict or Arts District, or having distinctive place names or references designed into them.

**PL4-2-b. Parking Location:** Locate short-term parking bike racks and bike share hardscape areas near the intended uses, but maintain clear pedestrian movement along desire lines, and maximize sidewalk activation opportunities along the storefronts. Locate bike racks within sight lines of front doors, windows, or areas with visual security. In areas where bicycle parking is anticipated to be high, consider whether an on-street bike rack or corral may be appropriate.

**DESIGN CONCEPT**

**DC1 Project Uses and Activities: Optimize the arrangement of uses and activities on site.**

**DC1-A Arrangement of Interior Uses**

**DC1-A-1. Visibility:** Locate uses and services frequently used by the public in visible or prominent areas, such as at entries or along the street front.

**DC1-A-2. Gathering Places:** Maximize the use of any interior or exterior gathering spaces.

**DC1-A-3. Flexibility:** Build in flexibility so the building can adapt over time to evolving needs, such as the ability to change residential space to commercial space as needed.

**DC1-A-4. Views and Connections:** Locate interior uses and activities to take advantage of views and physical connections to exterior spaces and uses.

**DC1-B Vehicular Access and Circulation**

**DC1-B-1. Access Location and Design:** Choose locations for vehicular access, service uses, and delivery areas that minimize conflict between vehicles and non-motorists wherever possible. Emphasize use of the sidewalk for pedestrians, and create safe and attractive conditions for pedestrians, bicyclists, and drivers.

**DC1-B-2. Facilities for Alternative Transportation:** Locate facilities for alternative transportation in prominent locations that are convenient and readily accessible to expected users.

**DC1-C Parking and Service Uses**

**DC1-C-1. Below-Grade Parking:** Locate parking below grade wherever possible. Where a surface parking lot is the only alternative, locate the parking in rear or side yards, or on lower or less visible portions of the site.

**DC1-C-2. Visual Impacts:** Reduce the visual impacts of parking lots, parking structures, entrances, and related signs and equipment as much as possible.

**DC1-C-3. Multiple Uses:** Design parking areas to serve multiple uses such as children's play space, outdoor gathering areas, sports courts, woonerf, or common space in multifamily projects.

**DC1-C-4. Service Uses:** Locate and design service entries, loading docks, and trash receptacles away from pedestrian areas or to a less visible portion of the site to reduce possible impacts of these facilities on building aesthetics and pedestrian circulation.

**Capitol Hill Supplemental Guidance:**

**DC1-1 Location and Design of Uses**

**DC1-1-a. Flexibility:** Maximize flexibility over the building's life, for all street-level spaces in commercial or residential use. Design space to accommodate either retail or arts and cultural uses, and different scales of tenants. For example: do not include structural or concrete stem walls or bulkheads protruding above grade level (which inhibit future modifications) along any sidewalk/street frontages.

**DC1-2 Parking and Service Uses**

**DC1-2-a. Visual Impacts:** When it is necessary to locate parking entrances and service uses on street frontages, or in highly visible locations, use artistic treatments (e.g. murals or decorative metalwork on garage doors and adjacent walls) or lush landscape screening to reduce visual impacts. This is especially important in locations where commercial uses extend to streets with residential character (e.g. Nagle Place, Harvard Avenue E, 14th Avenue).

**DC2 Architectural Concept: Develop an architectural concept that will result in a unified and functional design that fits well on the site and within its surroundings.**

## **DC2-A Massing**

**DC2-A-1. Site Characteristics and Uses:** Arrange the mass of the building taking into consideration the characteristics of the site and the proposed uses of the building and its open space.

**DC2-A-2. Reducing Perceived Mass:** Use secondary architectural elements to reduce the perceived mass of larger projects.

## **DC2-B Architectural and Facade Composition**

**DC2-B-1. Façade Composition:** Design all building facades—including alleys and visible roofs—considering the composition and architectural expression of the building as a whole. Ensure that all facades are attractive and well-proportioned.

**DC2-B-2. Blank Walls:** Avoid large blank walls along visible façades wherever possible. Where expanses of blank walls, retaining walls, or garage facades are unavoidable, include uses or design treatments at the street level that have human scale and are designed for pedestrians.

## **DC2-C Secondary Architectural Features**

**DC2-C-1. Visual Depth and Interest:** Add depth to facades where appropriate by incorporating balconies, canopies, awnings, decks, or other secondary elements into the façade design. Add detailing at the street level in order to create interest for the pedestrian and encourage active street life and window shopping (in retail areas).

**DC2-C-2. Dual Purpose Elements:** Consider architectural features that can be dual purpose—adding depth, texture, and scale as well as serving other project functions.

**DC2-C-3. Fit With Neighboring Buildings:** Use design elements to achieve a successful fit between a building and its neighbors.

## **DC2-D Scale and Texture**

**DC2-D-1. Human Scale:** Incorporate architectural features, elements, and details that are of human scale into the building facades, entries, retaining walls, courtyards, and exterior spaces in a manner that is consistent with the overall architectural concept

**DC2-D-2. Texture:** Design the character of the building, as expressed in the form, scale, and materials, to strive for a fine-grained scale, or “texture,” particularly at the street level and other areas where pedestrians predominate.

## **DC2-E Form and Function**

**DC2-E-1. Legibility and Flexibility:** Strive for a balance between building use legibility and flexibility. Design buildings such that their primary functions and uses can be readily determined from the exterior, making the building easy to access and understand. At the same time, design flexibility into the building so that it may remain useful over time even as specific programmatic needs evolve.

### ***Capitol Hill Supplemental Guidance:***

**DC2-1 Facades at Setbacks and Corners:** Where buildings have side setbacks adjacent to other buildings, materials and design treatments should intentionally ‘wrap the corner’ of window and door openings, and at building corners, so cladding materials and treatments appear substantial, and not two-dimensional or paper thin.

**DC2-2 Integrating Art:** Use art to animate the pedestrian realm including blank walls, sidewalks, entrances, walkways, etc. Engage artists early in the design process to integrate art

into the building design, rather than simply applying art onto a finished design. Consider themes and artists that represent the Capitol Hill community. See CS3.2, Placemaking, for additional guidance on integrating art into projects.

### **DC2-3 Secondary Architectural Features**

**DC2-3-a. Visual Depth and Interest:** Projecting balconies, recessed decks, and legibly-recessed, well-detailed windows are desirable.

**DC2-3-b. Fit with Neighboring Buildings:** Selectively include design elements or proportions that reflect Capitol Hill's historic character such as streetscape rhythm, historic parcel widths, fenestration patterns and/or material treatments.

**DC2-4 Scale and Texture:** Texture at Street Level: Emphasize pedestrian scale, durability, and texture at the street level based on positive local characteristics such as storefront mullion width and materiality, entrance details, and building materials with a handcrafted appearance. Building components that are small enough to hold such as brick, are desirable. Uniform facades composed of flush glass or large expanses of panels (metal, cement board, etc.), without the relief of frequent and highly-detailed entrances/framing treatments, detract from the desired human scale and texture at the street level.

## **DC3 Open Space Concept: Integrate open space design with the building design so that they complement each other.**

### **DC3-A Building-Open Space Relationship**

**DC3-A-1. Interior/Exterior Fit:** Develop an open space concept in conjunction with the architectural concept to ensure that interior and exterior spaces relate well to each other and support the functions of the development.

### **DC3-B Open Space Uses and Activities**

**DC3-B-1. Meeting User Needs:** Plan the size, uses, activities, and features of each open space to meet the needs of expected users, ensuring each space has a purpose and function.

**DC3-B-2. Matching Uses to Conditions:** Respond to changing environmental conditions such as seasonal and daily light and weather shifts through open space design and/or programming of open space activities.

**DC3-B-3. Connections to Other Open Space:** Site and design project-related open spaces to connect with, or enhance, the uses and activities of other nearby public open space where appropriate.

**DC3-B-4. Multifamily Open Space:** Design common and private open spaces in multifamily projects for use by all residents to encourage physical activity and social interaction.

### **DC3-C Design**

**DC3-C-1. Reinforce Existing Open Space:** Where a strong open space concept exists in the neighborhood, reinforce existing character and patterns of street tree planting, buffers or treatment of topographic changes. Where no strong patterns exist, initiate a strong open space concept that other projects can build upon in the future.

**DC3-C-2. Amenities/Features:** Create attractive outdoor spaces suited to the uses envisioned for the project.

**DC3-C-3. Support Natural Areas:** Create an open space design that retains and enhances onsite natural areas and connects to natural areas that may exist off-site and may provide habitat for wildlife.

**Capitol Hill Supplemental Guidance:**

**DC3-1 Open Space Uses and Accessibility**

**DC3-1-a. Ground Level Open Space:** Consider providing multi-use open space (generous corner landscape treatments; courtyard entries) that can be viewed, used, and enjoyed from the adjacent sidewalk. Design ground level common open spaces, or certain portions of them, that are accessible to the broader community.

**DC3-1-b. Residential Open Space:** Include areas for multi-generational use and social interaction. Locate children’s play space to where they can be seen by guardians and incorporate seating areas for community members to congregate.

**DC3-1-c. Healthy Open Space:** Incorporate planting beds to grow food or other features that will support physical activity. Design landscapes to provide ecological and social benefits.

**DC3-2 Design**

**DC3-2-a. Existing Open Space Patterns:** When present in the project vicinity, reiterate any existing positive open space patterns characteristic of Capitol Hill such as large canopy street and yard trees, high bank front yards, and extra wide planting strips.

**DC3-2-b. Public Realm Plans:** For development adjacent to City-adopted or community-generated public realm plans (e.g. Neighborhood Green Street, Street Concept Plan, Melrose Promenade), the development should implement or support the identified public realm concept.

**DC4 Exterior Elements and Finishes: Use appropriate and high quality elements and finishes for the building and its open spaces.**

**DC4-A Exterior Elements and Finishes**

**DC4-A-1. Exterior Finish Materials:** Building exteriors should be constructed of durable and maintainable materials that are attractive even when viewed up close. Materials that have texture, pattern, or lend themselves to a high quality of detailing are encouraged.

**DC4-A-2. Climate Appropriateness:** Select durable and attractive materials that will age well in Seattle’s climate, taking special care to detail corners, edges, and transitions.

**DC4-B Signage**

**DC4-B-1. Scale and Character:** Add interest to the streetscape with exterior signs and attachments that are appropriate in scale and character to the project and its environs.

**DC4-B-2. Coordination with Project Design:** Develop a signage plan within the context of architectural and open space concepts, and coordinate the details with façade design, lighting, and other project features to complement the project as a whole, in addition to the surrounding context.

**DC4-C Lighting**

**DC4-C-1. Functions:** Use lighting both to increase site safety in all locations used by pedestrians and to highlight architectural or landscape details and features such as entries, signs, canopies, plantings, and art.

**DC4-C-2. Avoiding Glare:** Design project lighting based upon the uses on and off site, taking care to provide illumination to serve building needs while avoiding off-site night glare and light pollution.

**DC4-D Trees, Landscape, and Hardscape Materials**

**DC4-D-1. Choice of Plant Materials:** Reinforce the overall architectural and open space design concepts through the selection of landscape materials.

**DC4-D-2. Hardscape Materials:** Use exterior courtyards, plazas, and other hard surfaced areas as an opportunity to add color, texture, and/or pattern and enliven public areas through the use of distinctive and durable paving materials. Use permeable materials wherever possible.

**DC4-D-3. Long Range Planning:** Select plants that upon maturity will be of appropriate size, scale, and shape to contribute to the site as intended.

**DC4-D-4. Place Making:** Create a landscape design that helps define spaces with significant elements such as trees.

**DC4-E Project Assembly and Lifespan**

**DC4-E-1. Deconstruction:** When possible, design the project so that it may be deconstructed at the end of its useful lifetime, with connections and assembly techniques that will allow reuse of materials.

**Capitol Hill Supplemental Guidance:**

**DC4-1 Exterior Finish Materials:** Consider each building as a high-quality, long-term addition to the neighborhood. Exterior finish materials should exhibit permanence and quality appropriate to Capitol Hill.

**DC4-1-a. Building Concept:** Integrate exterior detailing and materials into the building concept by relating to the structural expression of the building, and/or intentionally expressing the joints and transitions of the building materials and components.

**DC4-1-b. Quality:** Choose traditional or modern materials that are durable, proven, high quality, maintainable, that employ or complement more traditional materials such as brick, cast stone, architectural stone, terracotta details.

**DC4-1-c. Texture:** Materials that have texture, pattern, or color and are attractive even when viewed up close or lend themselves to a high quality of detailing are encouraged.

**DC4-1-d. Panels:** If panels (cement, metal, etc.) are used, they should be carefully-detailed, well-designed and combined with other materials to provide patterns, scale, and visual interest, particularly on lower levels. If used, panels should be of sufficient thickness to prevent warping or deformations.

**DC4-2 Sustainable and Environmental Choices**

**DC4-2-a. Salvage and Reuse:** Maximize the reuse of nontoxic salvaged building materials. Consider de-construction if building(s) to be demolished contain high value reusable materials (e.g. tile, flooring, old growth beams). Reuse salvaged materials in the new development as visible building components.

**DC4-2-b. Local and Regional Materials:** Choose local or regional building and landscape materials to reduce transport energy when possible.

**DC4-2-c. Bird Friendly Design:** Employ bird friendly design strategies for the upper floors of buildings with extensive glass, such as decorative screens, or louvers, or patterns integrated into the glass to warn birds before they collide. Locate landscape carefully to not create reflected greenery which attracts/confuses birds.

**DC4-2-d. Lighting:** Use directional down-lighting and other dark-sky friendly lighting strategies to enhance the perception of safety and minimize light pollution. Avoid outdoor lighting with high blue light content or other attributes that could adversely affect wildlife behavior and reproduction. Use low-wattage, warm tone lighting wherever possible and diffuse exterior light to make it more consistent with the context.

**DC4-2-e. Heat Island:** Design the building and open space to reduce the urban heat island effect. Use roofing materials with a high solar reflectance index or install a vegetated roof. Minimize the area of asphalt, concrete, and other hardscape. When used, consider coatings and colorants to achieve a lighter colored surface. Integrate plantings into passive design strategies for the building, e.g. use large canopy deciduous trees or a vine covered trellis to shade and cool a south-facing facade.

**DC4-3 Signage:** In addition to all requirements found in the Sign Code, the following guidelines also apply.

**DC4-3-a. Pedestrian Oriented:** Design areas on the building façade for individual business signs that are pedestrian-oriented (generally 20 feet maximum above grade) and integrated with the design concept and architectural details.

**DC4-3-b. Building Identification:** Design building identification signs to be well-integrated with the building's architectural elements.

**DC4-3-c. Tenants:** Incorporate unique, hand-crafted tenant signs to add visual interest to the simple building form. Signage design and placement should be well integrated with the design and style of the structure. Signs should not appear mass-produced.

**DC4-3-d. District Signage:** Use signs to reinforce the unique identity of the Capitol Hill as an Arts District and an EcoDistrict. Consider including district-branded signs, on-site interpretive panels or art installations that connect the building/site to these districts.

**DC4-4 Plant Materials and Hardscapes**

**DC4-4-a. Beneficial Plants:** Use plant species that are suitable for site condition, climate, and design intent. Maximize the use of native and/or naturally growing (non-invasive) plants that are self-sustaining, low maintenance, drought and pest resistant, and durable in urban conditions. Encourage the use of pollinator plants and those that provide wildlife and avian habitat appropriate to the region. Avoid invasive species that may jeopardize local ecosystems, or species that require the use of petrochemical fertilizer or pesticides.

**DC4-4-b. Diversity:** Plant diversity provides resistance to insect and diseases pests. As a general guide for larger sites, plant not more than 10 percent of any species, no more than 20 percent of any genus, and no more than 30 percent of any family. For smaller sites select species that contribute to plant diversity of the community.

## **RECOMMENDATIONS**

### **BOARD DIRECTION**

At the conclusion of the Early Design Guidance meeting, the Board recommended moving forward to MUP application.

\