



City of Seattle
Edward B. Murray, Mayor

Department of Construction and Inspections
Nathan Torgelson, Director

**CITY OF SEATTLE
ANALYSIS AND DECISION OF THE DIRECTOR OF
THE SEATTLE DEPARTMENT OF CONSTRUCTION AND INSPECTIONS**

Application Number: 3022063
Applicant Name: Einar Novion
Address of Proposal: 4818 Phinney Avenue North

SUMMARY OF PROPOSAL

Land Use Application to allow a 3-story, five unit rowhouse with surface parking for five vehicles. Project includes 200 cubic yards of grading. Existing structure to be demolished.

The following approval is required:

SEPA Environmental Determination (This project is subject to the Optional DNS Process (WAC 197-11-355) and Early DNS Process (SMC 25.05.355)).

SEPA DETERMINATION:

Determination of Non-significance

- No mitigating conditions of approval are imposed.
- Pursuant to SEPA substantive authority provided in SMC 25.06.660, the proposal has been conditioned to mitigate environmental impacts.

SITE AND VICINITY

Site Zone: Lowrise Multifamily 1 (LR1)

Nearby Zones:

North:	LR3
South:	LR1
West:	LR1
East:	LR1

ECAs: None



Site Size: 5,000 square feet

Public Comment:

The public comment period ended on January 24, 2016. One comment letter was received and carefully considered, to the extent that it raised issues within the scope of this review. These areas of public comment related to impacts of neighborhood sewer system and parking.

ANALYSIS – SEPA

Environmental review resulting in a Threshold Determination is required pursuant to the Seattle State Environmental Policy Act (SEPA), WAC 197-11, and the Seattle SEPA Ordinance (Seattle Municipal Code (SMC) Chapter 25.05).

The initial disclosure of the potential impacts from this project was made in the environmental checklist submitted by the applicant dated 9/24/2015. The Seattle Department of Construction and Inspections (SDCI) has annotated the environmental checklist submitted by the project applicant; reviewed the project plans and any additional information in the project file submitted by the applicant or agents; and any pertinent comments which may have been received regarding this proposed action have been considered. The information in the checklist, the supplemental information, and the experience of the lead agency with the review of similar projects form the basis for this analysis and decision.

The SEPA Overview Policy (SMC 25.05.665 D) clarifies the relationship between codes, policies, and environmental review. Specific policies for each element of the environment, and certain neighborhood plans and other policies explicitly referenced may serve as the basis for exercising substantive SEPA authority. The Overview Policy states in part: "*where City regulations have been adopted to address an environmental impact, it shall be presumed that such regulations are adequate to achieve sufficient mitigation*" subject to some limitations.

Under such limitations/circumstances, mitigation can be considered. Thus, a more detailed discussion of some of the impacts in appropriate.

Short-term Impacts

Construction activities could result in the following adverse impacts: construction dust and storm water runoff, erosion, emissions from construction machinery and vehicles, increased particulate levels, increased noise levels, occasional disruption of adjacent vehicular and pedestrian traffic, a small increase in traffic and parking impacts due to construction related vehicles, and increases in greenhouse gas emissions. Several construction-related impacts are mitigated by existing City codes and ordinances applicable to the project such as: the Stormwater Code (SMC 22.800-808), the Grading Code (SMC 22.170), the Street Use Ordinance (SMC Title 15), the Seattle Building Code, and the Noise Control Ordinance (SMC 25.08). Puget Sound Clean Air Agency regulations require control of fugitive dust to protect air quality. The following analyzes greenhouse gas, construction-related traffic, and construction-related noise, as well as mitigation.

Greenhouse Gas Emissions

Construction activities including construction worker commutes, truck trips, the operation of construction equipment and machinery, and the manufacture of the construction materials themselves result in increases in carbon dioxide and other greenhouse gas emissions which adversely impact air quality and contribute to climate change and global warming. While these impacts are adverse, they are not expected to be significant. Therefore no further mitigation is warranted pursuant to SMC 25.05.675.F.

Construction Impacts - Parking and Traffic

The proposed construction includes 200 cubic yards of grading. Increased trip generation is expected during the proposed demolition, grading, and construction activity. The area is subject to significant traffic congestion during peak travel times on nearby arterials. Large trucks turning onto arterial streets would be expected to further exacerbate the flow of traffic.

The area includes limited and timed or metered on-street parking. Additional parking demand from construction vehicles would be expected to further exacerbate the supply of on-street parking. It is the City's policy to minimize temporary adverse impacts associated with construction activities.

Pursuant to SMC 25.05.675.B (Construction Impacts Policy), additional mitigation is warranted and a Construction Management Plan is required, which will be reviewed by Seattle Department of Transportation (SDOT). The requirements for a Construction Management Plan include a Haul Route and a Construction Parking Plan. The submittal information and review process for Construction Management Plans are described on the SDOT website at: <http://www.seattle.gov/transportation/cmp.htm>.

Construction Noise

The project is expected to generate loud noise during demolition, grading and construction. The Seattle Noise Ordinance (SMC 25.08.425) permits increases in permissible sound levels associated with private development construction and equipment between the hours of 7:00 AM and 7:00 PM on weekdays and 9:00 AM and 7:00 PM on weekends and legal holidays in Lowrise zones.

If extended construction hours are desired, the applicant may seek approval from Seattle DCI through a Noise Variance request. The applicant's environmental checklist does not indicate that extended hours are anticipated.

A Construction Management Plan will be required prior to issuance of the first building permit, including contact information in the event of complaints about construction noise, and measures to reduce or prevent noise impacts. The submittal information and review process for Construction Management Plans are described on the SDOT website at: <http://www.seattle.gov/transportation/cmp.htm>. The limitations stipulated in the Noise Ordinance and the CMP are sufficient to mitigate noise impacts; therefore no additional SEPA conditioning is necessary to mitigation noise impacts per SMC 25.05.675.B.

Long -term Impacts

Long-term or use-related impacts are also anticipated as a result of approval of this proposal including greenhouse gas emissions. Compliance with applicable codes and ordinances is adequate to achieve sufficient mitigation for any additional long-term impacts as a result of this project and as such no further conditioning is warranted per SEPA (SMC 23.05.665). However, impact to greenhouse gas emissions and historic preservation warrant further analysis.

Greenhouse Gas Emissions

Operational activities, primarily vehicular trips associated with the project construction and the project's energy consumption, are expected to result in increases in carbon dioxide and other greenhouse gas emissions which adversely impact air quality and contribute to climate change and global warming. While these impacts are adverse, they are not expected to be significant, therefore, no further mitigation is warranted.

Historic Preservation

The existing structure on site is more than 50 years old. This structure was reviewed for potential to meet historic landmark status. The Department of Neighborhoods reviewed the proposal for compliance with the Landmarks Preservation requirements of SMC 25.12 and indicated the structure on site is unlikely to qualify for historic landmark status (Landmarks Preservation Board letter, reference number LPB 146/16). Per the Overview policies in SMC 25.05.665.D, the existing City Codes and regulations to mitigate impacts to historic resources are presumed to be sufficient, and no further conditioning is warranted per SMC 25.05.675.H.

DECISION – SEPA

This decision was made after review by the responsible official on behalf of the lead agency of a completed environmental checklist and other information on file with the responsible department. This constitutes the Threshold Determination and form. The intent of this declaration is to satisfy the requirement of the State Environmental Policy Act (RCW 43.21.C), including the requirement to inform the public of agency decisions pursuant to SEPA.

- Determination of Non-Significance. This proposal has been determined to not have a significant adverse impact upon the environment. An EIS is not required under RCW 43.21.030(2) (c).

The lead agency for this proposal has determined that it does not have a probable significant adverse impact on the environment. An environmental impact statement (EIS) is not required under RCW 43.21C.030 (2)(c). This decision was made after review of a completed environmental checklist and other information on file with the lead agency. This information is available to the public on request.

This DNS is issued after using the optional DNS process in WAC 197-11-355 and Early review DNS process in SMC 25.05.355. There is no further comment period on the DNS.

CONDITIONS – SEPA

Prior to Issuance of Demolition, Excavation/Shoring, or Construction Permit

1. Provide a Construction Management Plan that has been approved by SDOT. The submittal information and review process for Construction Management Plans are described on the SDOT website at: <http://www.seattle.gov/transportation/cmp.htm>.

Crystal Torres, Land Use Planner _____ Date: June 16, 2016
Seattle Department of Construction and Inspections

CT:bg

Torres/3022063.docx

IMPORTANT INFORMATION FOR ISSUANCE OF YOUR MASTER USE PERMIT

Master Use Permit Expiration and Issuance

The appealable land use decision on your Master Use Permit (MUP) application has now been published. At the conclusion of the appeal period, your permit will be considered “approved for issuance”. (If your decision is appealed, your permit will be considered “approved for issuance” on the fourth day following the City Hearing Examiner’s decision.) Projects requiring a Council land use action shall be considered “approved for issuance” following the Council’s decision.

The “approved for issuance” date marks the beginning of the **three year life** of the MUP approval, whether or not there are outstanding corrections to be made or pre-issuance conditions to be met. The permit must be issued by Seattle DCI within that three years or it will expire and be cancelled. (SMC 23-76-028) (Projects with a shoreline component have a **two year life**. Additional information regarding the effective date of shoreline permits may be found at 23.60.074.)

All outstanding corrections must be made, any pre-issuance conditions met and all outstanding fees paid before the permit is issued. You will be notified when your permit has issued.

Questions regarding the issuance and expiration of your permit may be addressed to the Public Resource Center at prc@seattle.gov or to our message line at 206-684-8467.