

## **RESIDENTIAL CODE**

### **WAC 51-51-0315 Section R315--Carbon monoxide alarms.**

**R315.1 Carbon Monoxide Alarms.** For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedroom in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages.

**R315.2 Existing Dwellings.** Existing dwellings within which fuel-fired appliances exist or that have attached garages shall be equipped with carbon monoxide alarms by January 1, 2013.

**EXCEPTION:** Owner-occupied detached one-family dwellings legally occupied prior to July 1, 2010.

**R315.3 Alarm Requirements.** Single station carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed in accordance with this code and the manufacturer's installation instructions.