

City of Seattle Steam Engineer and Boiler Fireman License Law

**Seattle Municipal Code
Chapter
6.420**



**Effective Date
21 June 2006**

City of Seattle
Department of Planning and Development

City of Seattle Steam Engineer and Boiler Fireman License Law

Additional Resources are available at:

www.seattle.gov/dpd

or,

Department of Planning and Development
700 5th Ave, ste 2000
P. O. Box 34019
Seattle, WA, 98124-4019

or,

(206) 684-5174

ORDINANCE 122115

AN ORDINANCE repealing Chapter 6.230 of the Seattle Municipal Code and adding a new Chapter 6.420, related to the requirements for licensing of steam engineers and boiler firemen.

BE IT ORDAINED BY THE CITY OF SEATTLE AS FOLLOWS:

SECTION 1.

Chapter 6.230 of the Seattle Municipal Code is repealed.

SECTION 2.

A new Chapter 6.420 is added to read as follows:

6.420.010 Scope, purpose and authority.

The regulation and licensing of steam engineers and boiler firemen and the operation of boilers and steam engines are governed by this chapter.

The purpose of this chapter is to provide standards for safe operation of boilers and steam engines.

The Director of the Department of Planning and Development is authorized to implement and enforce all the provisions of this chapter.

6.420.020 Unlawful activities.

- A. It is unlawful to have charge of, or operate or permit anyone to have charge of, or operate, any boiler or steam engine without a license issued under this chapter.
- B. It is unlawful to hire or contract with a person who does not have a license issued under this chapter to have charge of, or operate, any boiler or steam engine.
- C. It is unlawful for any person to knowingly:
 - 1. Prevent or attempt to prevent any person licensed under this chapter from performing any act required to be performed by this chapter; or
 - 2. Require or attempt to require any person licensed under this chapter to perform any act prohibited by this chapter.
- D. It is unlawful to fail to abide by a stop work order issued by the Director.

6.420.030 Definitions.

Words and phrases used in this chapter have the following meanings:

"Boiler" means a closed vessel in which water is heated, steam is generated, steam is superheated, or any combination thereof, under pressure or vacuum by the direct application of heat. The term "boiler" also includes fired units for heating or vaporizing liquids other than water where these systems are complete within themselves.

"Boiler plant" means one or more boilers and connecting piping and vessels within the same premises.

"Boiler supervisor" means a steam engineer Grade I, II or III who has passed additional examinations as required by the Director pursuant to the provisions of this chapter.

"BHP" means brake horsepower.

"Certified automatic boiler" means a boiler equipped with certain controls and limit devices as required by the Seattle Boiler Code, and for which the Director has finalized an Automatic Certification Application Permit.

"Certified monitored boiler" is a certified automatic boiler that meets the requirements of Section 330 of the Seattle Boiler Code and for which the Director has finalized a Monitored Certification Application Permit.

"City Boiler Inspector" means a City of Seattle Boiler/Pressure Systems Inspector employed by the Department.

"Department" means the Department of Planning and Development.

"Director" means the Director of the Department of Planning and Development and authorized representatives.

"Hoist and portable boiler" means a boiler used to provide steam for the operation of various types of equipment such as floating cranes, piledrivers and other similar types of equipment used in the construction industry.

"Hot-water supply boiler" is a boiler having a volume exceeding 120 gallons, or a heat input exceeding 200,000 BTU per hour, or a water temperature exceeding 210 degrees Fahrenheit but not exceeding a temperature of 250 degrees Fahrenheit, or a pressure not exceeding 160 psi, that provides hot water to be used externally to itself.

"kBTuh" means thousand BTU per hour.

"Low-pressure hot-water heating boiler" is a boiler from which hot water is circulated for heating purposes at pressures not exceeding 160 psi and temperatures not exceeding 250 degrees Fahrenheit, that provides hot water to be used externally to itself.

"Low-pressure steam-heating boiler" is a boiler furnishing steam at pressures not exceeding 15 psi.

"Nonregenerative system" is a system in which the heat rejected by an engine is lost to the atmosphere.

"Out of service." A boiler is "out of service" if it is manually shut down for inspection, maintenance, or repair, except for limited repairs and adjustments as set forth in Section 6.420.150.

"Potable water heater" (fired, electric, solar, and indirect) is a closed vessel in which water is heated by the combustion of fuels, electricity, or any other source, and withdrawn for use external to the system. Potable water heaters do not exceed any of the following criteria or capacities: a nominal water-containing capacity of 120 gallons, a heat input of 200,000 BTU per hour, an operating temperature of 210 degrees Fahrenheit, and a pressure of 160 psi.

"Power hot-water boiler" (high-temperature water boiler) is a boiler used for heating water or liquid to a pressure exceeding 160 psi or to a temperature exceeding 250 degrees F.

"Power steam boiler" is a boiler in which steam or other vapor is generated at pressures exceeding 15 psi. For purposes of this chapter the term shall not include a small power boiler.

"psi" means pounds per square inch.

"Regenerative system" is a system in which the heat rejected by an engine is used in a boiler.

"Seattle Boiler Code" is the Seattle Boiler and Pressure Vessel Code (Title 22 Subtitle IVA of the Seattle Municipal Code).

"Small power boiler" is a power steam boiler with pressures not exceeding 150 psi and not exceeding 800,000 BTU per hour heat input.

"Steam engine" means all prime movers using vapors from a boiler for motive power, steam-driven compressors, and steam pumps except steam pumps and similar auxiliaries used only as appurtenances for the operation of a boiler.

6.420.040 Applications and examinations.

- A. Persons desiring a license, or change of limitation as described in Section 6.420.070, shall make written application to the Director on forms provided by the Director. Applications shall be accompanied by a receipt showing payment of the required examination fee as required by the Fee Subtitle, Chapter 22.900E.
- B. Applicants for an operator's license shall pass an examination administered by the Director, and shall show to the satisfaction of the Director that they meet the minimum qualifications for one of the grades of license specified in Table A of Section 6.420.070.
- C. Examinations shall be practical in their character and shall relate to those matters that will fairly test the minimum capacity, skill, experience, and competence of each person examined to safely operate and properly care for boilers and steam engines, within the scope of the license sought.
- D. The Director may require affidavits regarding an applicant's character, training, experience and record, and such other supporting credentials as may be necessary to determine the applicant's fitness.
- E. The Director shall refuse to certify the applicant for a steam engineer's or boiler fireman's license if the result of the examination is such that the Director determines the applicant does not have sufficient

knowledge of, and experience in, the care or operation of boilers or steam engines, or if the applicant is found to be unfit to operate boilers or steam engines safely. The action of the Director shall be final.

- F. It is sufficient cause to refuse a steam engineer's or boiler fireman's license, or any renewal thereof, if the applicant, through neglect or incompetence while in charge of a boiler or steam engine, has caused serious damage to property or has endangered the lives of others.

6.420.050 Exemptions from license requirements.

A steam engineer's or boiler fireman's license is not required of any person in charge of, or operating, the following:

- A. Any boiler or steam engine subject to federal regulations;
- B. Any boiler not subject to reinspection by the Seattle Boiler Code;
- C. Low-pressure hot water, low-pressure steam and hot-water supply boiler plants having inputs of less than 2,500,000 BTU per hour;
- D. Any boiler having an input of less than 100,000 BTU per hour and a maximum pressure of 100 pounds per square inch or less;
- E. Potable water heaters;
- F. Ancillary equipment that may be connected to the operation of a boiler or boiler system such as, but not limited to, pumps, filters, pre-heaters, heat exchangers, and related pressure vessels;
- G. Non-regenerative gas turbines.

6.420.060 Periodic refresher training required.

All persons licensed according to this chapter shall attend an approved refresher course every five years. A document indicating proof of completion of the approved refresher course shall be provided to the Director.

6.420.070 Grades of licenses and limitations.

- A. The grades of steam engineers' and boiler firemen's licenses are as follows:
 Grade I Boiler Supervisor
 Grade II Boiler Supervisor
 Grade III Boiler Supervisor
 Grade I Steam Engineer
 Grade II Steam Engineer
 Grade III Steam Engineer
 Grade IV Boiler Fireman
 Small Power Boiler Fireman
 Grade V Boiler Fireman.
- B. License Limitations. The Director may impose limitations on licenses restricting the licensee to the operation and maintenance of particular equipment at a stated location, or to the operation and maintenance of a certain class of boilers or steam engines, or to specified permitted services in connection with the operation and maintenance of boilers and steam engines. Limitations shall be based upon the applicant's qualifications and shall be reasonably related to the protection of the public in the safe operation and maintenance of boilers and steam engines. Limitations may include, but are not limited to the following:
 - 1. Operation of boilers only.
 - 2. Operation of electric boilers only.
 - 3. Operation of hot water boilers only.
 - 4. Work at one address only.
- C. Applicants for a license shall possess the minimum qualifications for each grade of license as specified in Table A.

Table A—Qualifications for Steam Engineer and Boiler Fireman Licenses	
Grade of License applied for:	Minimum Qualifications
Grade I Boiler	At least one year of experience as a Grade I Steam Engineer pursuant to the

Supervisor	provisions of this ordinance.
Grade II Boiler Supervisor	At least one year of experience as a Grade II Steam Engineer pursuant to the provisions of this ordinance.
Grade III Boiler Supervisor	At least one year of experience as a Grade III Steam Engineer pursuant to the provisions of this ordinance.
Grade I Steam Engineer	1. At least five years of employment in a position directly responsible for the operation of boilers, or 2. Educational substitution for experience as allowed by Section 6.420.080 item 1, plus three years of experience. Licenses shall be limited to boilers only unless the applicant proves at least one year of experience in the operation of steam engines.
Grade II Steam Engineer	1. At least four years of employment in a position directly responsible for the operation of boilers, or 2. Educational substitution for experience as allowed by Section 6.420.080 item 1, plus two years of experience. Licenses shall be limited to boilers only unless the applicant proves at least one year of experience in the operation of steam engines.
Grade III Steam Engineer	1. At least three years of employment in a position directly responsible for the operation of boilers, or 2. Educational substitution for experience as allowed by Section 6.420.080 item 1, plus one year of experience. Licenses shall be limited to boilers only unless the applicant proves at least one year of experience in the operation of steam engines.
Grade IV Boiler Fireman	1. At least one year of employment in a position directly responsible for the operation of boilers, or 2. Allowable educational substitution for experience as allowed by Section 6.420.080 item 1 or 2. Licenses shall be limited to boilers only unless the applicant proves at least one year of experience in the operation of steam engines.
Small Power Boiler Fireman	No previous experience required.
Grade V Boiler Fireman	No previous experience required.

6.420.080 Allowable educational substitution for experience.

The educational qualifications described in this section may substitute for the work experience required by Section 6.420.070, when approved by the Director.

1. Graduation from a recognized school of technology with a curriculum approved by the Steam Licensing Advisory Board.
2. Completion of a training course in the fundamentals of boiler operation approved by the Director may be substituted for one year of boiler operating experience. The course shall include at least 40 hours of classroom work and either
 - a. 80 hours of on-site training relating to the care and operation of boilers under the direct supervision of a steam engineer with a license of Grade I, II or III; or
 - b. 40 hours of lab work at a facility approved by the Director.

6.420.090 Special license.

- A. Those who have been employed at least two years as licensed steam engineers or boiler firemen operating a boiler plant may apply for a special license if the capacity of the plant is enlarged or changed beyond the limits of their license. The special license shall permit the licensee to operate only such plant. The Director shall make an investigation of the changed boiler plant conditions together with such examination of the applicant as may be necessary to determine whether the applicant is qualified under this chapter to operate the enlarged or changed boiler plant. When the investigation and

examination reveal that the applicant is qualified to operate the plant in its changed condition, the Director shall approve the application and issue a special license.

- B. Special licenses may be renewed only once. At the expiration of the renewed license, licensees shall upgrade their licenses in accordance with the requirements of Section 6.420.070. If upgrades are not applied for, the licenses shall revert to the grade held prior to the issuance of the special license.

6.420.095 Reciprocity.

The Director may establish procedures for recognizing licenses issued by other jurisdictions whose licensing programs satisfy the purposes of this chapter.

6.420.100 Observation and inspection of boilers.

- A. The minimum requirements for operation and inspection of each type and capacity of equipment are as set forth in this Section and Tables B and C of this Section 6.420.100.
- B. Constant attendance. When constant attendance is required by this chapter, the engineer or boiler fireman in charge of a boiler, boiler plant, or steam engine shall not leave the boiler room or engine room when the boiler or steam engine is being operated without first either stopping the steam engine and shutting off all sources of heat in the boiler, or being relieved by a person duly licensed under this chapter.
Exception: The steam engineer or boiler fireman may take an occasional break without stopping the engine, shutting down the boiler or being relieved. In no case may any break last more than 20 minutes.
- C. Checked by boiler supervisor. When this chapter requires a boiler to be checked by a boiler supervisor, the boiler supervisor shall inspect all controls and safety devices pursuant to the requirements of Section 6.420.120 D, as a minimum.
- D. Checked by licensed operator. When this chapter requires a boiler to be checked by a licensed operator, a person holding a license issued under this chapter shall perform a physical examination of the boiler or engine to ensure proper operation and maintenance pursuant to the requirements of Sections 6.420.110 and 6.420.150, as a minimum.
- E. Twice daily check. When this chapter requires twice daily checks, the inspections that are required to be recorded in the boiler logbook by Section 6.420.110 shall be performed at least two times each day. The first check of the day shall be made not less than eight hours after the last recorded check of the previous day; the second check of the day shall be made at least six hours after the first recorded check of the day. Additional checks may be made to ensure safe operation of a boiler. Twice daily checks may not be performed by a Boiler Supervisor unless the Boiler Supervisor is a full time employee of the boiler owner.
- F. Check once every two hours. When this chapter requires a check every two hours, a physical examination of the boiler or engine to ensure proper operation and maintenance pursuant to the requirements of Sections 6.420.110 and 6.420.150, as a minimum, shall be made at least once every two hours.
- G. For purposes of Tables B and C, the input ratings of boilers shall be computed as follows:
 - 1. For gas, propane and similar burners, the rating shall be equal to the burner input as rated and labeled by the burner manufacturer. Where actual fuel flow during burner operation at the maximum firing rate can be reliably measured, the burner input may be computed by such method.
 - 2. For oil burners, the rating shall be equal to the gallons-per-hour rating of the fuel nozzle or nozzles.
 - 3. For electric boilers the rating shall be equal to the electrical input in KW as rated and labeled by the boiler manufacturer.
 - 4. In the case of multiple fuel burners, the rating shall be the greater of all computed inputs.
 - 5. For boilers in battery (connected to a common header), the rating shall be the cumulative input, as measured in paragraphs 1, 2, 3, or 4 above. For boilers in battery wired so that only a single boiler can operate at a given time, the license requirement shall be determined by the most restrictive individual license requirement for any boiler in the battery.
 - 6. For regenerative systems, the BHP of the prime mover (gas turbine, engine, etc.) will determine the grade for downstream recovery boilers and steam turbines.

H. All checks of boilers pursuant to the requirements of this chapter shall be logged and recorded as set forth in Section 6.420.110.

Table B License Requirements For Operation of Power Boilers and Steam Engines

Type of Boiler	Minimum License Requirement
A. All Boilers	
0–100 psi and 0–100 kBtuh input	No license required
B. Electric Boilers	
Not exceeding 1.5 cu. ft. and not exceeding 100 psi	No license required
C. All Boilers except Small Power Boilers	
Less than 1,000 kBtuh input each; not certified as Automatic. No more than 2 steam boilers on same header. ¹	Check by a Grade IV Boiler Fireman once every two hours
D. Small Power Boilers	
Maximum 800 kBtuh input; not certified as Automatic. No more than 2 steam boilers on same header	Semiannual check by a Grade III Boiler Supervisor and twice daily checks by a Small Power Boiler Fireman; or a Small Power Boiler Fireman on premises
E. Boilers certified as Automatic	
1. Maximum 20,000 kBtuh input. No more than 2 steam boilers on same header with a combined capacity no more than 20,000 kBtuh ¹	Check by a Grade IV Boiler Fireman once every two hours
2. More than 20,000 to 50,000 kBtuh input	Check by a Grade III Steam Engineer once every two hours
3. More than 50,000 to 300,000 kBtuh input	Check by a Grade II Steam Engineer once every two hours
4. More than 300,000 kBtuh input	Check by a Grade I Steam Engineer once every two hours
F. Boilers certified as Monitored	
1. Maximum 20,000 kBtuh input. No more than 2 steam boilers on same header with a combined capacity no more than 20,000 kBtuh ¹	Monthly checks by a Grade III Boiler Supervisor and twice daily checks by a Grade IV Boiler Fireman
2. More than 20,000 to 50,000 kBtuh input	Monthly checks by a Grade III Boiler Supervisor and twice daily checks by a Grade III Steam Engineer
3. More than 50,000 to 300,000 kBtuh input	Monthly checks by a Grade II Boiler Supervisor and twice daily checks by a Grade II Steam Engineer; or Weekly checks by a Grade II Boiler Supervisor and twice daily checks by a Grade III Steam Engineer.
4. More than 300,000 kBtuh input	Monthly checks by a Grade I Boiler Supervisor and twice daily checks by a Grade I Steam Engineer; or Weekly checks by a Grade I Boiler Supervisor and twice daily checks by a Grade II Steam Engineer.
G. All other boilers	
1. Maximum 20,000 kBtuh input. No more than 2 steam boilers on same header with a combined capacity no more than 20,000 kBtuh ¹	Constant attendance by a Grade IV Boiler Fireman
2. More than 20,000 to 50,000 kBtuh input	Constant attendance by a Grade III Steam Engineer
3. More than 50,000 to 300,000 kBtuh input	Constant attendance by a Grade II Steam Engineer

4. More than 300,000 kBtuh input	Constant attendance by a Grade I Steam Engineer
H. Steam engines	
1. Maximum 250 BHP	Constant attendance by a Grade III Steam Engineer or the same attendance requirements as the boiler serving the engine
2. More than 250 to 1,500 BHP	Constant attendance by a Grade II Steam Engineer or the same attendance requirements as the boiler serving the engine
3. More than 1,500 BHP	Constant attendance by a Grade I Steam Engineer or the same attendance requirements as the boiler serving the engine

Table C License Requirements for Operation of Low Pressure Boilers

TYPE OF BOILER	MINIMUM LICENSE REQUIRED
A. All types of boilers	
0–2,500 kBtuh input	No license required
B. Boilers Not Certified as Automatic or Monitored	
1. 2,500 to 5000 kBtuh max input. No boilers in battery.	Grade V Boiler Fireman on premises
2. More than 5,000 to 20,000 kBtuh max input. No more than 2 steam boilers on same header with a combined capacity no greater than 20,000 kBtuh. ¹	Constant attendance by a Grade IV Boiler Fireman
3. More than 20,000 to 50,000 kBtuh max input.	Constant attendance by a Grade III Steam Engineer
4. More than 50,000 to 300,000 kBtuh max input.	Constant attendance by a Grade II Steam Engineer
5. More than 300,000 kBtuh max input.	Constant attendance by a Grade I Steam Engineer
C. Boilers certified as Automatic	
1. 2,500 to 5000 kBtuh max input	Monthly checks by a Grade III Boiler Supervisor, or quarterly checks by a Grade III Boiler Supervisor and twice daily checks by a Grade V Boiler Fireman, or a Grade V Boiler Fireman on premises
More than 5000 kBtuh to 20,000 kBtuh max input. No more than 2 steam boilers on same header with a combined capacity no more than 20,000 kBtuh ¹	Quarterly checks by a Grade III Boiler Supervisor and twice daily checks by a Grade IV Boiler Fireman
More than 20,000 kBtuh – 50,000 kBtuh max input.	Quarterly checks by a Grade III Boiler Supervisor and twice daily checks by a Grade III Steam Engineer
More than 50,000 kBtuh to 300,000 kBtuh max input.	Quarterly checks by a Grade II Boiler Supervisor and twice daily checks by a Grade II Steam Engineer.
Over 300,000 kBtuh max input.	Quarterly checks by a Grade I Boiler Supervisor and twice daily checks by a Grade I Steam Engineer
D. Boilers certified as Monitored	
1. 2,500 to 5000 kBtuh max input.	Quarterly checks by a Grade III Boiler Supervisor.
2. More than 5,000 to 20,000 kBtuh max input. No more than 2 steam boilers on same header with a combined capacity no more than 20,000 kBtuh ¹	Semiannual checks by a Boiler Supervisor and twice daily checks by a Grade IV Boiler Fireman
3. More than 20,000 to 50,000 kBtuh max input. ¹	Semiannual checks by a Boiler Supervisor and twice daily checks by a Grade III Steam Engineer

4. More than 50,000 to 300,000 kBtuh max input.	Semiannual checks by a Grade II Boiler Supervisor and twice daily checks by a Grade II Steam Engineer; or Semiannual checks by a Grade II Boiler Supervisor and twice daily checks by a Grade III Steam Engineer.
5. Over 300,000 kBtuh max input.	Semiannual checks by a Grade I Boiler Supervisor and twice daily checks by a Grade I Steam Engineer; or Semiannual checks by a Grade I Boiler Supervisor and twice daily checks by a Grade II Steam Engineer.

Footnote to Tables B and C:

1. A Grade IV Boiler Fireman may operate more than two steam or vapor boilers with a greater combined capacity when the fireman is the head fireman on duty and under the direct on-site supervision of a licensed steam engineer for the purpose of training. The boilers shall not exceed the capacity permitted by the license of the supervising engineer.

6.420.110 Duties of steam engineers and boiler firemen.

Licensed steam engineers and boiler firemen shall perform the following duties in connection with the operation and maintenance of boilers and steam engines:

- A. Test the operation of the boiler and its control and safety devices periodically on a routine basis in accordance with nationally recognized standards and/or boiler and control manufacturer's written recommendations;
- B. Maintain and operate the equipment in a safe manner and according to nationally recognized standards such as those recommended by the American Society of Mechanical Engineers for boilers and as adopted by the Director;
- C. Prepare and maintain a boiler log book and record, at least daily or as otherwise required by this chapter, such pertinent boiler readings and data as may be recommended by the boiler manufacturer, nationally recognized standards, or required by the Boiler Inspector and/or the senior license holder or other authorized person in charge of the boiler operation. The boiler logbook shall be kept on the premises at all times and be available for inspection by the City Boiler Inspector.

6.420.120 Duties of boiler supervisors.

Boiler supervisors shall perform the duties listed in this section in connection with the supervision of automatic and monitored boilers.

- A. Prepare boiler logbooks with the name, telephone numbers, and home and business addresses of the boiler supervisor on the front cover. The boiler logbooks shall be kept on the premises and be available for inspection by the City Boiler Inspector.
- B. Determine the proper light-off, operating, and shutdown procedures and clearly set forth such procedures in the inside front cover of the boiler logbooks. Determine proper firing rate and the set point or operating limits of all safety devices required on automatic or monitored boilers by the Seattle Boiler Code. Boiler supervisors shall clearly mark such set point or limits in the inside back cover of the boiler logbooks.
- C. Determine the list of pertinent boiler data entries to be recorded in the boiler logbooks by the boiler owners or the owners' designated representatives and list such entries on the inside back cover. This list shall include such items as any unusual conditions observed, including safety shutdowns, repairs required, adjustments required and adjustments made. All entries shall be made in the boiler logbook and shall include the signature of the person making such readings, observations, or adjustments. It is lawful to cross out words or sentences which should be changed or corrected but erasures are prohibited. The boiler supervisor's written instructions shall include the above signature requirement and the prohibition of erasures.
- D. Examine each boiler and boiler logbook in accordance with the frequency of examinations required by Section 6.420.100. Examination shall include the testing of all control devices required for automatic boilers by the Seattle Boiler Code and the testing of monitoring systems when used.
- E. If a boiler is a certified monitored boiler as defined in Section 6.420.030:

1. The boiler supervisor shall cause signals to be sent to the monitoring station to test the reliability of the monitoring equipment and the response of the monitoring station.
 2. The boiler supervisor shall report all failures of either the equipment or the response to the City Boiler Inspector within 24 hours. Such report shall be in writing.
- F. Boiler supervisors shall inspect and test all other controls on the boiler and shall flush the low-water cutoffs, if applicable, to assure that all control devices are in safe and proper operation. They shall permit continued automatic boiler operation only if their examination, inspection and testing indicate that the boiler is in a safe operating condition.
- G. No modification, revisions, or alterations to a boiler or its control devices shall be made except under a boiler supervisor's supervision except:
1. Restoration of control devices to original factory operating conditions at the set point or within the operating limits determined by the boiler supervisor as set forth in the boiler logbook, or
 2. Repair or adjustment of the burner system for viscosity changes or to correct fuel-air ratios to restore proper operation at the firing rate indicated in the boiler logbook by the boiler supervisor, or
 3. Repair or adjustment of any other system not directly related to the primary safety controls or to the pressure vessel to restore such systems to proper operating conditions. Entries of such repairs or adjustments shall be made in the boiler logbook and shall include the signature of those making such repairs or adjustments.
- H. Attend all startups of an automatic boiler out of service after corrective work other than limited adjustments or repairs by others as set forth in subsection G has been performed on the boiler, its firing equipment, or its control and safety devices. The boiler supervisor shall remain in constant attendance until:
1. The boiler has reached its preset operating range of pressure, and
 2. The primary controls and safety devices have been proved, and
 3. The boiler is acceptable to him/her for continued operation.
- Boiler supervisors are not required to be in attendance during light-off of original boiler equipment being installed by and under the control of the boiler manufacturer or the manufacturer's representative, by a boiler installation contractor or boiler or burner installer making such installation under the manufacturer's written instructions and recommendations. Boiler supervisor are not required to be in attendance during light-off following adjustment or authorized boiler or burner manufacturer alterations made by the above representative, contractor or installer within the guarantee or warranty time period during which time the representative, contractor or installer is obligated to render such service. The representative, contractor or installer shall furnish the boiler supervisor with recommended set points or operating limits of all control devices and recommended firing rates as well as other pertinent data in writing. The representative, contractor or installer shall record all subsequent changes, adjustments, alterations or recommendations in the boiler logbook and shall sign the logbook.
- I. Provide for a substitute boiler supervisor to attend to boilers in the boiler supervisor's charge when he/she is unable to respond to trouble calls. The boiler supervisor shall list the names, home and business telephone numbers and addresses of substitute boiler supervisors on the front of the boiler logbooks.
- J. Respond to trouble calls in accordance with the following:
1. Make verbal contact with the licensed operator, boiler owner or the owner's representative within two hours of a trouble call from such person, and
 2. Have the capability of being present at a boiler site within four hours on a trouble call from that site.
- K. A boiler supervisor may not act as both boiler supervisor and the licensed operator except when:
- a. The boiler supervisor is a full-time employee of the boiler owner/user or,
 - b. The licensed operator is unavailable due to vacation, illness or similar temporary circumstances.

6.420.150 Reporting of defective boilers.

- A. Before operating any boiler, steam engineers and boiler firemen shall examine the boiler permit issued for the boiler to see that the permit is in force. If the permit has expired the steam engineer or boiler fireman shall notify his/her employer. If the permit has been expired for more than 90 days, the steam engineer or boiler fireman shall also notify the City Boiler Inspector of the date of expiration. The

steam engineer or boiler fireman shall note the pressure allowed by the permit and shall test the operation of the boiler and its control and safety devices for proper operation.

- B. Whenever the steam engineer or boiler fireman believes any part of a boiler or steam engine to be in defective or potentially unsafe condition, the steam engineer or boiler fireman shall report the fact to his/her employer in writing. If immediate corrective action is not taken, the steam engineer or boiler fireman shall report such defective or potentially unsafe conditions to the City Boiler Inspector.
- C. The City Boiler Inspector shall thereupon investigate the same, and report any lack of proper care on the part of any licensed person to the employer and the Director.
- D. Steam engineers and boiler firemen shall report to their employers and to the City Boiler Inspector any damage or injury to any boiler or steam engine under their charge or care which affects the safe operation of the boiler or steam engine. The boiler and any parts thereof shall not be removed or disturbed before an inspection has been made by a department inspector unless for the purpose of saving life. Failure to make such reports shall be sufficient cause for the suspension or revocation of the license of the person in charge.
- E. It is the duty of all licensed steam engineers and boiler firemen to report serious negligence in the care of boilers and steam engines to their employers and the City Boiler Inspector.

6.420.180 Licenses to be posted or carried.

All licensed steam engineers and boiler firemen on duty shall display their licenses in a conspicuous place in the room where the boiler or steam engine is located. Licenses shall be effective only for the operation of the plant where they are displayed. When the posting of their licenses is not practicable, steam engineers and boiler firemen shall carry their licenses on their persons, and on demand shall exhibit the licenses. Boiler supervisors shall display legible copies of their licenses in the log book of each boiler they supervise, pursuant to the requirements of Section 6.420.120.

6.420.190 Posting of regulations.

A copy of this chapter or a condensed version thereof shall be posted by the employer in every boiler and engine room where licensed operators or boiler supervisors are required.

6.420.200 License expiration and renewal.

- A. All licenses shall expire at midnight on September 30 of each year.
- B. Licenses shall not be transferred or assigned.
- C. Licenses may be renewed annually upon payment of the renewal fee. Renewals shall specify the same grade and be subject to such conditions or limitations as may be provided under the license to be renewed. Licensed persons desiring a renewal must also meet the requirements of Section 6.420.060.
- D. The Director may refuse to renew a license if the license holder demonstrates neglect or incompetence in the care and operation of boilers pursuant to this code.
- E. Licenses that have been expired for more than one year shall not be renewed until the licensee has passed an examination administered in accordance with this chapter.

6.420.210 Revocation of license.

- A. Any license issued pursuant to this chapter may be revoked by the Director if any of the following is found:
 - 1. The licensee has misrepresented facts related to the operation of any boiler or steam engine;
 - 2. The licensee has provided false information on an application for a license governed by the chapter;
 - 3. The licensee fails an examination administered according to Section 6.420.040;
 - 4. The licensee demonstrates neglect or incompetence in the care and operation of boilers pursuant to this code; or
 - 5. The existence of special circumstances that warrant revocation in the interests of public safety and welfare.

Licenses that have been revoked may be reinstated only after the applicant passes an examination administered according to this chapter.

- B. Whenever the Director determines that there are grounds for revoking a license, the Director may issue a notice of revocation and stop work order. The notice shall be served by personal service in the manner set forth in RCW 4.28.080 for service of a summons or sent by first class mail to the licensee.
- C. Unless a request for review before the Director is made in accordance with this subsection the notice shall become the final order of the Director. A request for review is an administrative remedy that must be exhausted before judicial review of the decision may be sought.
 - 1. Any person aggrieved by a notice issued by the Director pursuant to this section may obtain a review of the notice by delivering to the Department such request in writing within ten (10) days of the date of service of the notice. For purposes of this subsection, service shall be complete at the time of personal service, or if mailed, three days from the date of mailing. When the last day of the period so computed is a Saturday, Sunday or City holiday, the period shall run until five (5:00) p.m. on the next business day. The request shall be in writing, and upon receipt of the request, the Director shall notify any persons served the notice of the deadline for submitting additional information in the form of written material for the review, which shall be within ten (10) days after the request is received. Before the deadline for submission of information, any person aggrieved by or interested in the notice (including any persons served the notice) may submit any additional information in the form of written material to the Director for consideration as part of the review.
 - 2. The review will be made by the Steam License Advisory Board. The Steam License Advisory Board will review all additional information received by the deadline for submission of information. The Board may also request clarification of information received. After review of the additional information, the Steam License Advisory Board may recommend that the Director:
 - i. Sustain the notice of revocation;
 - ii. Withdraw the notice; or
 - iii. Continue the review to a date certain for receipt of additional information.
 - 3. Recommendations of the Board shall be in writing; shall be mailed to the Director and the appellant; and shall apply only to the case being heard.
 - 4. The Director shall issue an Order and shall cause the same to be sent by first class mail to the person or persons named on the notice and any other person that has requested notice of the decision.
 - 5. Any person who has standing to file an appeal with the Hearing Examiner may file such an appeal within ten (10) days of issuance of the Order of the Director.

6.420.220 Steam License Advisory Board.

- A. The Director shall appoint a Steam License Advisory Board consisting of as many as nine members for four-year terms. The terms shall be staggered so that no more than three board members' terms expire in the same year.
- B. The Steam License Advisory Board shall consist of up to three persons who are, or have been, licensed as a steam engineer or boiler fireman; up to three persons owning boilers or managing boilers for owners; and up to three persons from the general public.
- C. The Steam License Advisory Board shall advise and assist the Director in the administration of the steam engineer's and boiler fireman's license program. The Director is authorized to define the duties of and prescribe the procedure for the Board. The Steam License Advisory Board may recommend to the Director revisions to this chapter.

6.420.240 Inspections.

Licensees shall have their license card available while engaged in the care or operation of any boiler or steam engine and shall present the card at the request of the Director. The Director may conduct periodic inspections of licensees to determine compliance with these regulations.

6.420.250 Stop work orders.

If the Director finds any condition or work is in violation of this chapter, the Director may issue a stop work order. The order shall describe the violation in writing. It shall be posted on the premises or served on any person responsible for the condition or work. It is unlawful for any person to engage in or to cause any work subject to the order to be done until authorization from the Director is received.

6.430.260 Notice of violation.

- A. Notice. If, after investigation, the Director determines that there has been a violation of this code not resulting in revocation of a license, the Director may serve a notice of violation upon the person responsible for the action or condition. The notice of violation may state the requirements violated, what corrective action, if any, is necessary to comply with the standards or requirements, and set a reasonable time for compliance. The notice may be served upon the responsible person by regular first class mail, addressed to the last known address of such person. The notice of violation shall be considered an Order of the Director.
- B. Other remedies. Nothing in this subsection shall be deemed to limit or preclude any action or proceeding pursuant to Section 6.430.250 of this chapter, and nothing in this section shall be deemed to obligate or require the Director to issue a notice of violation prior to the imposition of civil or criminal penalties.
- C. Review by the Director. Any person affected by a notice of violation issued by the Director pursuant to this chapter may obtain a review of the notice by requesting such review in writing within ten days after service of the notice. Service shall be complete at the time of personal service, or if mailed, on the date of mailing. When the last day of the period computed is a Saturday, Sunday, federal or City holiday, the period shall run until 5:00 p.m. of the next business day. Upon receipt of a request, the Director shall notify the person requesting the review of the date, time and place of the Director's review. The review shall be not less than ten nor more than twenty days after the request is received, unless otherwise agreed by the person requesting the review. Any person affected by the notice of violation may submit addition information to the Director for consideration on or before the date of the review. A representative of the Director who is familiar with the case and the applicable regulations will conduct the review. The Director's representative will consider any information presented and in the Department's file. After the review, the Director shall issue an Order of the Director that may:
 - 1. Sustain the notice of violation; or
 - 2. Withdraw the notice of violation; or
 - 3. Amend the notice of violation; or
 - 4. Continue the review to a future dateThe Director shall issue an order within a reasonable time after the conclusion of the review. The Director shall mail the order by regular first class mail to the person or persons named in the notice of violation.

6.430.270 Penalties.

- A. Civil Penalties. Any failure to comply with the provisions of this chapter shall be subject to a cumulative civil penalty in an amount not to exceed \$500 per day for each violation from the date the violation occurs or begins until compliance is achieved. In cases where the Director has issued a notice of violation, the violation will be deemed to begin, for purposes of determining the number of days of violation, on the date compliance is required by the notice of violation. The penalty imposed by this section shall be collected by civil action brought in the name of the City. The Director shall notify the City Attorney in writing of the name of any person subject to the penalty, and the City Attorney shall, with the assistance of the Director, take appropriate action to collect the penalty. In any civil action for a penalty, the City has the burden of proving by a preponderance of the evidence that a violation exists or existed; the issuance of the notice of violation or of an order following a review by the Director is not itself evidence that a violation exists.
- B. Alternative Criminal Penalty. Any person who violates or fails to comply with this chapter shall be guilty of a gross misdemeanor subject to the provisions of Chapters 12A.02 and 12A.04, except that absolute liability shall be imposed for such a violation or failure to comply and none of the mental states described in Section 12A.04.030 need be proved. The Director may request the City Attorney to prosecute such violations criminally as an alternative to the civil procedure outlined in this chapter.

6.420.280 Additional relief.

The Director may seek legal or equitable relief to enjoin any acts or practices and abate any condition which constitutes a violation of this chapter when civil or criminal penalties are inadequate to effect compliance.

6.420.290 Existing licenses continued.

Anyone holding a license under Chapter 6.230, and in effect at the time the ordinance codified in this chapter becomes effective, shall be entitled to continue to operate under that license subject to all the provisions of this chapter.

6.420.300 Application of other provisions.

The licenses provided for in this chapter are subject to the general provisions of the Seattle License Code set forth in Chapters 6.02 and 6.202. In the event of a conflict between the provisions of Chapters 6.02 and 6.202 and this chapter, the provisions of this chapter shall control.

SECTION 3.

This ordinance shall take effect and be in force thirty (30) days from and after its approval by the Mayor, but if not approved and returned by the Mayor within ten (10) days after presentation, it shall take effect as provided by Municipal Code Section 1.04.020.