

**CITY OF SEATTLE**

**ORDINANCE** \_\_\_\_\_

**COUNCIL BILL** \_\_\_\_\_

AN ORDINANCE relating to Seattle Municipal Code Section 22.502.016 and amending Sections 110, 205, 225, 604, 1603, 1604 and 1702 of the 2012 Seattle Plumbing Code, to clarify regulations and adopt amendments consistent with the Washington State Plumbing Code.

**BE IT ORDAINED BY THE CITY OF SEATTLE AS FOLLOWS:**

Section 1. Chapter 1 of the Seattle Plumbing Code, which Chapter was last amended by Ordinance 124274, is amended as follows:

\* \* \*

**SECTION 110**

**ADMINISTRATIVE REVIEW**

**110.1 Administrative review by the Authority Having Jurisdiction.** Prior to issuance of the plumbing permit, ((A))applicants may request administrative review by the Authority Having Jurisdiction of decisions or actions pertaining to the administration and enforcement of this code. Requests shall be addressed to the Authority Having Jurisdiction.

**110.2 Administrative review by the Construction Codes Advisory Board.** After administrative review by the Authority Having Jurisdiction, and prior to issuance of the plumbing permit, ((A))applicants may request review of decisions or actions pertaining to the application and interpretation of this code by the Construction Codes Advisory Board according to International Building Code Section 103.11, except for stop work orders, notices of violations and revocations of permits. The review will be performed by three or more members of the Construction Codes Advisory Board, chosen by the Board Chair. The Chair shall consider the subject of the review and members' expertise when selecting members to conduct a review. The

1 decision of the review panel is advisory only; the final decision is made by the Authority Having  
2 Jurisdiction.

3 \* \* \*

4 Section 2. Chapter 2 of the Seattle Plumbing Code, which Chapter was last amended by  
5 Ordinance 124274, is amended as follows:

6 \* \* \*

7 **205.0** -C-

8 **[W] Certified Backflow Assembly Tester.** A person certified by the Washington state  
9 department of health under chapter 246-292 WAC to inspect (for correct installation and  
10 approval status) and test (for proper operation), maintain and repair (in compliance with chapter  
11 18.106 RCW) backflow prevention assemblies, devices and air gaps. (~~A person who has shown  
12 competence to test and maintain backflow assemblies to the satisfaction of the Authority Having  
13 Jurisdiction.~~)

14 \* \* \*

15 **225.0** -W-

16 \* \* \*

17 **[W] Water/Wastewater Utility - A public or private entity, including a water purveyor as**  
18 **defined in chapter 246-290 WAC, which may treat, deliver, or do both functions to reclaimed**  
19 **(recycled) water, potable water, or both to wholesale or retail customers.**

20 \* \* \*

21 Section 3. Chapter 6 of the Seattle Plumbing Code, which Chapter was last amended by  
22 Ordinance 124274, is amended as follows:

23 \* \* \*

24 **604.0 Materials**

25 \* \* \*

1 **[W] 604.11 Lead Content.** The maximum allowable lead content in pipes, pipe fittings,  
2 plumbing fittings and fixtures intended to convey or dispense water for human consumption shall  
3 be not more than a weighted average of 0.25 percent with respect to the wetted surfaces of pipes,  
4 pipe fittings, plumbing fittings and fixtures. For solder and flux, the lead content shall be not  
5 more than 0.2 percent where used in piping systems that convey or dispense water for human  
6 consumption. ((Water pipe and fittings with a lead content which exceeds 8 percent shall be  
7 prohibited in piping systems used to convey potable water.))

8 **EXCEPTIONS:**

- 9 1. Pipes, pipe fittings, plumbing fittings, fixtures or backflow preventers used for nonpotable  
10 services such as manufacturing, industrial processing, irrigation, outdoor watering, or any  
11 other uses where the water is not used for human consumption.
- 12 2. Water closets, bidets, urinals, fill valves, flushometer valves, tub fillers, shower valves,  
13 service saddles, or water distribution main gate valves that are two inches (50 mm) in  
14 diameter or larger.

15 \* \* \*

16 Section 4. Chapter 16 of the Seattle Plumbing Code, which Chapter was last amended by  
17 Ordinance 124274, is amended as follows:

18 \* \* \*

19 **1603 Reclaimed (Recycled) Water Systems.**

20 \* \* \*

21 **[W] 1603.4 Connection to Potable or Reclaimed (Recycled) Water Systems.** Reclaimed  
22 (recycled) water systems shall have no connection to a potable water supply or alternate water  
23 source system. Potable water is permitted to be used as makeup water for a reclaimed (recycled)  
24 water storage tank provided the water supply inlet is protected by an approved air gap ((~~or~~  
25 ~~reduced-pressure principle backflow preventer~~)) in accordance with this code.



- 1 (1) The potable water system shall be activated and pressurized. The on-site treated  
2 nonpotable water system shall be shut down and completely drained.
- 3 (2) The potable water system shall remain pressurized for a minimum period of time  
4 specified by the Authority Having Jurisdiction while the on-site treated nonpotable  
5 water system is empty. The minimum period the on-site treated nonpotable water  
6 system is to remain depressurized shall be determined on a case-by-case basis,  
7 taking into account the size and complexity of the potable and on-site treated water  
8 distribution systems, but in no case shall that period be less than 1 hour.
- 9 (3) Fixtures, potable and on-site treated, shall be tested and inspected for flow. Flow  
10 from an on-site treated water system outlet indicates a cross-connection. No flow  
11 from a potable water outlet shall indicate that it is connected to the on-site treated  
12 water system.
- 13 (4) The drain on the on-site treated nonpotable water system shall be checked for flow  
14 during the test and at the end of the test.
- 15 (5) The potable water system shall then be completely drained.
- 16 (6) The on-site treated nonpotable water system shall then be activated and pressurized.
- 17 (7) The on-site treated nonpotable water system shall remain pressurized for a  
18 minimum period of time specified by the Authority Having Jurisdiction while the  
19 potable water system is empty. The minimum period the potable water system is to  
20 remain depressurized shall be determined on a case-by-case basis, but in no case  
21 shall that period be less than 1 hour.
- 22 (8) Fixtures, potable and on-site treated nonpotable, shall be tested and inspected for  
23 flow. Flow from a potable water system outlet indicates a cross-connection. No  
24 flow from an on-site treated water outlet will indicate that it is connected to the  
25 potable water system.

1 (9) The drain on the potable water system shall be checked for flow during the test and  
2 at the end of the test.

3 (10) Where there is no flow detected in the fixtures which would indicate a cross-  
4 connection, the potable water system shall be repressurized.

5 **[W] 1604.12.2.3 Discovery of Cross Connection.** In the event that a cross-connection is  
6 discovered, the following procedure, in the presence of the Authority Having Jurisdiction,  
7 shall be activated immediately:

8 (1) On-site treated nonpotable water piping to the building shall be shut down at the  
9 meter and the on-site treated water riser shall be drained.

10 (2) Potable water piping to the building shall be shut down at the meter.

11 (3) The cross-connection shall be uncovered and disconnected.

12 (4) The building shall be retested following procedures listed in Sections 1604.12.2.1  
13 and 1604.12.2.2.

14 (5) The potable water system shall be chlorinated with 50 parts-per-million (ppm)  
15 chlorine for twenty-four hours.

16 (6) The potable water system shall be flushed after twenty-four hours, and a standard  
17 bacteriological test for drinking water shall be performed by a laboratory certified  
18 for drinking water in Washington state. Where test results are ((~~acceptable~~))  
19 satisfactory to the Authority Having Jurisdiction, health authority having  
20 jurisdiction, and the water purveyor, the potable water system shall be permitted to  
21 be recharged.

22 **Informative Note:** See chapter 246-290 WAC for regulation of Group A Public Water Supplies.

23 **1604.12.2.4 Annual Inspection.** An annual inspection of the on-site treated nonpotable  
24 water system shall be required in accordance with Section 1604.12.2.1. Annual cross-  
25 connection testing in accordance with Section 1604.12.2.2 shall be required by the  
26

1 Authority Having Jurisdiction, unless site conditions do not require it. The test shall  
2 occur no less than once every 4 years.

3 Alternate testing requirements shall be permitted by the Authority Having  
4 Jurisdiction.

5 \* \* \*

6 Section 5. Chapter 17 of the Seattle Plumbing Code, which Chapter was last amended by  
7 Ordinance 124274, is amended as follows:

8 \* \* \*

9 **Section 1702.0 Nonpotable Rainwater Catchment Systems.**

10 \* \* \*

11 **1702.2 Permit.** It shall be unlawful for a person to construct, install, alter, or cause to be  
12 constructed, installed, or altered a nonpotable rainwater catchment system in a building or on a  
13 premises without first obtaining a permit to do such work from the authority having jurisdiction.

14 **EXCEPTIONS:**

- 15 1. A permit is not required for exterior rainwater catchment systems used for outdoor drip and  
16 subsurface irrigation with a maximum storage capacity of 360 gallons (1363 L).  
17 2. A plumbing permit is not required for rainwater catchment systems for single family  
18 dwellings where outlets, piping, and system components are located on the exterior of the  
19 building. This does not exempt the need for permits where required for electrical  
20 connections, tank supports, or enclosures.

21 **1702.2.1 Plumbing Plan Submission.** No permit for a rainwater catchment system shall be  
22 issued until complete plumbing plans, with data satisfactory to the Authority Having  
23 Jurisdiction, have been submitted and approved.

1 [W] 1702.2.2 Discovery of Cross Connection. In the event that a cross-connection is  
2 discovered, the following procedure, in the presence of the Authority Having Jurisdiction,  
3 shall be activated immediately:

4 (1) Rainwater catchment water piping to the building shall be shut down at the meter, and  
5 the rainwater water riser shall be drained.

6 (2) Potable water piping to the building shall be shut down at the meter.

7 (3) The cross-connection shall be uncovered and disconnected.

8 (4) The building shall be retested following procedures listed in Sections 1603.11.2.1 and  
9 1603.11.2.2.

10 (5) The potable water system shall be chlorinated with 50 parts-per-million (ppm) chlorine  
11 for twenty-four hours.

12 (6) The potable water system shall be flushed after twenty-four hours, and a standard  
13 bacteriological test for drinking water shall be performed by a laboratory certified for  
14 drinking water in Washington state. Where test results are satisfactory to the Authority  
15 Having Jurisdiction, health authority having jurisdiction, and the water purveyor, the  
16 potable water system shall be permitted to be recharged.

17 Informative Note: See chapter 246-290 WAC for regulation of Group A Public Water Supplies.

18 \* \* \*

19 Section 6. This ordinance shall take effect and be in force 30 days after its approval by  
20 the Mayor, but if not approved and returned by the Mayor within ten days after presentation, it  
21 shall take effect as provided by Seattle Municipal Code Section 1.04.020.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

Passed by the City Council the \_\_\_\_ day of \_\_\_\_\_, 2014, and  
signed by me in open session in authentication of its passage this  
\_\_\_\_ day of \_\_\_\_\_, 2014.

\_\_\_\_\_  
President \_\_\_\_\_ of the City Council

Approved by me this \_\_\_\_ day of \_\_\_\_\_, 2014.

\_\_\_\_\_  
Edward B. Murray, Mayor

Filed by me this \_\_\_\_ day of \_\_\_\_\_, 2014.

\_\_\_\_\_  
Monica Martinez Simmons, City Clerk

(Seal)