

Marginal Markings

- Solid vertical lines indicate technical changes from 2012 IBC.
- - - Dashed vertical lines indicate technical changes in Seattle amendments.
- ➔ Solid deletion arrow indicates IBC text has been deleted.
- ⇨ Hollow arrow indicates Seattle amendments have been deleted.

Text Markings

- Underlining indicates Seattle amendments. ADULT FAMILY HOME.
- Italics indicate a defined term. *A dwelling* licensed.
- Strikethrough indicates Seattle deletions. (~~ADULT FAMILY HOME~~)
- A bracketed and underlined W indicates Washington state amendments. [W]

CHAPTER 14 HEATING AND COOLING EQUIPMENT AND APPLIANCES

SECTION M1413 EVAPORATIVE COOLING EQUIPMENT

[W] M1413.1 General. Evaporative cooling equipment and appliances shall comply with UL 1995 or UL/CSA/ANCE 60335-2-40 and shall be installed:

1. In accordance with the manufacturer's instructions.
2. On level platforms in accordance with Section M1305.1.4.1.
3. So that openings in exterior walls are flashed in accordance with Section R703.4.
4. So as to protect the potable water supply in accordance with Section (~~P2902~~) 603 of the *Uniform Plumbing Code*.
5. So that air intake opening locations are in accordance with Section R303.5.1.