

## 2017 Seattle Stormwater Code Proposed Changes

Section	Description of Change	Explanation
22.800.100 Transition to Revise Stormwater Code	Change references from 23.22.064 to 23.22.074	Correct typos.
22.805.070.D.2 Minimum Requirements for On-site Stormwater Management, Table A, On-site List for Single-family Residential Projects.	For Infiltration Trenches and Dry Wells BMPs, remove requirement to evaluate non-roof surfaces.	Align with Ecology requirements that BMPs are only intended for use in infiltrating runoff from non-pollution-generating surfaces.
22.805.070.D.4 Minimum Requirements for On-site Stormwater Management, Table C, On-site List for Parcel-based Projects.	For Infiltration Trenches and Dry Wells BMPs, remove requirement to evaluate non-roof surfaces.	Align with Ecology requirements that BMPs are only intended for use in infiltrating runoff from non-pollution-generating surfaces.
22.805.070.D.5 Minimum Requirements for On-site Stormwater Management, Table D, On-site List for Roadway Projects.	For projects discharging to a designated receiving water or its basin, clarify that 1.) only pollution-generating surfaces require evaluation for permeable pavement surfaces and infiltrating bioretention; and 2.) rain gardens are not required to be evaluated.	1. Correct error to align with policy intent and acknowledge that designated receiving waters are not flow sensitive. 2. Rain gardens are not considered feasible for roadway runoff.
22.805.080.B.4 Flow Control Peak Control Standard.	Add omitted 2-year recurrence type.	Correct typo.
22.807.020.B Drainage Control Review and Application Requirements – Submittal Requirements	Make several administrative changes.	Reflect current practice and clarify intent.

Summary of Proposed 2017 Stormwater Code Changes

November 2, 2017