


# MATERIAL STANDARD

## BRACKET, ALUMINUM, LUMINAIRE SUPPORT FOR ALLEY WALL MOUNTING



**Luminaire Support Brackets** shall meet the applicable requirements of ANSI C136.13 except as modified herein. The brackets are intended for mounting on alley wall surfaces of wood, brick, or stone.

The support brackets shall be a tapered elliptical configuration as shown, and shall be made of high-strength alloy capable of withstanding the loading of Sections 12 and 13 of ANSI C136.13. The luminaire attachment end shall terminate in a 2-inch NPS round tube section of 7 inches minimum length. The mounting plate shall be of the dimensions shown and made of 6061-T6 aluminum alloy.

The brackets shall be resistant to the corrosive and erosive action of normally prevailing atmospheric conditions encountered in industrial seaboard areas.

**Marking.** The brackets shall be permanently marked with the manufacturer's name or trademark.

**Packaging.** The brackets shall be packaged in accordance with the manufacturer's commercial practice to ensure safe delivery without damage.

Reference Specifications: ANSI C136.13, latest revision.

Stock Unit: EA

Stock Number	Bracket		Maximum Weight of Luminaire-Lbs.	Approved Manufacturers
	Length-Ft.	Rise-In.		Lexington
570512	3.25	12	50	570512

ORIGINATOR	STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>Jim S. Horn</i>	<i>Charles J. Shaffer</i>	<i>John L. Skinner</i>	<i>Betty Robin</i>