


**GROUND CONNECTION FOR SPLICES IN NETWORK VAULTS AND MANHOLES**



Install terminal lug ③ to ground bus per Construction Guideline NSV-30

**MATERIAL LIST**

ITEM	QTY	DESCRIPTION	STOCK NO.	MATL STD
1	1	Tap, compression, parallel type	677326E	6773.5
2	15	Wire, #2, bare Cu., stranded	610434	6103.9
3A	1	Terminal, compression, #2, Al-Cu for Al bus	651255	6774.9
3B	1	Terminal, compression, #2, Copper for Cu bus	677071E	6770.7
4	1	Fastener Assy, 1/2" x 1-3/4", for Al bus	782050	7820.0
		ITEMS USED WITH COPPER GROUND BUS		
5	1	Screw, cap, SB, 1/2" X 1-1/2"	784587E	7845.1
6	1	Nut, SB, 1/2"	783325E	7833.3
7	1	Washer, flat, SB, 1/2"	788026E	7880.2
8	1	Washer, split, lock, SB, 1/2"	788125E	7880.2

ORIGINATOR	STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>Jim S. Horn</i>	<i>Charles L. Shaffer</i>	<i>John C. Chinner</i>	<i>Betty Robin</i>