


CONSTRUCTION GUIDELINE

SECONDARY SERVICE DETAILS



Note: See Construction Guideline DU5-5 for connector details.

Material List

Item	Quantity	Description	Stock No.	Material Standard
1	as required	CLAMP, wedge Note: Ignore manufacturers' markings, follow this table instead.	#4-#2	581340E 5813.3
			#2-1/0	581342E 5813.3
			2/0-4/0	581344E 5813.3
2	2	DEADEND, automatic, #4	581308E	5813.1
3	1	NUT, oval eye, 5/8"	565252E	5652.1
4	2	CONNECTOR, tap, split bolt, #4-#4	668864E	6688.7
5	as required	WIRE #4, bare, Cu, hard drawn or #4 poly, Cu, medium hard drawn	610008	6100.1
			611392	6114.5
6	as required	SERVICE CABLE*, triplex or quadruplex	#2 triplex (#4 neutral)	600672 6007.5
			#2 quadruplex (#2 neutral)	600734 6007.5
			#2 triplex, coil (#4 neutral)	600673 6007.5
			1/0 triplex, coil (#2 neutral)	012580 none
			1/0 triplex (#2 neutral)	600664 6007.5
			1/0 quadruplex (1/0 neutral)	600735 6007.5
			4/0 triplex (2/0 neutral)	600669 6007.5
			4/0 quadruplex (4/0 neutral)	600738 6007.5

* For services larger than 4/0, contact Engineering.

STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>Goldshield</i>	<i>John Blinner</i>	<i>Harold Juy</i>