



REVISIONS		
REV	DATE	MF
DR	CK	APP
W.O. #		
DESCRIPTION		
0	5/10/2006	
AE		
W.O. # 38124-37		

REFERENCES

FOR REFERENCES, SEE TA-2000

NOTES

1. VEGETATION CLEARANCE CRITERIA IS BASED ON WAC-296-24-960, RCW 64.12.035 AND SEATTLE CITY LIGHT BEST PRACTICE

CONDUCTOR TYPE CLEARANCE

- A. PRIMARY DISTRIBUTION, 4KV-26KV AND TRANSFORMER, SWITCHES & ELECTRICAL EQUIPMENT ON THE POLE ... 10'
- B. SECONDARY, FIBER OPTIC, CABLE TV AND TELEPHONE CABLE 5'
- C. TRANSMISSION CONDUCTOR, VOLTAGE > 26KV (NOT SHOWN) APPLICABLE IN SOME LOCATIONS 16.5'

2. ILLUSTRATION IS SHOWN FOR A TYPICAL 47' POLE, AND CLEARANCE AT THE POLE. ABOVE CRITERIA ALSO APPLY TO OTHER POLE HEIGHTS AND TO CONDUCTOR/WIRE TO TREE CLEARANCE ALONG THE SPAN

**OVERHEAD DISTRIBUTION
NORTH & SOUTH DISTRIBUTION**

**3 PHASE DISTRIBUTION POWERLINE
TREE CLEARANCE**

DIRECTIONAL PRUNING - DECIDUOUS



Seattle City Light

DR: A. EDENS	DATE: 05/10/2006	CLASS L
CK: <i>A. Edens</i> 5/10/06	APP: DBS 5-12-06	
SCALE NONE	REV. NO. 0	DRAWING NO. TA-2001