



**City of Seattle**  
**Seattle City Light Department**

**DEPARTMENT POLICY & PROCEDURE**

---

**Subject**

**Number**

**DPP 500 P III-401, Schedule 103**

**FLOODLIGHTS – RENTAL**

**Effective**

**January 7, 2014**

---

**/s/ by Jorge Carrasco**

**Supersedes**

**January 11, 2012**

---

**Approved by Jorge Carrasco**

**Page 1 of 3**

---

**1.0 Policy**

- 1.1 The Department shall install on its electrical distribution system poles, where available, energy efficient rental floodlights to provide nighttime security and safety for persons and property. Installation charges shall be according to §2.0 of this schedule. Monthly charges are prescribed by ordinance.
  - 1.1.1 Floodlights shall not be installed on Department poles for business enhancement, aesthetic or decorative purposes.
  - 1.1.2 Illumination of signs, billboards, commercial displays, and storefronts shall be defined as a business enhancement.
  - 1.1.3 New and used automobile lots shall be illuminated with rental floodlights only to the level necessary for after hours nighttime security. Both private and public parking lots can have rental floodlight illumination for the security of persons and parked vehicles.
  - 1.1.4 The Department shall encourage customers to provide their own energy efficient security lighting whenever possible, and will provide information to assist customers.
  - 1.1.5 The determination as to whether requested floodlighting is for security purposes or other purposes shall be made by the Customer Care Division.

1.2 Floodlight rental requests shall be accepted for:

- 100-watt sodium-vapor
- 150-watt sodium-vapor
- 250-watt sodium-vapor
- 400-watt sodium-vapor

1.3 Rental for mercury-vapor floodlights shall be for existing installations only.

1.3.1 No new mercury-vapor floodlight installations shall be made.

1.3.2 Existing fixtures shall not be moved to new locations.

1.3.3 The Department reserves the right to convert or replace existing mercury-vapor floodlights with sodium-vapor or LED floodlights. No installation charge will be assessed in these instances.

1.4 Installation charges are payable upon application for service.

1.5 Replacement of burnt out lamps and other service shall be completed as soon as reasonably possible after notification by the customer.

**2.0 Installation Charges**

2.1 Basic installation charge applicable to wood poles in overhead distribution areas and to underground-fed metal street light poles, where secondary circuit is available . . . . . \$177

2.2 For each additional fixture installed at same location at same time . . . . . \$153

2.3 Additional charges when required:

Extend secondary circuit one span . . . . . \$156

Extend secondary each additional span . . . . . \$133

Extend duplex wire one span . . . . . \$168

**3.0 Appendix**

Distribution: Posted online at <http://sclweb.light.ci.seattle.wa.us/dpp/>

**4.0 Revision History**

<b>Version</b>	<b>Date</b>	<b>Changes Made</b>	<b>Revised By</b>
3.0	06-21-2013	Revised to update labor and material costs.	Austin Coover
2.0	12-1-11	Revised to update labor and material costs.	Jackie Kirn and Robert Bartley
1.0	10-18-10	Revised to update charges and text.	Margy Jones and Robert Bartley