




## FAX TRANSMITTAL

---

**TO:** Ron Abrahamson  
Trammell Crow Company

**FROM:** Brian C. Stanford



PBS Environmental

**DATE:** 7 March 2001

**FAX #:** 684-0525 (5 pages)

**RE:** Arctic Building - Plaster/Skim Coat/Paint Chip Samples

---

Included are the laboratory results for samples collected in the Arctic Building. The plaster and skim coat materials from Suite 250 and the stairwell tested negative for asbestos. PBS also collected paint chip samples from the same areas. The paint was found to contain a low percentage of lead in the stairwell sample. No lead was detected in the paint sample collected from Suite 250.

Call me if you have any questions at 233-9639. Thank you.

c:\faxtrans\doc.marcquakearctic