

Seattle Fire Department Permit Application

Code 3402-Install **Installation of Combustible Liquid Tank Serving Generator**



Permit Fee: **\$478.00**

TO BE COMPLETED BY TANK INSTALLER (PLEASE PRINT):

TANK SITE ADDRESS:		
INSTALLER BUSINESS NAME:		
INSTALLER MAILING ADDRESS:	SUITE:	
CITY:	STATE:	ZIP:
INSTALLER CONTACT PERSON:		
PHONE NUMBER: ()	E-MAIL ADDRESS:	
ESTIMATED INSTALLATION DATE:		
Type of tank(s) being installed at this site (check all that apply):		
<input type="checkbox"/> Indoor Tank(s):	<input type="checkbox"/> Outdoor Tank(s):	
Number of tanks: _____	Number of tanks: _____	
Individual tank capacity: _____	Individual tank capacity: _____	
Tank Type: <input type="checkbox"/> UL 142 <input type="checkbox"/> UL 2085	Tank Type: <input type="checkbox"/> UL 142 <input type="checkbox"/> UL 2085	
Description of Tank Location(s): _____		

Payment must accompany all applications. Please include a check made payable to the CITY OF SEATTLE.

Permit applications may be submitted in person weekdays from 8:00 a.m. to 4:30 p.m., or mailed to:

Seattle Fire Department
Fire Marshal's Office – Permits
220 Third Ave S, 2nd Floor
Seattle, WA 98104-2608

To pay with a Visa or Master Card, email this completed application to us,
and then visit www.seattle.gov/fire/permits to make a payment.
Tel: (206) 386-1450
E-mail: permits@seattle.gov

Call 206-386-1450, at least 24 hours prior to needed inspection time to arrange for an appointment.

FMO USE:	APPROVED BY:
Check No.: _____	Inspector: _____ SFD ID# _____
Receipt No.: _____	Date: _____
Application ID#: _____	



INSTALLATION PERMIT

Combustible Liquid Tank Serving Emergency/Standby Power Systems Code: 3402-Install

Installer's Business Name: _____

Address Where Tank is Located: _____

TANK TYPE	TANK CAPACITY	LOCATION

This permit is not transferable or renewable.

Special Permit Conditions: _____

<p><i>FIRE DEPARTMENT APPROVAL:</i> Inspector: _____ INJ/ILL#: _____ Approval Date: _____</p>

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. (SFC 105.3.5)