

Seattle Fire Department

Permit Conditions

7905

Site Address: _____

Inspector: _____

Master Fuel Transfer

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. [SFC 105.3.5]

NOTE: This permit is intended to provide an alternate, emergency or temporary method of transferring fuel for vessel propulsion and auxiliary use. It is not intended for handling or bulk transfer of combustible liquids designated as cargo.

1. The refueling location must hold a valid "Marine Refueling Facility" permit from the Seattle Fire Department. [SFC 105.6.18]

EXCEPTION: Vacuum truck operations transferring other than Class I Flammable Liquids are not required to be conducted at Marine Refueling Facilities.

2. A permit validation number is required to be obtained by the permittee referenced herein, prior to all fuel transfers and shall be obtained by calling the Fire Department at (206) 386-1450. Information to be furnished includes: [SFC 105.3]
 - a) Name of Marine Master Fuel Transfer permit holder conducting the transfer.
 - b) Requester's name and telephone number.
 - c) Job location (including pier number or address), vessel name, and the Marine Refueling Facility permit number if necessary.
 - d) Date and time fuel transfer will be performed.
 - e) Product name and quantity to be transferred.
3. The validation number obtained by the requester is only valid for the date, time and specific operation requested. The validation number is only good for 24 hours. [SFC 105.3]
4. U.S. Coast Guard notification is the responsibility of the fuel transfer operator. [SFC 105.3]
5. The Fire Code Official shall be notified immediately when an unauthorized discharge becomes reportable under state, federal or local regulations. [SFC 5003.3.1]
6. A copy of this Master Fuel Transfer permit shall be carried on the vehicle or barge used to transfer fuel or shall be conspicuously posted on-site at fixed facilities where transfers are permitted. [SFC 105.3.5]
7. A shipboard fire watch shall be maintained at all times during fueling transfer operations. [SFC 105.3]