

Seattle Fire Department

Permit Conditions

7906

Site Address: _____

Inspector: _____

Marine Refueling Facility

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. [SFC 105.3.5]

NOTE: This permit is intended to provide an alternate, emergency or temporary method of transferring fuel for vessel propulsion and auxiliary use. It is not intended for handling or bulk transfer of combustible liquids designated as cargo

1. The dispensing of combustible liquids into marine vessels at the permitted location shall be allowed only by persons or firms possessing a valid Seattle Fire Department Master Fuel Transfer permit (Permit Code 7905). [SFC 105.3]
2. Transfer of flammable liquids (flash point below 100 degrees Fahrenheit) is prohibited. [SFC 105.3] [AD 27.01.14-5.8.2.2]
3. Only a single tank vehicle shall be allowed on the pier at any one time. The vehicle shall be compartmentalized and shall be positioned in the direction of exit from the pier. The tank vehicle shall have a valid permit for operation from the Fire Department. [SFC 105.3]
4. Reverse flow prevention and remote shut down control shall be provided. [SFC 105.3]
5. Tie lines and chaffing pads shall be provided for the transfer lines. [SFC 105.3]
6. Vehicle operator shall remain with the vehicle during the transfer operation. [SFC 105.3]
7. Hose lines shall not cross any intervening vessels. [SFC 105.3]
8. Where the dock is accessible to vehicle traffic, a 20-foot unobstructed access road to the shore end of the dock shall be maintained for access of fire-fighting apparatus. [SFC 105.3] [AD 27.01.14-5.11]
9. Cargo handling, welding and cutting, smoking, open flames and other hazardous activities shall be prohibited within 50 feet of fueling operations. No welding or cutting shall be allowed on the vessel during fueling operations. [SFC 105.3]
10. A minimum of two (2) listed portable fire extinguishers of 40-BC rating shall be available within 75 feet of fueling operations. [SFC 105.3]
11. A shipboard fire watch shall be maintained at all times during fuel transfer operations. [SFC 105.3]
12. During refueling operations the following signs shall be posted in the area of transfer:

"NO SMOKING" and "SECURE ALL IGNITION SOURCES" [SFC 105.3] [AD 27.01.14-5.12.3]
13. The *Fire Code Official* shall be notified immediately when an unauthorized discharge becomes reportable under state, federal or local regulations or when any spill or accidental release, inside or outside of a building, could present a fire or life safety hazard. [SFC 5003.3.1]