

Seattle Fire Department

Permit Conditions

7912-ODMF

Applicant/Business Name: _____

Inspector: _____

On-Demand Mobile Fueling Operator

This permit shall be kept with the operator at all times and shall be readily available for inspection by the fire code official. [Seattle Fire Code Section 105.3.5]

1. On-Demand Mobile Fueling shall only be from fueling vehicles approved by the Fire Code Official. Each fueling vehicle shall have a separate permit.
[Seattle Fire Code Section 105.6.18 #6]
2. On-Demand Mobile Fueling shall only be conducted at sites that have an operational permit issued by the Fire Code Official.
[Seattle Fire Code Section 105.6.18 #11 and 5707.1.1]
3. On-Demand Mobile Fueling, including the mobile fueling vehicle and point of connection of the vehicle being fueled, shall not occur on public streets, public ways, inside of buildings or on the roof or inside of any parking structure.
[Seattle Fire Code Section 5707.4]
4. Mobile fueling operators shall have an *approved* written safety and emergency response plan that establishes policies and procedures for fire safety, spill prevention and control, personnel training, and compliance with other applicable requirements of this code.
[Seattle Fire Code Section 5707.3.1]
5. Mobile fueling vehicles shall be operated only by designated personnel who are trained on proper fueling procedures and the safety and emergency response plan. Training records of operators shall be maintained. [Seattle Fire Code Section 5707.3.2]
6. Mobile fueling vehicles shall be constantly attended during fueling operations with brakes set and warning lights in operation. Mobile fueling vehicles shall not obstruct emergency vehicle access roads. [Seattle Fire Code Section 5707.6]

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call 206-386-1450 or email permits@seattle.gov. Information also available at <https://www.seattle.gov/fire/business-services/permits#mobilefueling>, although that information may not be updated daily.

Seattle Fire Department

Permit Conditions

7912-ODMF

Applicant/Business Name: _____

Inspector: _____

On-Demand Mobile Fueling Operator

7. Mobile fueling vehicles shall be positioned in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an approved reel or in an approved compartment prior to moving the mobile fueling vehicle.
[Seattle Fire Code Section 5707.6.1]
8. Operators shall place a drip pan or an absorbent pillow under the nozzle and each fuel fill opening prior to and during dispensing operations to catch drips.
[Seattle Fire Code Section 5707.6.2]
9. Safety cones or other visual barriers shall be employed as warning devices to highlight the vehicle fueling area. Signs prohibiting smoking or open flames within 25 feet shall be prominently posted in the vehicle fueling area. [Seattle Fire Code Section 5707.6.3]
10. The mobile fueling vehicle flasher lights shall be in operation while dispensing operations are in progress. [Seattle Fire Code Section 5707.6.4]
11. The operator shall position the mobile fueling vehicle in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an approved reel or in an approved compartment prior to moving the mobile fueling vehicle. [Seattle Fire Code Section 5707.6.1]
12. Safety cans and approved metal containers shall be secured to the mobile fueling vehicle except when in use. [Seattle Fire Code Section 5707.2.2(3)]
13. Fueling a motor vehicle from tanks or containers mounted in a trailer connected to a mobile fueling vehicle is prohibited. [Seattle Fire Code Section 5707.2.2 (4)]

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call 206-386-1450 or email permits@seattle.gov. Information also available at <https://www.seattle.gov/fire/business-services/permits#mobilefueling>, although that information may not be updated daily.

Seattle Fire Department

Permit Conditions

7912-ODMF

Applicant/Business Name: _____

Inspector: _____

On-Demand Mobile Fueling Operator

- 14. Spills shall be reported in accordance with Section 5003.3.1. The person, firm or corporation responsible for an unauthorized discharge shall institute and complete all actions necessary to remedy the effects of such unauthorized discharge, whether sudden or gradual, without cost to the jurisdiction. Where deemed necessary by the fire code official, cleanup can be initiated by the fire department or by an authorized individual or firm. [Seattle Fire Code Section 5003.3.1.4 and 5707.6.6]

- 15. Nighttime mobile fueling shall only be made in areas deemed adequately lighted. [Seattle Fire Code Section 5707.6.5]

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call 206-386-1450 or email permits@seattle.gov. Information also available at <https://www.seattle.gov/fire/business-services/permits#mobilefueling>, although that information may not be updated daily.
