

# Seattle Fire Department Permit Conditions

7913

Site Address: \_\_\_\_\_

Inspector: \_\_\_\_\_

## Mobile Fleet Fueling Site

**This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. [SFC 105.3.5]**

**The following requirements are based on Seattle Fire Code Section 5706.5.4.5.**

1. Dispensing of fuel into vehicles at this location shall only be conducted by a mobile fleet fueling company who has a valid mobile fleet fueling permit issued by Seattle Fire Department.
2. The type of fuel is limited to Class II or III combustible liquids. Dispensing of gasoline or Class I flammable liquids is prohibited.
3. Fuel dispensing shall only be from tank vehicles complying the requirements of NFPA 385, state and federal requirements. Each tank vehicle shall operate under a current flammable liquids vehicle permit issued by Seattle Fire Department, and be equipped with No smoking or open flame signs, a portable fire extinguisher and a spill kit.
4. Dispensing from a tank mounted in the bed of a pick-up truck is prohibited.
5. Fuel dispensing shall be conducted in areas not accessible to the public or shall be limited to times when the public is not present.
6. Fueling dispensing shall only take place during daylight hours, unless adequate lighting is available.
7. Fueling dispensing shall be conducted at least from 15 feet from buildings, property lines, combustible storage, and storm drains that do not have approved oil interceptors, covers or an approved equivalent.
8. Fueling dispensing shall be conducted at least 25 feet from any source of ignition.
9. The engines of vehicles being fueled shall be shut off during fuel dispensing.
10. The fuel dispensing hose shall not be driven over by vehicles.
11. Drip pans or an absorbent pillow shall be placed under each fuel fill opening prior to and during dispensing operations.