

# Seattle Fire Department

## Permit Conditions

801-V

### Aerosol Products

#### RETAIL AREA:

1. Hazardous materials permit shall be posted in a conspicuous location on the premises or shall be kept on the premises designated therein. Permits shall be subject to inspection upon request. [2009 SFC Sec. 105.3.4]
2. Material safety data sheets shall be readily available on the premises and shall identify the classification level of each aerosol product. [2009 SFC Sec. 2801.3]
3. Maximum quantity in the retail display areas shall not exceed 500 pounds. [2009 SFC Table 2806.2.1]
4. Aerosol products shall not be stacked more than 6 feet from the base of the aerosol array to the top of the aerosol array unless containers are placed on fixed shelving or otherwise secured in an approved manner. [2009 SFC 2806.2.2]
5. Aerosol products located in retail display areas shall be removed from combustible cartons. [2009 SFC Sec. 2806.2.3]

#### **EXCEPTIONS:**

- 1) Display using a portion of combustible cartons which consists of only the bottom panel and not more than 2 inches of the side panel is allowed.
  - 2) When the retail sales area is protected in accordance with NFPA 30B, storage of aerosol products in combustible cartons allowed,
6. A minimum rated 40-BC fire extinguisher shall be located within 30 feet of all aerosol storage, use and handling. [2009 SFC Sec.906.1]

#### STORAGE AREA:

7. When storage is on shelves, the height of such storage or retail display to the top of aerosol containers shall not exceed 8 feet. [2009 SFC Sec. 2806.2.2]
8. Not more than 2,000 pounds of Levels 2 and 3 aerosols shall be stored in a storage area. [SFC 2009 Table 2806.2.1]