Seattle Public Utilities Seismic Study Summary

December 17, 2019

Seattle Public Utilities




Presentation Outline

- Background
- Seismic Hazards
- Seismic Study Findings
- Seismic Mitigation Recommendations



SPU Seismic Mitigation Program History


- Seattle Water Department Seismic Vulnerability Study (Cygna Energy Services, 1990)
- Earthquake Loss Modeling of the Seattle Water System (Kennedy Jenks Chilton/USGS, 1990)
- SPU Seismic Upgrade Program (e.g., OCC, Myrtle Elevated Tanks, Barton Standpipe, etc.)
- Performance of Water Supply Systems in the February 28, 2001 Nisqually Earthquake (system post-earthquake hydraulic modeling, Water Research Foundation, 2008)





New Developments (since 1990)

- Puget Sound region surface faults determined to be active (e.g., Seattle Fault, South Whidbey Island Fault, Tacoma Fault, etc.)
- Migration from 10% probability of exceedance in 50 years (475 year return interval) design earthquake to 2% probability of exceedance in 50 years (2475 year return interval) design earthquake



New Developments (since 1990 - cont)

 Earthquake Experience (e.g., Northridge, Japanese, Chilean and New Zealand events)

 Earthquake-resistant ductile iron pipe becomes available in U.S.





Los Angeles Tests Water Pipes That Stand Up to Quakes

Seismic Vulnerability Assessment Project Goals

- Preliminary seismic vulnerability assessments for all critical water transmission and distribution system facilities
- Hydraulic modeling of post-earthquake water system performance
- Establish post-earthquake water transmission and distribution system performance goals
- Develop planning level mitigation measures, cost estimates and timeframe to meet service level goals.
- Define seismic design standards for water transmission and distribution pipelines.

Earthquake Source Zones





Source	Max. Size	Recurrence
Subduction zone	M 9+	200–600 years
Deep Juan de Fuca plate	M 7+	30–50 years
 Crustal faults 	M 7+	Hundreds of years?



Volcano



Active crustal fault



Active plate boundary fault

^{*}figure modified from USGS Cascadia earthquake graphics at http://geomaps.wr.usgs.gov/pacnw/pacnweq/index.html

Seattle Earthquake Likelihood in the Next 50 Years

- 15% to 20% chance of catastrophic earthquake, similar to 2011 Christchurch or Tohoku earthquakes
 - 14% chance of M9 (plus or minus) Cascadia subduction earthquake
 - 5% chance of M6.5 or larger Seattle Fault earthquake
- 85% chance of at least one intraplate earthquake "similar" to the 2001 Nisqually earthquake









Seismic Hazard Analysis - Scenarios

- Three Scenarios
 - M7.0 Seattle Fault
 - M9.0 Cascadia Subduction Zone
 - 0.02 Probability of Exceedance in 50 Years Ground Motions
- Hazards Evaluated
 - Ground Shaking Intensity (PGA)
 - Permanent Ground Displacements

SPU Water System Seismic Hazard Map



M7 Seattle Fault Zone Peak Ground Acceleration







Earthquake Hazards – Liquefaction



Permanent Ground Displacement





Seismic Vulnerability Assessments

- "Vertical" Facilities
 - Watersheds
 - Treatment Plants
 - Reservoirs/Tanks
 - Pump Stations and Gatehouses
 - Support Facilities
- Pipelines
 - Transmission
 - Distribution

Watersheds

- Dams Meet FERC requirements
- Landslides
 - Minor impacts in M7.0 SFZ and M9.0 CSZ events
 - Moderate or more severe impacts possible for building code ground motions
- Other Facilities
 - Tolt intake bridge connections
 - Tolt screenhouse
 - Landsburg Tunnel Gatehouse



Treatment Plants

- Structural Performance generally good
- Some Nonstructural Concerns
- Sloshing in Basins
- Onsite Emergency Power
- Clearwells some damage (particularly for building code ground motions) but expected to remain functional



Regional Reservoirs and Tanks

- Reservoirs
 - Riverton Reservoirs Is Most Vulnerable
 - Eastside Reservoir Also AConcern
 - Damage Possible to Other Reservoirs But Most or All Others Are Expected to Remain Functional

Up-close inspection

shows a gapped area

discoloration below

of about 1/4 in and

 Elevated Tanks and Standpipes: All Are Vulnerable to Code Level

Ground Motions

Potential direction of lateral seismic force

Up sh su to

Myrtle #2

Eastside Reservoir After Nisqually Earthquake:


Up-close inspection shows vertical surfaces compressed together




Regional Pump Stations

Several Pump Stations Are Vulnerable But Most of Vulnerable Pump Stations Are Not Critical






Transmission Pipelines






Transmission Pipelines



SPU Water System Seismic Hazard Map



Vulnerability Assessment Findings Summary

- For a catastrophic earthquake (15% to 20% chance in next 50 years)
 - Loss of Cedar and Tolt Transmission Systems Likely
 - Loss of Eastside Supply Line Likely
 - Distribution Pipeline Failures
 - M7 SFZ Scenario: ± 2000 failures
 - M9 CSZ Scenario: ± 1400 failures
 - Most Terminal Reservoirs Remain Functional
 - Loss of Over One Dozen Critical Facilities
 - Loss of Water Pressure Throughout Direct Service Area Within ± 24 Hours
- Mitigation plans balancing risk vs cost

Mitigation Approach – Short Term Measures (Next 15 to 20 Years)

- Enhance emergency preparedness and response planning
 - Earthquake-specific response plan
 - Significantly augment pipeline repair material stocks
 - Assess adequacy/improve emergency drinking water
- Develop/implement isolation and control strategies
 - Reservoir isolation valves
 - Explore isolating areas of large amounts of pipe damage
 - Add valves to make isolation easier

Mitigation Approach – Long Term Measures (Next 50 Plus Years)

- Build It Right (Now Until Forever)
 - Use earthquake-resistant pipe when pipe is replaced
 - Design new facilities to remain functional
- Upgrade Vulnerable Critical Facilities (Next 50 Plus Years)
 - Most vulnerable transmission pipelines locations (Cedar system has top priority)
 - Critical facilities
 - Large volume reservoirs
 - Key pump stations and support facilities
 - Life-safety



Seismic Resilience Recommendations


- \$15 to \$20 million per year 50+ years
- Refer to Seismic Study Executive Summary for a list of proposed projects
- Options analysis for all projects
 - Proactive upgrade options
 - Operational response until replacement
 - Example: a vulnerable pipe crossing
 - Proactive replacement/seismic upgrade of pipe
 - Open trench replacement
 - Slip-line pipe
 - Wait until condition-related replacement
 - Install emergency connections
 - Place spare pipe immediately adjacent



Seismic Projects and CIP Planning

- Seismic projects included in 20-year CIP projections
- Seismic is one of many drivers
 - Aging infrastructure
 - Move Seattle coordination
 - Climate change
 - Dam Safety
 - Regulatory requirements
 - Environmental needs
 - Technology advancements


Historic and Proposed Capital Facilities Plan Spending through 2040 (2018-2023 Adopted CIP, plus 2024-2040 Estimate, in thousands of 2017 dollars)



^{*} Other includes Fleets, Facilities, Security, Information Technology, SCADA and other miscellaneous projects.



Direct Service Area Restoration Projected Improvement



Questions?