



**RISER NOTES:**

1. ALL PANELS/EQUIPMENT SHALL BE PERMANENTLY LABELED FOR "ARC FLASH HAZARD" AS REQUIRED BY SEC.110.16 OF THE NEC.
2. COORDINATE W/ SCL FOR NEW SERVICE REQUIREMENTS & METERING.
3. INSTALL GROUNDING SYSTEM PER CODE.

**CUSTOMER REQUIREMENTS**

DOCUMENT CHECKLIST:

- DESIRED VOLTAGE, SINGLE OR THREE PHASE
- TOTAL AND INDIVIDUAL MAIN DISCONNECT SIZES (AMPERES)
- METERS AND/OR CURRENT TRANSFORMER(S), REFER TO CONSTRUCTION STANDARD DU13-4/NMT-30
- NUMBER, SIZE AND TYPE (CU/AL) OF NEC CABLES
  - USE ALLOWABLE CABLES SIZES/TYPES (CONSTRUCTION STANDARD 1561.07)
  - IF FEEDER SCHEDULE, CABLE CALLOUTS MUST MATCH CHART

**RISER DIAGRAM (SECONDARY)**

SCALE: NOT TO SCALE

ONE INCH AT FULL SIZE	<b>REVISIONS</b>	<b>ENDORSEMENTS</b>	<b>Seattle City Light</b> Distribution Engineering	PROJECT TYPE	SHEET		
	DATE	SIGNATURE		DATE	RISER DIAGRAM (SECONDARY)	1 OF 1	
	DRAWN BY: CHECKED BY: APPROVED BY:	DRAWN: CB		10/15/2017	APPROVED FOR SEATTLE CITY LIGHT	PROJECT NAME	WORK ORDER NO.-TASK
	WORK ORDER #:	CHECK:		APPROVED:	PROJECT ENGINEER	PROJECT ADDRESS	CITY
DESCRIPTION	<small>THIS DRAWING IS THE PROPERTY OF THE CITY OF SEATTLE AND ITS SEATTLE CITY LIGHT DEPARTMENT. IT IS PRODUCED SOLELY FOR THE USE BY SEATTLE CITY LIGHT AND OTHER CITY DEPARTMENTS. THE USE, REPRODUCTION, AND TRANSFER OF THIS DRAWING AND/OR ANY INFORMATION CONTAINED IN THE DRAWING REQUIRES THE WRITTEN PERMISSION OF SEATTLE CITY LIGHT.</small>		SHEET CONTENTS	DRAWING NO.	REV. NO.		
			QUARTERSECTION NUMBER(S)	SECTION / TOWNSHIP / RANGE	0		