CHAPTER 16

STRUCTURAL DESIGN

User notes:

About this chapter: Chapter 16 establishes minimum design requirements so that the structural components of buildings are proportioned to resist the loads that are likely to be encountered. In addition, this chapter assigns buildings and structures to risk categories that are indicative of their intended use. The loads specified herein along with the required load combinations have been established through research and service performance of buildings and structures. The application of these loads and adherence to the serviceability criteria enhance the protection of life and property.

Code development reminder: Code change proposals to this chapter will be considered by the IBC—Structural Code Development Committee during the 2022 (Group B) Code Development Cycle.

SECTION 1601 GENERAL

[S] 1601.1 Scope. The provisions of this chapter shall govern the structural design of buildings, structures and portions thereof regulated by this code.

Exceptions:

- 1. Carports are not required to comply with this chapter if they satisfy all the following criteria:
 - 1.1. Accessory to Group R-3 occupancies,
 - 1.2. Used to shelter only vehicles, trailers or vessels,
 - 1.3. Constructed of metal, plastic or fabric,
 - 1.4. No more than 3 pounds per square foot in total weight, and
 - 1.5. No more than 300 square feet covered area.
- 2. Temporary tents and similar structures are not required to comply with this chapter if they satisfy all the following criteria:
 - 2.1 The occupant load is less than 100;
 - 2.2 The structure is fully or partially enclosed and 400 square feet or less in area; or are entirely unenclosed and 700 square feet or less in area;
 - 2.3 The structure is constructed of metal, plastic or fabric; and
 - 2.4 The structure is no more than 3 pounds per square foot in total weight.

SECTION 1602 NOTATIONS

1602.1 Notations. The following notations are used in this chapter:

- D = Dead load.
- D_i = Weight of ice in accordance with Chapter 10 of ASCE 7.
- E = Combined effect of horizontal and vertical earthquake induced forces as defined in Section 12.4 of ASCE 7.
- F = Load due to fluids with well-defined pressures and maximum heights.
- F_a = Flood load in accordance with Chapter 5 of ASCE 7.
- H = Load due to lateral earth pressures, ground water pressure or pressure of bulk materials.
- L = Live load.
- $L_r = \text{Roof live load.}$
- R =Rain load.
- S =Snow load.
- T = Cumulative effects of self-straining load forces and effects.
- V_{asd} = Allowable stress design wind speed, miles per hour (mph) (km/hr) where applicable.

- V = Basic design wind speeds, miles per hour (mph) (km/hr) determined from Figures 1609.3(1) through 1609.3(12) or ASCE 7.
- W = Load due to wind pressure.
- W_i = Wind-on-ice in accordance with Chapter 10 of ASCE 7.

SECTION 1603 CONSTRUCTION DOCUMENTS

[S] 1603.1 General. *Construction documents* shall show the size, section and relative locations of structural members with floor levels, column centers and offsets dimensioned. The design loads and other information pertinent to the structural design required by Sections 1603.1.1 through 1603.1.9 shall be indicated on the *construction documents*.

Exception: Construction documents for buildings constructed in accordance with the conventional light-frame construction provisions of Section 2308 shall indicate the following structural design information:

- 1. Floor and roof dead and live loads.
- 2. ((Ground snow)) Snow load. $((, p_{e^{-}}))$
- 3. Basic design wind speed, V, miles per hour (mph) (km/hr) and allowable stress design wind speed, V_{asd} , as determined in accordance with Section 1609.3.1 and wind exposure.
- 4. Seismic design category and site class.
- 5. Flood design data, if located in *flood hazard areas* established in Section 1612.3.
- 6. Design load-bearing values of soils.
- 7. Rain load data.

1603.1.1 Floor live load. The uniformly distributed, concentrated and impact floor *live load* used in the design shall be indicated for floor areas. Use of *live load* reduction in accordance with Section 1607.12 shall be indicated for each type of *live load* used in the design.

1603.1.2 Roof live and snow load. The ((*roof live load*)) roof live and snow load used in the design shall be indicated for roof areas (Sections 1607.14 and 1608).

1603.1.3 ((Roof snow load data)) <u>Reserved</u>. ((The ground snow *load*, p_g , shall be indicated. In areas where the ground snow *load*, p_g , exceeds 10 pounds per square foot (psf) (0.479 kN/m²), the following additional information shall also be provided, regardless of whether snow *loads* govern the design of the roof:

- 1. Flat-roof snow load, p_{f}
- 2. Snow exposure factor, C_{a} .
- 3. Snow load importance factor, I...
- 4. Thermal factor, C_{i} .
- 5. Slope factor(s), C_{c} .
- 6. Drift surcharge load(s), p_{ab} where the sum of p_{ab} and p_{ab} exceeds 20 psf (0.96 kN/m²).
- 7. Width of snow drift(s), w.))

1603.1.4 Wind design data. The following information related to wind *loads* shall be shown, regardless of whether wind *loads* govern the design of the lateral force-resisting system of the structure:

- 1. Basic design *wind speed*, *V*, miles per hour and *allowable stress design wind speed*, *V*_{asd}, as determined in accordance with Section 1609.3.1.
- 2. Risk category.
- 3. Wind exposure. Applicable wind direction if more than one wind exposure is utilized.
- 4. Applicable internal pressure coefficient.
- 5. Design wind pressures and their applicable zones with dimensions to be used for exterior component and cladding materials not specifically designed by the *registered design professional* responsible for the design of the structure, pounds per square foot (kN/m²).

1603.1.5 Earthquake design data. The following information related to seismic *loads* shall be shown, regardless of whether seismic *loads* govern the design of the lateral force-resisting system of the structure:

1. *Risk category*.

- 2. Seismic importance factor, I_e .
- 3. Mapped spectral response acceleration parameters, S_s and S_1 .
- 4. Site class.
- 5. Design spectral response acceleration parameters, S_{DS} and S_{DI} .
- 6. Seismic design category.
- 7. Basic seismic force-resisting system(s).
- 8. Design base shear(s).
- 9. Seismic response coefficient(s), CS.
- 10. Response modification coefficient(s), R.
- 11. Analysis procedure used.

1603.1.6 Geotechnical information. The design load-bearing values of soils shall be shown on the *construction documents*.

1603.1.7 Flood design data. For buildings located in whole or in part in *flood hazard areas* as established in Section 1612.3, the documentation pertaining to design, if required in Section 1612.4, shall be included and the following information, referenced to the datum on the community's *Flood Insurance Rate Map* (FIRM), shall be shown, regardless of whether *flood loads* govern the design of the building:

- 1. Flood design class assigned according to ASCE 24.
- 2. In *flood hazard areas* other than *coastal high hazard areas* or *coastal A zones*, the elevation of the proposed *lowest floor*, including the basement.
- 3. In *flood hazard areas* other than *coastal high hazard areas* or *coastal A zones*, the elevation to which any nonresidential building will be dry floodproofed.
- 4. In *coastal high hazard areas* and *coastal A zones*, the proposed elevation of the bottom of the lowest horizontal structural member of the *lowest floor*, including the basement.

1603.1.8 Special loads. Special *loads* that are applicable to the design of the building, structure or portions thereof, including but not limited to the *loads* of machinery or equipment, and that are greater than specified floor and roof *loads* shall be specified by their descriptions and locations.

1603.1.8.1 Photovoltaic panel systems. The *dead load* of rooftop-mounted *photovoltaic panel systems*, including rack support systems, shall be indicated on the *construction documents*.

Note: Floor and roof design load provisions regarding posting of live loads, issuance of certificates of occupancy and restrictions on loading are located in Section 107 Floor and Roof Design Loads.

1603.1.9 Roof rain load data. Rain intensity, *i* (in/hr) (cm/hr), shall be shown regardless of whether rain *loads* govern the design.

SECTION 1604 GENERAL DESIGN REQUIREMENTS

1604.1 General. Building, structures and parts thereof shall be designed and constructed in accordance with *strength* design, *load and resistance factor* design, *allowable stress design*, empirical design or conventional construction methods, as permitted by the applicable material chapters and referenced standards.

1604.2 Strength. Buildings and *other structures*, and parts thereof, shall be designed and constructed to support safely the *factored loads* in load combinations defined in this code without exceeding the appropriate strength *limit states* for the materials of construction. Alternatively, buildings and *other structures*, and parts thereof, shall be designed and constructed to support safely the *nominal loads* in load combinations defined in this code without exceeding the appropriate specified allowable stresses for the materials of construction.

Loads and forces for occupancies or uses not covered in this chapter shall be subject to the approval of the building official.

1604.3 Serviceability. Structural systems and members thereof shall be designed to have adequate stiffness to limit deflections as indicated in Table 1604.3.

CONSTRUCTION	L or L,	S or W ^f	D + L ^{d, g}
Roof members: ^e			
Supporting plaster or stucco ceiling	1/360	<i>l</i> /360	<i>l</i> /240
Supporting nonplaster ceiling	<i>l</i> /240	<i>l</i> /240	<i>l</i> /180
Not supporting ceiling	<i>l</i> /180	<i>l</i> /180	<i>l</i> /120
Floor members	1/360	—	<i>l</i> /240
Exterior walls:			
With plaster or stucco finishes	_	<i>l</i> /360	
With other brittle finishes	_	<i>l</i> /240	—
With flexible finishes	_	<i>l</i> /120	—
Interior partitions: ^b			
With plaster or stucco finishes	1/360	—	
With other brittle finishes	<i>l</i> /240	—	_
With flexible finishes	<i>l</i> /120	—	—
Farm buildings	_	_	<i>l</i> /180
Greenhouses	—		<i>l</i> /120

TABLE 1604.3 DEFLECTION LIMITS^{a, b, c, h, i}

For SI: 1 foot = 304.8 mm.

a. For structural roofing and siding made of formed metal sheets, the total load deflection shall not exceed *l*/60. For secondary roof structural members supporting formed metal roofing, the live load deflection shall not exceed *l*/150. For secondary wall members supporting formed metal siding, the design wind load deflection shall not exceed 1/90. For roofs, this exception only applies when the metal sheets have no roof covering.

b. Flexible, folding and portable partitions are not governed by the provisions of this section. The deflection criterion for interior partitions is based on the horizontal load defined in Section 1607.16.

See Section 2403 for glass supports.

d. The deflection limit for the $D^{++}(L + L_{p})$ load combination only applies to the deflection due to the creep component of long-term dead load deflection plus the short-term live load deflection. For lumber, structural glued laminated timber, prefabricated wood I-joists and structural composite lumber members that are dry at time of installation and used under dry conditions in accordance with the ANSI/AWC NDS, the creep component of the long-term deflection shall be permitted to be estimated as the immediate dead load deflection resulting from 0.5D. For lumber and glued laminated timber members installed or used at all other moisture conditions or cross laminated timber and wood structural panels that are dry at time of installation and used under dry conditions in accordance with the ANSI/AWC NDS, the creep component of the long-term deflection is permitted to be estimated as the immediate dead load deflec-tion resulting from *D*. The value of 0.5*D* shall not be used in combination with ANSI/AWC NDS provisions for long-term loading. e. The preceding deflections do not ensure against ponding. Roofs that do not have sufficient slope or camber to ensure adequate drainage shall be investi-

gated for ponding. See Chapter 8 of ASCE 7.

The wind load shall be permitted to be taken as 0.42 times the "component and cladding" loads or directly calculated using the 10-year mean return interval wind speed for the purpose of determining deflection limits in Table 1604.3. Where framing members support glass, the deflection limit therein shall not exceed that specified in Section 1604.3.7

For steel structural members, the deflection due to creep component of long-term dead load shall be permitted to be taken as zero. For aluminum structural members or aluminum panels used in skylights and sloped glazing framing, roofs or walls of surroom additions or patio covers not supporting edge of glass or aluminum sandwich panels, the total load deflection shall not exceed *l*/60. For continuous aluminum structural members is upporting edge of glass, the total load deflection shall not exceed *l*/175 for each glass lite or *l*/60 for the entire length of the member, whichever is more stringent. For aluminum sandwich panels used in roofs or walls of sunroom additions or patio covers, the total load deflection shall not exceed 1/120.

i. l = Length of the member between supports. For cantilever members, l shall be taken as twice the length of the cantilever.

1604.3.1 Deflections. The deflections of structural members shall not exceed the more restrictive of the limitations of Sections 1604.3.2 through 1604.3.5 or that permitted by Table 1604.3.

1604.3.2 Reinforced concrete. The deflection of reinforced concrete structural members shall not exceed that permitted by ACI 318.

1604.3.3 Steel. The deflection of steel structural members shall not exceed that permitted by AISC 360, AISI S100, ASCE 8, SJI 100 or SJI 200, as applicable.

1604.3.4 Masonry. The deflection of masonry structural members shall not exceed that permitted by TMS 402.

1604.3.5 Aluminum. The deflection of aluminum structural members shall not exceed that permitted by AA ADM.

1604.3.6 Limits. The deflection limits of Section 1604.3.1 shall be used unless more restrictive deflection limits are required by a referenced standard for the element or finish material.

1604.3.7 Framing supporting glass. The deflection of framing members supporting glass subjected to 0.6 times the "component and cladding" wind loads shall not exceed either of the following:

- 1 1/175 of the length of span of the framing member, for framing members having a length not more than 13 feet 6 inches (4115 mm).
- 2. 1/240 of the length of span of the framing member + 1/4 inch (6.4 mm), for framing members having a length greater than 13 feet 6 inches (4115 mm).

1604.4 Analysis. *Load effects* on structural members and their connections shall be determined by methods of structural analysis that take into account equilibrium, general stability, geometric compatibility and both short- and long-term material properties.

Members that tend to accumulate residual deformations under repeated service *loads* shall have included in their analysis the effects of added deformations expected to occur during their service life.

Any system or method of construction to be used shall be based on a rational analysis in accordance with well-established principles of mechanics. Such analysis shall result in a system that provides a complete *load* path capable of transferring *loads* from their point of origin to the load-resisting elements.

The total lateral force shall be distributed to the various vertical elements of the lateral force-resisting system in proportion to their rigidities, considering the rigidity of the horizontal bracing system or *diaphragm*. Rigid elements assumed not to be a part of the lateral force-resisting system are permitted to be incorporated into buildings provided that their effect on the action of the system is considered and provided for in the design. A *diaphragm* is rigid for the purpose of distribution of *story* shear and torsional moment when the lateral deformation of the *diaphragm* is less than or equal to two times the average *story* drift. Where required by ASCE 7, provisions shall be made for the increased forces induced on resisting elements of the structural system resulting from torsion due to eccentricity between the center of application of the lateral forces and the center of rigidity of the lateral force-resisting system.

Every structure shall be designed to resist the effects caused by the forces specified in this chapter, including overturning, uplift and sliding. Where sliding is used to isolate the elements, the effects of friction between sliding elements shall be included as a force.

1604.5 Risk category. Each building and structure shall be assigned a *risk category* in accordance with Table 1604.5. Where a referenced standard specifies an occupancy category, the *risk category* shall not be taken as lower than the occupancy category specified therein. Where a referenced standard specifies that the assignment of a *risk category* be in accordance with ASCE 7, Table 1.5-1, Table 1604.5 shall be used in lieu of ASCE 7, Table 1.5-1.

Exception: The assignment of buildings and structures to Tsunami *Risk Categories* III and IV is permitted to be in accordance with Section 6.4 of ASCE 7.

RISK CATEGORY	NATURE OF OCCUPANCY
	Buildings and other structures that represent a low hazard to human life in the event of failure, including but not limited
	to:
Ι	• Agricultural facilities.
	Certain temporary facilities.
	Minor storage facilities.
II	Buildings and other structures except those listed in Risk Categories I, III and IV.
III	 Buildings and other structures that represent a substantial hazard to human life in the event of failure, including but not limited to: Buildings and other structures whose primary occupancy is public assembly with an occupant load greater than 300. Buildings and other structures containing one or more public assembly spaces, each having an occupant load greater than 300 and a cumulative occupant load of these public assembly spaces of greater than 2,500. Buildings and other structures containing Group E or Group I-4 occupancies or combination therof, with an occupant load greater than 250. Buildings and other structures containing educational occupancies for students above the 12th grade with an occupant load greater than 500. Group I-2, Condition 1 occupancies with 50 or more care recipients. Group I-2, Condition 2 occupancies not having emergency surgery or emergency treatment facilities. Group I-3 occupancies. Any other occupancy with an occupant load greater than 5,000.^a Power-generating stations, water treatment facilities for potable water, wastewater treatment facilities and other public utility facilities not included in Risk Category IV. Buildings and other structures not included in Risk Category IV containing quantities of toxic or explosive materials that: Exceed maximum allowable quantities per control area as given in Table 307.1(1) or 307.1(2) or per outdoor control area in accordance with the <i>International Fire Code</i>; and Are sufficient to pose a threat to the public if released.^b
	Buildings and other structures designated as essential facilities, including but not limited to:
	• Group I-2, Condition 2 occupancies having emergency surgery or emergency treatment facilities.
	• Ambulatory care facilities having emergency surgery or emergency treatment facilities.
	• Fire, rescue, ambulance and police stations and emergency vehicle garages
	• Designated earthquake, hurricane or other emergency shelters.
	• Designated emergency preparedness, communications and operations centers and other facilities required for emer- gency response.
IV	• Power-generating stations and other public utility facilities required as emergency backup facilities for Risk Category IV structures.
	Buildings and other structures containing quantities of highly toxic materials that:
	• Exceed maximum allowable quantities per control area as given in Table 307.1(2) or per outdoor control area in accordance with the <i>International Fire Code</i> ; and
	• Are sufficient to pose a threat to the public if released. ^b
	Aviation control towers, air traffic control centers and emergency aircraft hangars.
	Buildings and other structures having critical national defense functions.
	• Water storage facilities and pump structures required to maintain water pressure for fire suppression.
E	

TABLE 1604.5 RISK CATEGORY OF BUILDINGS AND OTHER STRUCTURES

a. For purposes of occupant load calculation, occupancies required by Table 1004.5 to use gross floor area calculations shall be permitted to use net floor areas to determine the total occupant load.

b. Where approved by the building official, the classification of buildings and other structures as Risk Category III or IV based on their quantities of toxic, highly toxic or explosive materials is permitted to be reduced to Risk Category II, provided that it can be demonstrated by a hazard assessment in accordance with Section 1.5.3 of ASCE 7 that a release of the toxic, highly toxic or explosive materials is not sufficient to pose a threat to the public.

1604.5.1 Multiple occupancies. Where a building or structure is occupied by two or more occupancies not included in the same *risk category*, it shall be assigned the classification of the highest *risk category* corresponding to the various occupancies. Where buildings or structures have two or more portions that are structurally separated, each portion shall be separately classified. Where a separated portion of a building or structure provides required access to, required egress from or shares life safety components with another portion having a higher *risk category*, both portions shall be assigned to the higher *risk category*.

Exception: Where a *storm shelter* designed and constructed in accordance with ICC 500 is provided in a building, structure or portion thereof normally occupied for other purposes, the *risk category* for the normal occupancy of the building shall apply unless the *storm shelter* is a designated emergency shelter in accordance with Table 1604.5.

1604.6 In-situ load tests. The *building official* is authorized to require an engineering analysis or a load test, or both, of any construction whenever there is reason to question the safety of the construction for the intended occupancy. Engineering analysis and load tests shall be conducted in accordance with Section 1708.

1604.7 Preconstruction load tests. Materials and methods of construction that are not capable of being designed by *approved* engineering analysis or that do not comply with the applicable referenced standards, or alternative test procedures in accordance with Section 1707, shall be load tested in accordance with Section 1709.

1604.8 Anchorage. Buildings and *other structures*, and portions thereof, shall be provided with anchorage in accordance with Sections 1604.8.1 through 1604.8.3, as applicable.

1604.8.1 General. Anchorage of the roof to walls and columns, and of walls and columns to foundations, shall be provided to resist the uplift and sliding forces that result from the application of the prescribed *loads*.

1604.8.2 Structural walls. Walls that provide vertical load-bearing resistance or lateral shear resistance for a portion of the structure shall be anchored to the roof and to all floors and members that provide lateral support for the wall or that are supported by the wall. The connections shall be capable of resisting the horizontal forces specified in Section 1.4.4 of ASCE 7 for walls of structures assigned to *Seismic Design Category* A and to Section 12.11 of ASCE 7 for walls of structures assigned to all other *seismic design categories*. Required anchors in masonry walls of hollow units or *cavity walls* shall be embedded in a reinforced grouted structural element of the wall. See Sections 1609 for wind design requirements and 1613 for earthquake design requirements.

1604.8.3 Decks. Where supported by attachment to an *exterior wall*, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self-supporting. Connections of decks with cantilevered framing members to *exterior walls* or other framing members shall be designed for both of the following:

- 1. The reactions resulting from the *dead load* and *live load* specified in Table 1607.1, or the snow *load* specified in Section 1608, in accordance with Section 1605, acting on all portions of the deck.
- 2. The reactions resulting from the *dead load* and *live load* specified in Table 1607.1, or the snow *load* specified in Section 1608, in accordance with Section 1605, acting on the cantilevered portion of the deck, and no *live load* or snow *load* on the remaining portion of the deck.

1604.9 Wind and seismic detailing. Lateral force-resisting systems shall meet seismic detailing requirements and limitations prescribed in this code and ASCE 7 Chapters 11, 12, 13, 15, 17 and 18 as applicable, even where wind *load effects* are greater than seismic *load effects*.

Exception: References within ASCE 7 to Chapter 14 shall not apply, except as specifically required herein.

1604.10 Loads on storm shelters. *Loads* and load combinations on storm shelters shall be determined in accordance with ICC 500.

SECTION 1605 LOAD COMBINATIONS

1605.1 General. Buildings and *other structures* and portions thereof shall be designed to resist the strength load combinations specified in ASCE 7, Section 2.3, the *allowable stress design* load combinations specified in ASCE 7, Section 2.4, or the alternative *allowable stress design* load combinations of Section 1605.2.

Exceptions:

- 1. The modifications to load combinations of ASCE 7 Section 2.3, ASCE 7 Section 2.4, and Section 1605.2 specified in ASCE 7 Chapters 18 and 19 shall apply.
- 2. Where the allowable stress design load combinations of ASCE 7 Section 2.4 are used, flat roof snow loads of 30 pounds per square foot (1.44 kN/m²) and roof live loads of 30 pounds per square foot (1.44 kN/m²) or less need not be combined with seismic load. Where flat roof snow loads exceed 30 pounds per square foot (1.44 kN/m²), 20 percent shall be combined with seismic loads.
- 3. Where the allowable stress design load combinations of ASCE 7 Section 2.4 are used, crane hook loads need not be combined with *roof live loads* or with more than three-fourths of the snow load or one-half of the wind loads.

1605.1.1 Stability. Regardless of which load combinations are used to design for strength, where overall structure stability (such as stability against overturning, sliding, or buoyancy) is being verified, use of the load combinations specified in

Section 2.3 or 2.4 of ASCE 7, and in Section 1605.2 shall be permitted. Where the load combinations specified in ASCE 7, Section 2.3 are used, strength reduction factors applicable to soil resistance shall be provided by a registered design professional. The stability of retaining walls shall be verified in accordance with Section 1807.2.3.

1605.2 Alternative allowable stress design load combinations. In lieu of the load combinations in ASCE 7, Section 2.4, structures and portions thereof shall be permitted to be designed for the most critical effects resulting from the following combinations. Where using these alternative allowable stress load combinations that include wind or seismic *loads*, allowable stresses are permitted to be increased or load combinations reduced where permitted by the material chapter of this code or the referenced standards. For load combinations that include the counteracting effects of dead and wind *loads*, only two-thirds of the minimum *dead load* likely to be in place during a design wind event shall be used. Where using these alternative load combinations to evaluate sliding, overturning and soil bearing at the soil-structure interface, the reduction of foundation overturning from Section 12.13.4 in ASCE 7 shall not be used. Where using these alternative basic *load* combinations for proportioning foundations for loadings, which include seismic *loads*, the vertical seismic *load effect*, E_{v} , in Equation 12.4-4 of ASCE 7 is permitted to be taken equal to zero. Where required by ASCE 7, Chapters 12, 13 and 15, the load combinations including overstrength of ASCE 7, Section 2.3.6 shall be used.

$D + L + (L_r \text{ or } S \text{ or } R)$	(Equation 16-1)
D + L + 0.6W	(Equation 16-2)
D + L + 0.6W + S/2	(Equation 16-3)
D + L + S + 0.6W/2	(Equation 16-4)
D + L + S + E/1.4	(Equation 16-5)
0.9D + E/1.4	(Equation 16-6)

Exceptions:

- 1. Crane hook *loads* need not be combined with *roof live loads* or with more than three-fourths of the snow load or one-half of the wind load.
- Flat roof snow *loads* of 30 pounds per square foot (1.44 kN/m²) or less and *roof live loads* of 30 pounds per square foot (1.44 kN/m²) or less need not be combined with seismic loads. Where flat roof snow loads exceed 30 pounds per square foot (1.44 kN/m²), 20 percent shall be combined with seismic loads.

SECTION 1606 DEAD LOADS

1606.1 General. *Dead loads* are those *loads* defined in Chapter 2 of this code. *Dead loads* shall be considered to be permanent loads.

1606.2 Weights of materials of construction. For purposes of design, the actual weights of materials of construction shall be used. In the absence of definite information, values used shall be subject to the approval of the *building official*.

1606.3 Weight of fixed service equipment. In determining dead loads for purposes of design, the weight of fixed service equipment, including the maximum weight of the contents of fixed service equipment, shall be included. The components of fixed service equipment that are variable, such as liquid contents and movable trays, shall not be used to counteract forces causing overturning, sliding, and uplift conditions in accordance with Section 1.3.6 of ASCE 7.

Exceptions:

- 1. Where force effects are the result of the presence of the variable components, the components are permitted to be used to counter those load effects. In such cases, the structure shall be designed for force effects with the variable components present and with them absent.
- 2. For the calculation of seismic force effects, the components of fixed service equipment that are variable, such as liquid contents and movable trays, need not exceed those expected during normal operation.

1606.4 Photovoltaic panel systems. The weight of *photovoltaic panel systems*, their support system, and ballast shall be considered as dead *load*.

1606.5 Vegetative and landscaped roofs. The weight of all landscaping and hardscaping materials for vegetative and landscaped roofs shall be considered as *dead load*. The weight shall be computed considering both fully saturated soil and drainage layer materials and fully dry soil and drainage layer materials to determine the most severe *load* effects on the structure.

[S] 1606.6 Solar zone for solar-ready roof. Where a *solar zone* is required by the *International Energy Conservation Code*, it shall be designed for an assumed dead load of 5 pounds per square foot in addition to other required live and dead loads. An area of 2 square feet for each 1000 square feet of solar zone area shall be designed for an assumed dead load of 175 pounds per

square foot. If the actual weight of the system at the time of installation exceeds the assumed loads in this section, the actual weight shall be used to verify the adequacy of the roof structure. This area shall be located within or adjacent to the solar zone. The as-designed dead load and live load for the *solar zone* shall be clearly marked on the *construction documents*.

Note: The 175 psf represents the weight of the inverters necessary for PV systems. See International Energy Conservation Code Section C412.

SECTION 1607 LIVE LOADS

1607.1 General. Live loads are those loads defined in Chapter 2 of this code.

[S] TABLE 1607.1 MINIMUM UNIFORMLY DISTRIBUTED LIVE LOADS, $L_{\rm o}$, AND MINIMUM CONCENTRATED LIVE LOADS

		OCCUPANCY OR USE	UNIFORM (psf)	CONCENTRATED (pounds)	ALSO SEE SECTION
1.	Apartments (see resi	dential)		—	—
2	Access floor	Office use	50	2,000	—
۷.	systems	Computer use	100	2,000	—
3.	Armories and drill re	ooms	150 ^b	—	
		Fixed seats (fastened to floor)	60 ^a		
		Follow spot, projections and control rooms	50		
		Lobbies	100 ^a		
		Movable seats	100 ^a		
		Stage floors	150 ^b		
4.	Assembly areas	Platforms (assembly)	100 ^a		
		Bleachers, folding and telescopic seating and grandstands	100 ^a (See Section 1607.19)		
		Stadiums and arenas with fixed seats (fastened to the floor)	60 ^a (See Section 1607.19)		
		Other assembly areas	100 ^a		
5.	Balconies and decks		1.5 times the live load for the area served, not required to exceed 100		_
6.	Catwalks for mainte	nance and service access	40	300	—
7.	((Cornices)) Canopi	es ^d and cornices	60		—
		First floor	100		
8.	Corridors	Other floors	Same as occupancy served except as indicated		—
9.	Dining rooms and re	estaurants	100 ^a		—
10.	Dwellings (see resid	ential)	_		—
11.	Elevator machine ro (on area of 2 inches	om and control room grating by 2 inches)	_	300	
12.	Finish light floor pla	te construction (on area of 1 inch by 1 inch)	_	200	
13	Fire escapes		100		
15.		On single-family dwellings only	40		
14.	14. Fixed ladders		See Section 1	607.17	—
15.	Garages	Passenger vehicles only	40°	See Section 1607.7	_
		Trucks and buses	See Section 1607.8		
16.	Handrails, guards an	id grab bars	See Section	1607.9	
17.	17. Helipads		See Section 1607.6		—

		OCCUPANCY OR USE	UNIFORM (psf)	CONCENTRATED (pounds)	ALSO SEE SECTION
		Corridors above first floor	80	1,000	
18.	Hospitals	Operating rooms, laboratories	60	1,000	
		Patient rooms	40	1,000	
19.	Hotels (see residential)			_	
		Corridors above first floor	80	1,000	—
20	Libraries	Reading rooms	60	1,000	
20.		Stack rooms	150 ^b	1,000	Section 1607.18
21	M	Heavy	250 ^b	3,000	
21.	Manufacturing	Light	125 ^b	2,000	
22.	((Marquees, except	one- and two-family dwellings)) Reserved.	75		
		Corridors above first floor	80	2,000	
23.	Office buildings	File and computer rooms shall be designed for heavier loads based on anticipated occupancy	_	_	
	8	Lobbies and first-floor corridors	100	2,000	
		Offices	50	2,000	
24	Penal institutions	Cell blocks	40		
27.	renar institutions	Corridors	100		
		Bowling alleys, poolrooms and similar uses	75 ^a		
		Dance halls and ballrooms	100^{a}		
25.	Recreational uses	Gymnasiums	100^{a}		
		Ice skating rinks	250 ^b	-	
		Roller skating rinks	100 ^a	-	
		One- and two-family dwellings:			
		Uninhabitable attics without storage	10		
		Uninhabitable attics with storage	20		
		Habitable attics and sleeping areas	30		
26	Residential	Canopies, including marquees	20		Section
26.		Non-residential portion of live-work units	<u>50ª</u>		1607.22
		All other areas	40	1	
		Hotels and multifamily dwellings:			
		Private rooms and corridors serving them	40	1	
		Public rooms ^a and corridors serving them	100		

[S] TABLE 1607.1—continued MINIMUM UNIFORMLY DISTRIBUTED LIVE LOADS, L_o , AND MINIMUM CONCENTRATED LIVE LOADS

		OCCUPANCY OR USE	UNIFORM (psf)	CONCENTRATED (pounds)	ALSO SEE SECTION
		Ordinary flat, pitched, and curved roofs (that are not occupiable)	20		
		Roof areas used for assembly purposes	100 ^a	_	
		Roof areas used for occupancies other than assembly	Same as occupancy served	_	
		Vegetative and landscaped roofs:		_	
		Roof areas not intended for occupancy	20	_	Section
		Roof areas used for assembly purposes	100 ^a		1607.14.2
		Roof areas used for other occupancies	Same as occupancy served	_	
27.	Roofs	Awnings and canopies:		_	
		Fabric construction supported by a skeleton structure	5 ^a		
		All other construction, except one- and two-family dwellings	20	_	
		Primary roof members exposed to a work floor:	1		
		Single panel point of lower chord of roof trusses or any point along primary structural members supporting roofs over manufacturing, storage warehouses, and repair garages	_	2,000	Section 1607.15.2
		All other primary roof members		300	
		All roof surfaces subject to maintenance workers		300	
		Classrooms	40	1,000	
28.	Schools	Corridors above first floor	80	1,000	
		First-floor corridors	100	1,000	
29.	Scuttles, skylight rib	s and accessible ceilings	—	200	
30.	Sidewalks, vehicular	driveways and yards, subject to trucking	250 ^b	8,000	Section 1607.20
31	Stairs and exits	One- and two-family dwellings	40	300	Section 1607.21
51.	Stall's and exits	All other	100	300	Section 1607.21
32.	Storage areas above	ceilings	20	_	
	Storage ware-	Heavy	250 ^b		
33.	houses (shall be designed for heavier loads if required for anticipated storage)	Light	125 ^b	-	
		Retail:		1	
<u>.</u>	C.	First floor	100	1,000	1
54.	Stores	Upper floors	75	1,000	
		Wholesale, all floors	125 ^b	1,000	1
35.	75. Vehicle barriers		See Section	1607.10	
36.	Walkways and eleva	ted platforms (other than exitways)	60		
37.	Yards and terraces, p	edestrian	100 ^a		

TABLE 1607.1—continued MINIMUM UNIFORMLY DISTRIBUTED LIVE LOADS, L_{o} , AND MINIMUM CONCENTRATED LIVE LOADS

For SI: 1 inch = 25.4 mm, 1 square inch = 645.16 mm^2 , 1 square foot = 0.0929 m^2 , 1 pound per square foot = 0.0479 kN/m^2 , 1 pound = 0.004448 kN, 1 pound per cubic foot = 16 kg/m^3 .

a. Live load reduction is not permitted.

b. Live load reduction is only permitted in accordance with Section 1607.12.1.2 or Item 1 of Section 1607.12.2.

c. Live load reduction is only permitted in accordance with Section 1607.12.1.3 or Item 2 of Section 1607.12.2.

d. This loading condition need only be considered for *canopies* that meet all of the following conditions:

1. The upper surface is sloped less than 30 degrees (0.5 rad) from horizontal; and

2. The canopy is located adjacent to a right of way or assembly area; and

- 3. The *canopy* is located less than 10 feet (3048 mm) above the ground at all points, or less than 10 feet (3048 mm) below an adjacent roof, or less than 10 feet (3048 mm) from operable openings above or adjacent to the level of the *canopy*.
- For other *canopies*, roof loads as specified in this chapter shall be applied. *Canopy* is defined in Section 202.
- **1607.2 Loads not specified.** For occupancies or uses not designated in Section 1607, the *live load* shall be determined in accordance with a method *approved* by the *building official*.

1607.3 Uniform live loads. The *live loads* used in the design of buildings and *other structures* shall be the maximum loads expected by the intended use or occupancy but shall not be less than the minimum uniformly distributed *live loads* given in Table 1607.1.

1607.4 Concentrated live loads. Floors, roofs and other similar surfaces shall be designed to support the uniformly distributed *live loads* prescribed in Section 1607.3 or the concentrated *live loads*, given in Table 1607.1, whichever produces the greater *load effects*. Unless otherwise specified, the indicated concentration shall be assumed to be uniformly distributed over an area of 2-1/2 feet by 2-1/2 feet (762 mm by 762 mm) and shall be located so as to produce the maximum *load effects* in the structural members.

1607.5 Partition loads. In office buildings and in other buildings where partition locations are subject to change, provisions for partition weight shall be made, whether or not partitions are shown on the construction documents, unless the specified *live load* is 80 psf (3.83 kN/m^2) or greater. The partition *load* shall be not less than a uniformly distributed *live load* of 15 psf (0.72 kN/m^2).

1607.6 Helipads. Helipads shall be designed for the following live loads:

- 1. A uniform live load, L, as specified in Items 1.1 and 1.2. This load shall not be reduced.
 - 1.1. 40 psf (1.92 kN/m²) where the design basis helicopter has a maximum take-off weight of 3,000 pounds (13.35 kN) or less.
 - 1.2. 60 psf (2.87 kN/m²) where the design basis helicopter has a maximum take-off weight greater than 3,000 pounds (13.35 kN).
- 2. A single concentrated *live load*, *L*, of 3,000 pounds (13.35 kN) applied over an area of 4.5 inches by 4.5 inches (114 mm by 114 mm) and located so as to produce the maximum *load effects* on the structural elements under consideration. The concentrated *load* is not required to act concurrently with other uniform or concentrated *live loads*.
- 3. Two single concentrated *live loads*, *L*, 8 feet (2438 mm) apart applied on the landing pad (representing the helicopter's two main landing gear, whether skid type or wheeled type), each having a magnitude of 0.75 times the maximum take-off weight of the helicopter, and located so as to produce the maximum *load effects* on the structural elements under consideration. The concentrated loads shall be applied over an area of 8 inches by 8 inches (203 mm by 203 mm) and are not required to act concurrently with other uniform or concentrated *live loads*.

Landing areas designed for a design basis helicopter with maximum take-off weight of 3,000 pounds (13.35 kN) shall be identified with a 3,000-pound (13.34 kN) weight limitation. The landing area weight limitation shall be indicated by the numeral "3" (kips) located in the bottom right corner of the landing area as viewed from the primary approach path. The indication for the landing area weight limitation shall be a minimum 5 feet (1524 mm) in height.

1607.7 Passenger vehicle garages. Floors in garages or portions of a building used for the storage of motor vehicles shall be designed for the uniformly distributed *live loads* indicated in Table 1607.1 or the following concentrated *load*:

- 1. For garages restricted to passenger vehicles accommodating not more than nine passengers, 3,000 pounds (13.35 kN) acting on an area of 4.5 inches by 4.5 inches (114 mm by 114 mm).
- 2. For mechanical parking structures without slab or deck that are used for storing passenger vehicles only, 2,250 pounds (10 kN) per wheel.

1607.8 Heavy vehicle loads. Floors and other surfaces that are intended to support vehicle *loads* greater than a 10,000-pound (4536 kg) gross vehicle weight rating shall comply with Sections 1607.8.1 through 1607.8.5.

1607.8.1 Loads. Where any structure does not restrict access for vehicles that exceed a 10,000-pound (4536 kg) gross vehicle weight rating, those portions of the structure subject to such *loads* shall be designed using the vehicular *live loads*, including consideration of impact and fatigue, in accordance with the codes and specifications required by the jurisdiction having authority for the design and construction of the roadways and bridges in the same location of the structure.

1607.8.2 Fire truck and emergency vehicles. Where a structure or portions of a structure are accessed and loaded by fire department access vehicles and other similar emergency vehicles, the structure shall be designed for the greater of the following *loads*:

- 1. The actual operational *loads*, including outrigger reactions and contact areas of the vehicles as stipulated and *approved* by the *building official*.
- 2. The live loading specified in Section 1607.8.1.

1607.8.3 Heavy vehicle garages. Garages designed to accommodate vehicles that exceed a 10,000-pound (4536 kg) gross vehicle weight rating, shall be designed using the live loading specified by Section 1607.8.1. For garages the design for impact and fatigue is not required.

Exception: The vehicular *live loads* and *load* placement are allowed to be determined using the actual vehicle weights for the vehicles allowed onto the garage floors, provided that such *loads* and placement are based on rational engineering principles and are approved by the building official, but shall be not less than 50 psf (2.9 kN/m^2). This *live load* shall not be reduced.

1607.8.4 Forklifts and movable equipment. Where a structure is intended to have forklifts or other movable equipment present, the structure shall be designed for the total vehicle or equipment *load* and the individual wheel *loads* for the anticipated vehicles as specified by the owner of the facility. These *loads* shall be posted in accordance with Section 1607.8.5.

1607.8.4.1 Impact and fatigue. *Impact loads* and fatigue loading shall be considered in the design of the supporting structure. For the purposes of design, the vehicle and wheel *loads* shall be increased by 30 percent to account for impact.

[S] 1607.8.5 Posting. The maximum weight of vehicles allowed into or on a garage or other structure shall be posted by the owner or the owner's authorized agent in accordance with Section ((106.1)) <u>107</u>.

1607.9 Loads on handrails, guards, grab bars and seats. *Handrails* and *guards* shall be designed and constructed for the structural loading conditions set forth in Section 1607.9.1. Grab bars, shower seats and accessible benches shall be designed and constructed for the structural loading conditions set forth in Section 1607.9.2.

1607.9.1 Handrails and guards. *Handrails* and *guards* shall be designed to resist a linear *load* of 50 pounds per linear foot (plf) (0.73 kN/m) in accordance with Section 4.5.1.1 of ASCE 7. Glass *handrail* assemblies and *guards* shall comply with Section 2407.

Exceptions:

- 1. For one- and two-family dwellings, only the single concentrated *load* required by Section 1607.9.1.1 shall be applied.
- 2. In Group I-3, F, H and S occupancies, for areas that are not accessible to the general public and that have an *occupant load* less than 50, the minimum *load* shall be 20 pounds per foot (0.29 kN/m).

1607.9.1.1 Concentrated load. *Handrails* and *guards* shall be designed to resist a concentrated *load* of 200 pounds (0.89 kN) in accordance with Section 4.5.1 of ASCE 7.

1607.9.1.2 Guard component loads. Balusters, panel fillers and guard infill components, including all rails except the handrail and the top rail, shall be designed to resist a concentrated load of 50 pounds (0.22 kN) in accordance with Section 4.5.1.2 of ASCE 7.

1607.9.2 Grab bars, shower seats and accessible benches. Grab bars, shower seats and accessible benches shall be designed to resist a single concentrated *load* of 250 pounds (1.11 kN) applied in any direction at any point on the grab bar, shower seat, or seat of the accessible bench so as to produce the maximum *load effects*.

1607.10 Vehicle barriers. *Vehicle barriers* for passenger vehicles shall be designed to resist a concentrated *load* of 6,000 pounds (26.70 kN) in accordance with Section 4.5.3 of ASCE 7. Garages accommodating trucks and buses shall be designed in accordance with an *approved* method that contains provisions for traffic railings.

1607.11 Impact loads. The *live loads* specified in Sections 1607.3 through 1607.10 shall be assumed to include adequate allowance for ordinary impact conditions. Provisions shall be made in the structural design for uses and loads that involve unusual vibration and impact forces.

1607.11.1 Elevators. Members, elements and components subject to dynamic *loads* from elevators shall be designed for *impact loads* and deflection limits prescribed by ASME A17.1/CSA B44.

1607.11.2 Machinery. For the purpose of design, the weight of machinery and moving *loads* shall be increased as follows to allow for impact:

- 1. Light machinery, shaft- or motor-driven, 20 percent.
- 2. Reciprocating machinery or power-driven units, 50 percent.

Percentages shall be increased where specified by the manufacturer.

1607.11.3 Elements supporting hoists for façade access and building maintenance equipment. In addition to any other applicable *live loads*, structural elements that support hoists for façade access and building maintenance equipment shall be designed for a *live load* of 2.5 times the rated *load* of the hoist or the stall *load* of the hoist, whichever is larger.

1607.11.4 Fall arrest, lifeline, and rope descent system anchorages. In addition to any other applicable *live loads*, fall arrest, lifeline, and rope descent system anchorages and structural elements that support these anchorages shall be designed for a *live load* of not less than 3,100 pounds (13.8 kN) for each attached line, in any direction that the *load* can be applied.

Anchorages of horizontal lifelines and the structural elements that support these anchorages shall be designed for the maximum tension that develops in the horizontal lifeline from these *live loads*.

1607.12 Reduction in uniform live loads. Except for uniform *live loads* at roofs, all other minimum uniformly distributed *live loads*, L_o , in Table 1607.1 are permitted to be reduced in accordance with Section 1607.12.1 or 1607.12.2. Uniform *live loads* at roofs are permitted to be reduced in accordance with Section 1607.14.2.

1607.12.1 Basic uniform live load reduction. Subject to the limitations of Sections 1607.12.1.1 through 1607.12.1.3 and Table 1607.1, members for which a value of $K_{LL}A_T$ is 400 square feet (37.16 m²) or more are permitted to be designed for a reduced uniformly distributed *live load*, *L*, in accordance with the following equation:

$$L = L_o \left(0.25 + \frac{15}{\sqrt{K_{LL}A_T}} \right)$$

(Equation 16-7)

For SI: $L = L_o \left(0.25 + \frac{4.57}{\sqrt{K_{LL}A_T}} \right)$

where:

L = Reduced design *live load* per square foot (m²) of area supported by the member.

 L_o = Unreduced design *live load* per square foot (m²) of area supported by the member (see Table 1607.1).

 K_{LL} = Live load element factor (see Table 1607.12.1).

 A_T = Tributary area, in square feet (m²).

L shall be not less than $0.50L_o$ for members supporting one floor and L shall be not less than $0.40L_o$ for members supporting two or more floors.

LIVE LOAD ELEMENT FACTOR, K_{LL}	
ELEMENT	KLL
Interior columns	4
Exterior columns without cantilever slabs	4
Edge columns with cantilever slabs	3
Corner columns with cantilever slabs	2
Edge beams without cantilever slabs	2
Interior beams	2
Members not previously identified including:	
Edge beams with cantilever slabs	
Cantilever beams	
One-way slabs	1
Two-way slabs	
Members without provisions for continuous shear transfer normal to their span	

TABLE 1607.12.1 LIVE LOAD ELEMENT FACTOR, K

1607.12.1.1 One-way slabs. The tributary area, A_{τ} , for use in Equation 16-7 for one-way slabs shall not exceed an area defined by the slab span times a width normal to the span of 1.5 times the slab span.

1607.12.1.2 Heavy live loads. Live loads that exceed 100 psf (4.79 kN/m²) shall not be reduced.

Exceptions:

- 1. The *live loads* for members supporting two or more floors are permitted to be reduced by not greater than 20 percent, but the *live load* shall be not less than *L* as calculated in Section 1607.12.1.
- 2. For uses other than storage, where *approved*, additional *live load* reductions shall be permitted where shown by the *registered design professional* that a rational approach has been used and that such reductions are warranted.

STRUCTURAL DESIGN

1607.12.1.3 Passenger vehicle garages. The live loads shall not be reduced in passenger vehicle garages.

Exception: The *live loads* for members supporting two or more floors are permitted to be reduced by not greater than 20 percent, but the *live load* be shall be not less than *L* as calculated in Section 1607.12.1.

1607.12.2 Alternative uniform live load reduction. As an alternative to Section 1607.12.1 and subject to the limitations of Table 1607.1, uniformly distributed *live loads* are permitted to be reduced in accordance with the following provisions. Such reductions shall apply to slab systems, beams, girders, columns, piers, walls and foundations.

1. A reduction shall not be permitted where the *live load* exceeds 100 psf (4.79 kN/m²) except that the design *live load* for members supporting two or more floors is permitted to be reduced by not greater than 20 percent.

Exception: For uses other than storage, where *approved*, additional *live load* reductions shall be permitted where shown by the *registered design professional* that a rational approach has been used and that such reductions are warranted.

- 2. A reduction shall not be permitted in passenger vehicle parking garages except that the *live loads* for members supporting two or more floors are permitted to be reduced by not greater than 20 percent.
- 3. For *live loads* not exceeding 100 psf (4.79 kN/m²), the design *live load* for any structural member supporting 150 square feet (13.94 m²) or more is permitted to be reduced in accordance with Equation 16-8
- 4. For one-way slabs, the area, *A*, for use in Equation 16-8 shall not exceed the product of the slab span and a width normal to the span of 0.5 times the slab span.

R = 0.08(A - 150)

For SI: R = 0.861(A - 13.94)

Such reduction shall not exceed the smallest of:

- 1. 40 percent for members supporting one floor.
- 2. 60 percent for members supporting two or more floors.
- 3. *R* as determined by the following equation:

 $R = 23.1(1 + D/L_o)$

where:

- A = Area of floor supported by the member, square feet (m²).
- D = Dead load per square foot (m²) of area supported.
- L_o = Unreduced *live load* per square foot (m²) of area supported.
- R = Reduction in percent.

1607.13 Distribution of floor loads. Where uniform floor *live loads* are involved in the design of structural members arranged so as to create continuity, the minimum applied loads shall be the full *dead loads* on all spans in combination with the floor *live loads* on spans selected to produce the greatest *load effect* at each location under consideration. Floor *live loads* are permitted to be reduced in accordance with Section 1607.12.

[S] 1607.14 Roof loads. The structural supports of roofs and ((*marquees*)) <u>canopies</u> shall be designed to resist wind and, where applicable, snow and earthquake *loads*, in addition to the *dead load* of construction and the appropriate *live loads* as prescribed in this section. ((, or as set forth in Table 1607.1.)) The *live loads* acting on a sloping surface shall be assumed to act vertically on the horizontal projection of that surface.

1607.14.1 Distribution of roof loads. Where uniform roof live *loads* are reduced to less than 20 psf (0.96 kN/m^2) in accordance with Section 1607.14.2.1 and are applied to the design of structural members arranged so as to create continuity, the reduced roof *live load* shall be applied to adjacent spans or to alternate spans, whichever produces the most unfavorable *load effect*. See Section 1607.14.2 for reductions in minimum roof *live loads* and Section 7.5 of ASCE 7 for ((partial)) snow loading.

1607.14.2 Reduction in uniform roof live loads. The minimum uniformly distributed *live loads* of roofs and ((*marquees*)) *canopies*, L_o , in Table 1607.1 are permitted to be reduced in accordance with Section 1607.14.2.1.

1607.14.2.1 Ordinary roofs, awnings and canopies. Ordinary flat, pitched and curved roofs, and *awnings* and canopies other than of fabric construction supported by a skeleton structure, are permitted to be designed for a reduced uniformly distributed *roof live load*, L_r , as specified in the following equations or other controlling combinations of *loads* as specified in Section 1605, whichever produces the greater *load effect*.

In structures such as *greenhouses*, where special scaffolding is used as a work surface for workers and materials during maintenance and repair operations, a lower roof *load* than specified in the following equations shall not be used

(Equation 16-8)

(Equation 16-9)

unless *approved* by the *building official*. Such structures shall be designed for a minimum roof live *load* of 12 psf (0.58 kN/m^2).

In this prime
$$L_r = L_o R_1 R_2$$
(Equation 16-10)where: $12 \le L_r \le 20$ For SI: $L_r = L_o R_1 R_2$ where: $0.58 \le L_r \le 0.96$ $L_o = Unreduced roof live load per square foot (m2) of horizontal projection supported by the member (see Table 1607.1). $L_r = Reduced roof live load per square foot (m2) of horizontal projection supported by the member.The reduction factors R_1 and R_2 shall be determined as follows: $R_1 = 1$ for $A_t \le 200$ square feet (18.58 m²) $R_1 = 1.2 - 0.001A_t$ for 200 square feet $< A_t < 600$ square feet(Equation 16-12)For SI: $1.2 - 0.011A_t$ for 18.58 square meters $< A_t < 55.74$ square meters$$

$$R_1 = 0.6 \text{ for } A_t \ge 600 \text{ square feet } (55.74 \text{ m}^2)$$
 (Equation 16-13)

where:

 A_i = Tributary area (span length multiplied by effective width) in square feet (m²) supported by the member, and

$R_2 = 1$ for $F \le 4$	(Equation 16-14)
$R_2 = 1.2 - 0.05 F$ for $4 < F < 12$	(Equation 16-15)
$R_2 = 0.6 \text{ for } F \ge 12$	(Equation 16-16)

where:

F = For a sloped roof, the number of inches of rise per foot (for SI: $F = 0.12 \times$ slope, with slope expressed as a percentage), or for an arch or dome, the rise-to-span ratio multiplied by 32.

[S] 1607.14.2.2 Occupiable roofs. Areas of roofs that are occupiable, such as *vegetative roofs*, landscaped roofs ((or for assembly)) or other similar purposes, and ((*marquees*)) *canopies* are permitted to have their uniformly distributed *live loads* reduced in accordance with Section 1607.12.

1607.14.3 Awnings and canopies. *Awnings* and canopies shall be designed for uniform *live loads* as required in Table 1607.1 as well as for snow *loads* and wind *loads* as specified in Sections 1608 and 1609.

1607.14.4 Photovoltaic panel systems. Roof structures that provide support for *photovoltaic panel systems* shall be designed in accordance with Sections 1607.14.4.1 through 1607.14.4.5, as applicable.

1607.14.4.1 Roof live load. Roof structures that support *photovoltaic panel systems* shall be designed to resist each of the following conditions:

1. Applicable uniform and concentrated roof *loads* with the *photovoltaic panel system dead loads*.

Exception: *Roof live loads* need not be applied to the area covered by *photovoltaic panels* where the clear space between the panels and the roof surface is 24 inches (610 mm) or less.

2. Applicable uniform and concentrated roof loads without the *photovoltaic panel system* present.

1607.14.4.2 Photovoltaic panels or modules. The structure of a roof that supports solar *photovoltaic panels* or modules shall be designed to accommodate the full solar *photovoltaic panels* or modules and ballast *dead load*, including concentrated *loads* from support frames in combination with the *loads* from Section 1607.14.4.1 and other applicable *loads*. Where applicable, snow drift *loads* created by the *photovoltaic panels* or modules shall be included.

1607.14.4.3 Photovoltaic panels installed on open grid roof structures. Structures with open grid framing and without a *roof deck* or sheathing supporting *photovoltaic panel systems* shall be designed to support the uniform and concentrated *roof live loads* specified in Section 1607.14.4.1, except that the uniform *roof live load* shall be permitted to be reduced to 12 $psf(0.57 \text{ kN/m}^2)$.

1607.14.4.4 Ground-mounted photovoltaic (PV) panel systems. Ground-mounted photovoltaic (PV) panel systems that are independent structures and do not have accessible/occupied space underneath are not required to accommodate a roof photovoltaic *live load*. Other *loads* and combinations in accordance with Section 1605 shall be accommodated.

1607.14.4.5 Ballasted photovoltaic panel systems. Roof structures that provide support for ballasted *photovoltaic panel systems* shall be designed, or analyzed, in accordance with Section 1604.4; checked in accordance with Section 1604.3.6 for deflections; and checked in accordance with Section 1611 for ponding.

1607.15 Crane loads. The crane *live load* shall be the rated capacity of the crane. Design *loads* for the runway beams, including connections and support brackets, of moving bridge cranes and monorail cranes shall include the maximum wheel *loads* of the crane and the vertical impact, lateral and longitudinal forces induced by the moving crane.

1607.15.1 Maximum wheel load. The maximum wheel *loads* shall be the wheel *loads* produced by the weight of the bridge, as applicable, plus the sum of the rated capacity and the weight of the trolley with the trolley positioned on its runway at the location where the resulting *load effect* is maximum.

1607.15.2 Vertical impact force. The maximum wheel *loads* of the crane shall be increased by the following percentages to account for the effects of vertical impact or vibration:

Monorail cranes (powered)	25 percent
Cab-operated or remotely operated bridge cranes (powered)	25 percent
Pendant-operated bridge cranes (powered)	10 percent
Bridge cranes or monorail cranes with hand-geared bridge, trolley and hoist	0 percent

1607.15.3 Lateral force. The lateral force on crane runway beams with electrically powered trolleys shall be calculated as 20 percent of the sum of the rated capacity of the crane and the weight of the hoist and trolley. The lateral force shall be assumed to act horizontally at the traction surface of a runway beam, in either direction perpendicular to the beam, and shall be distributed with due regard to the lateral stiffness of the runway beam and supporting structure.

1607.15.4 Longitudinal force. The longitudinal force on crane runway beams, except for bridge cranes with hand-geared bridges, shall be calculated as 10 percent of the maximum wheel *loads* of the crane. The longitudinal force shall be assumed to act horizontally at the traction surface of a runway beam, in either direction parallel to the beam.

1607.16 Interior walls and partitions. Interior walls and partitions that exceed 6 feet (1829 mm) in height, including their finish materials, shall have adequate strength and stiffness to resist the *loads* to which they are subjected but not less than a horizontal *load* of 5 psf (0.240 kN/m^2).

1607.16.1 Fabric partitions. *Fabric partitions* that exceed 6 feet (1829 mm) in height, including their finish materials, shall have adequate strength and stiffness to resist the following *load* conditions:

- 1. The horizontal distributed *load* need only be applied to the partition framing. The total area used to determine the distributed *load* shall be the area of the fabric face between the framing members to which the fabric is attached. The total distributed *load* shall be uniformly applied to such framing members in proportion to the length of each member.
- 2. A concentrated *load* of 40 pounds (0.176 kN) applied to an 8-inch-diameter (203 mm) area [50.3 square inches (32 452 mm²)] of the fabric face at a height of 54 inches (1372 mm) above the floor.

(($\frac{1607.16.2 \text{ Fire walls.}}{1000 \text{ In order to meet the structural stability requirements of Section 706.2 where the structure on either side of the wall has collapsed,$ *fire walls*and their supports shall be designed to withstand a minimum horizontal allowable stress*load*of 5 psf (0.240 kN/m²).))

1607.17 Fixed ladders. Fixed ladders with rungs shall be designed to resist a single concentrated *load* of 300 pounds (1.33 kN) in accordance with Section 4.5.4 of ASCE 7. Where rails of fixed ladders extend above a floor or platform at the top of the ladder, each side rail extension shall be designed to resist a single concentrated *load* of 100 pounds (0.445 kN) in accordance with Section 4.5.4 of ASCE 7. Ship's ladders shall be designed to resist the *stair loads* given in Table 1607.1.

1607.18 Library stack rooms. The live loading indicated in Table 1607.1 for library stack rooms applies to stack room floors that support nonmobile, double-faced library book stacks, subject to the following limitations:

- 1. The nominal book stack unit height shall not exceed 90 inches (2290 mm).
- 2. The nominal shelf depth shall not exceed 12 inches (305 mm) for each face.
- 3. Parallel rows of double-faced book stacks shall be separated by aisles not less than 36 inches (914 mm) in width.

1607.19 Seating for assembly uses. *Bleachers, folding and telescopic seating* and *grandstands* shall be designed for the *loads* specified in ICC 300. Stadiums and arenas with fixed seats shall be designed for the horizontal sway *loads* in Section 1607.19.1.

1607.19.1 Horizontal sway loads. The design of stadiums and arenas with fixed seats shall include horizontal swaying forces applied to each row of seats as follows:

- 1. 24 pounds per linear foot (0.35 kN/m) of seat applied in a direction parallel to each row of seats.
- 2. 10 pounds per linear foot (0.15 kN/m) of seat applied in a direction perpendicular to each row of seats.

The parallel and perpendicular horizontal swaying forces are not required to be applied simultaneously.

1607.20 Sidewalks, vehicular driveways, and yards subject to trucking. The live loading indicated in Table 1607.1 for sidewalks, vehicular driveways, and yards subject to trucking shall comply with the requirements of this section.

1607.20.1 Uniform loads. In addition to the *loads* indicated in Table 1607.1, other uniform *loads* in accordance with an approved method that contains provisions for truck loading shall be considered where appropriate.

1607.20.2 Concentrated loads. The concentrated wheel *load* indicated in Table 1607.1 shall be applied on an area of 4-1/2 inches by 4-1/2 inches (114 mm by 114 mm).

1607.21 Stair treads. The concentrated *load* indicated in Table 1607.1 for *stair* treads shall be applied on an area of 2 inches by 2 inches (51 mm by 51 mm). This *load* need not be assumed to act concurrently with the uniform *load*.

1607.22 Residential attics. The *live loads* indicated in Table 1607.1 for *attics* in residential occupancies shall comply with the requirements of this section.

1607.22.1 Uninhabitable attics without storage. In residential occupancies, uninhabitable *attic* areas without storage are those where the maximum clear height between the joists and rafters is less than 42 inches (1067 mm), or where there are not two or more adjacent trusses with web configurations capable of accommodating an assumed rectangle 42 inches (1067 mm) in height by 24 inches (610 mm) in width, or greater, within the plane of the trusses. The *live load* in Table 1607.1 need not be assumed to act concurrently with any other *live load* requirement.

1607.22.2 Uninhabitable attics with storage. In residential occupancies, uninhabitable attic areas with storage are those where the maximum clear height between the joist and rafter is 42 inches (1067 mm) or greater, or where there are two or more adjacent trusses with web configurations capable of accommodating an assumed rectangle 42 inches (1067 mm) in height by 24 inches (610 mm) in width, or greater, within the plane of the trusses. The live load in Table 1607.1 need only be applied to those portions of the joists or truss bottom chords where both of the following conditions are met:

- 1. The attic area is accessed from an opening not less than 20 inches (508 mm) in width by 30 inches (762 mm) in length that is located where the clear height in the attic is not less than 30 inches (762 mm).
- 2. The slope of the joists or truss bottom chords is not greater than 2 units vertical in 12 units horizontal.

The remaining portions of the joists or truss bottom chords shall be designed for a uniformly distributed concurrent live load of not less than 10 pounds per square foot (0.48 kN/m^2) .

1607.22.3 Attics served by stairs. Attic spaces served by stairways other than the pull-down type shall be designed to support the minimum *live load* specified for habitable *attics* and sleeping rooms.

SECTION 1608 SNOW LOADS

[S] 1608.1 General. <u>Roofs shall be designed for a uniform snow load of at least 25 psf (1200 Pa)</u>. Design snow *loads* shall be determined in accordance with Chapter 7 of ASCE 7, but the design roof *load* shall be not less than that determined by Section 1607.

1608.2 Ground snow loads. The ground snow *loads* to be used in determining the design snow *loads* for roofs shall be determined in accordance with ASCE 7 or Figures 1608.2(1) and 1608.2(2) for the contiguous United States and Table 1608.2 for Alaska. Site-specific case studies shall be made in areas designated "CS" in Figures 1608.2(1) and 1608.2(2). Ground snow *loads* for sites at elevations above the limits indicated in Figures 1608.2(1) and 1608.2(2) and for all sites within the CS areas shall be *approved*. Ground snow *load* determination for such sites shall be based on an extreme value statistical analysis of data available in the vicinity of the site using a value with a 2-percent annual probability of being exceeded (50-year mean recurrence interval). Snow loads are zero for Hawaii, except in mountainous regions as *approved* by the *building official*.

Adak30Anchorage50Angoon70Barrow25Barter Island35Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	LOCATION	POUNDS PER SQUARE FOOT
Anchorage50Angoon70Barrow25Barter Island35Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Adak	30
Angoon70Barrow25Barter Island35Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Anchorage	50
Barrow25Barter Island35Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Angoon	70
Barter Island35Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Barrow	25
Bethel40Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Barter Island	35
Big Delta50Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Bethel	40
Cold Bay25Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Big Delta	50
Cordova100Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Cold Bay	25
Fairbanks60Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Cordova	100
Fort Yukon60Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Fairbanks	60
Galena60Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Fort Yukon	60
Gulkana70Homer40Juneau60Kenai70Kodiak30Kotzebue60	Galena	60
Homer40Juneau60Kenai70Kodiak30Kotzebue60	Gulkana	70
Juneau60Kenai70Kodiak30Kotzebue60	Homer	40
Kenai70Kodiak30Kotzebue60	Juneau	60
Kodiak30Kotzebue60	Kenai	70
Kotzebue 60	Kodiak	30
	Kotzebue	60
McGrath 70	McGrath	70
Nenana 80	Nenana	80
Nome 70	Nome	70
Palmer 50	Palmer	50
Petersburg 150	Petersburg	150
St. Paul Islands 40	St. Paul Islands	40
Seward 50	Seward	50
Shemya 25	Shemya	25
Sitka 50	Sitka	50
Talkeetna 120	Talkeetna	120
Unalakleet 50	Unalakleet	50
Valdez 160	Valdez	160
Whittier 300	Whittier	300
Wrangell 60	Wrangell	60
Yakutat 150	Yakutat	150

TABLE 1608.2
GROUND SNOW LOADS, \pmb{p}_g , FOR ALASKAN LOCATIONS

For SI:1 pound per square foot = 0.0479 kN/m^2 .

STRUCTURAL DESIGN





FIGURE 1608.2(1) GROUND SNOW LOADS, p_g , FOR THE UNITED STATES (psf)



NOTE: See ASCE 7 Table 7.2-8 for New Hampshire.

FIGURE 1608.2(2) GROUND SNOW LOADS, p_g , FOR THE UNITED STATES (psf)

1608.3 Ponding instability. *Susceptible bays* of roofs shall be evaluated for ponding instability in accordance with Chapters 7 and 8 of ASCE 7.

SECTION 1609 WIND LOADS

1609.1 Applications. Buildings, structures and parts thereof shall be designed to withstand the minimum wind *loads* prescribed herein. Decreases in wind *loads* shall not be made for the effect of shielding by *other structures*.

1609.1.1 Determination of wind loads. Wind *loads* on every building or structure shall be determined in accordance with Chapters 26 to 30 of ASCE 7. The type of opening protection required, the basic design *wind speed*, *V*, and the exposure category for a site is permitted to be determined in accordance with Section 1609 or ASCE 7. Wind shall be assumed to come from any horizontal direction and wind pressures shall be assumed to act normal to the surface considered.

Exceptions:

- 1. Subject to the limitations of Section 1609.1.1.1, the provisions of ICC 600 shall be permitted for applicable Group R-2 and R-3 buildings.
- 2. Subject to the limitations of Section 1609.1.1.1, residential structures using the provisions of AWC WFCM.
- 3. Subject to the limitations of Section 1609.1.1.1, residential structures using the provisions of AISI S230.
- 4. Designs using NAAMM FP 1001.
- 5. Designs using TIA-222 for antenna-supporting structures and antennas, provided that the horizontal extent of Topographic Category 2 escarpments in Section 2.6.6.2 of TIA-222 shall be 16 times the height of the escarpment.
- 6. Wind tunnel tests in accordance with ASCE 49 and Sections 31.4 and 31.5 of ASCE 7.

The wind speeds in Figures 1609.3(1) through 1609.3(12) are basic design wind speeds, V, and shall be converted in accordance with Section 1609.3.1 to allowable stress design wind speeds, V_{asd} , when the provisions of the standards referenced in Exceptions 4 and 5 are used.

1609.1.1.1 Applicability. The provisions of ICC 600 are applicable only to buildings located within Exposure B or C as defined in Section 1609.4. The provisions of ICC 600, AWC WFCM and AISI S230 shall not apply to buildings sited on the upper half of an isolated hill, ridge or escarpment meeting all of the following conditions:

- 1. The hill, ridge or escarpment is 60 feet (18 288 mm) or higher if located in Exposure B or 30 feet (9144 mm) or higher if located in Exposure C.
- 2. The maximum average slope of the hill exceeds 10 percent.
- 3. The hill, ridge or escarpment is unobstructed upwind by other such topographic features for a distance from the high point of 50 times the height of the hill or 2 miles (3.22 km), whichever is greater.

1609.2 Protection of openings. In *windborne debris regions*, glazing in buildings shall be impact resistant or protected with an impact-resistant covering meeting the requirements of an *approved* impact-resistant standard or ASTM E1996 referenced herein as follows:

- 1. Glazed openings located within 30 feet (9144 mm) of grade shall meet the requirements of the large missile test of ASTM E1996.
- 2. Glazed openings located more than 30 feet (9144 mm) above grade shall meet the provisions of the small missile test of ASTM E1996.

Exceptions:

- 1. Wood structural panels with a minimum thickness of 7/16 inch (11.1 mm) and maximum panel span of 8 feet (2438 mm) shall be permitted for opening protection in buildings with a mean roof height of 33 feet (10 058 mm) or less that are classified as a Group R-3 or R-4 occupancy. Panels shall be precut so that they shall be attached to the framing surrounding the opening containing the product with the glazed opening. Panels shall be predrilled as required for the anchorage method and shall be secured with the attachment hardware provided. Attachments shall be designed to resist the components and cladding *loads* determined in accordance with the provisions of ASCE 7, with corrosion-resistant attachment hardware provided and anchors permanently installed on the building. Attachment in accordance with Table 1609.2 with corrosion-resistant attachment hardware provided and anchors permanently installed on the building is permitted for buildings with a mean roof height of 45 feet (13 716 mm) or less where V_{asd} determined in accordance with Section 1609.3.1 does not exceed 140 mph (63 m/s).
- 2. Glazing in *Risk Category* I buildings, including *greenhouses* that are occupied for growing plants on a production or research basis, without public access shall be permitted to be unprotected.
- 3. Glazing in *Risk Category* II, III or IV buildings located over 60 feet (18 288 mm) above the ground and over 30 feet (9144 mm) above *aggregate* surface roofs located within 1,500 feet (458 m) of the building shall be permitted to be unprotected.

TABLE 1609.2 WINDBORNE DEBRIS PROTECTION FASTENING SCHEDULE FOR WOOD STRUCTURAL PANELS^{a, b, c, d}

	FASTENER SPACING (inches)			
	Panel Span ≤ 4 feet	4 feet < Panel Span ≤ 6 feet	6 feet < Panel Span ≤ 8 feet	
No. 8 wood-screw-based anchor with 2-inch embedment length	16	10	8	
No. 10 wood-screw-based anchor with 2-inch embedment length	16	12	9	
1/4-inch diameter lag-screw-based anchor with 2-inch embedment length	16	16	16	

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm, 1 pound = 4.448 N, 1 mile per hour = 0.447 m/s.

a. This table is based on 140 mph wind speeds and a 45-foot mean roof height.

b. Fasteners shall be installed at opposing ends of the wood structural panel. Fasteners shall be located not less than 1 inch from the edge of the panel.

c. Anchors shall penetrate through the exterior wall covering with an embedment length of 2 inches minimum into the building frame. Fasteners shall be located not less than 2-1/2 inches from the edge of concrete block or concrete.

d. Where panels are attached to masonry or masonry/stucco, they shall be attached using vibration-resistant anchors having a minimum ultimate withdrawal capacity of 1,500 pounds.

1609.2.1 Louvers. Louvers protecting intake and exhaust ventilation ducts not assumed to be open that are located within 30 feet (9144 mm) of grade shall meet the requirements of AMCA 540.

1609.2.2 Application of ASTM E1996. The text of Section 6.2.2 of ASTM E1996 shall be substituted as follows:

6.2.2 Unless otherwise specified, select the wind zone based on the basic design wind speed, V, as follows:

6.2.2.1 Wind Zone l—130 mph \leq basic design wind speed, V < 140 mph.

6.2.2.2 Wind Zone 2—140 mph \leq basic design wind speed, V < 150 mph at greater than one mile (1.6 km) from the coastline. The coastline shall be measured from the mean high water mark.

6.2.2.3 Wind Zone 3—150 mph (67 m/s) \leq basic design wind speed, $V \leq$ 160 mph (72 m/s), or 140 mph (63 m/s) \leq basic design wind speed, $V \leq$ 160 mph (72 m/s) and within one mile (1.6 km) of the coastline. The coastline shall be measured from the mean high water mark.

6.2.2.4 Wind Zone 4— basic design wind speed, V > 160 mph (72 m/s).

1609.2.3 Garage doors. Garage door glazed opening protection for windborne debris shall meet the requirements of an *approved* impact-resisting standard or ANSI/DASMA 115.

1609.3 Basic design wind speed. The basic design *wind speed*, *V*, in mph, for the determination of the wind *loads* shall be determined by Figures 1609.3(1) through 1609.3(12). The basic design *wind speed*, *V*, for use in the design of *Risk Category* II buildings and structures shall be obtained from Figures 1609.3(1), 1609.3(5) and 1609.3(6). The basic design *wind speed*, *V*, for use in the design of *Risk Category* III buildings and structures shall be obtained from Figures 1609.3(2), 1609.3(7) and 1609.3(8). The basic design *wind speed*, *V*, for use in the design of *Risk Category* II buildings and structures shall be obtained from Figures 1609.3(3), 1609.3(9) and 1609.3(10). The basic design *wind speed*, *V*, for use in the design of *Risk Category* I buildings and structures shall be obtained from Figures 1609.3(1), 1609.3(1) and 1609.3(1). The basic design *wind speed*, *V*, for use in the design of *Risk Category* I buildings and structures shall be obtained from Figures 1609.3(1), 1609.3(1). The basic design *wind speed*, *V*, for use in the design of *Risk Category* I buildings and structures shall be obtained from Figures 1609.3(4), 1609.3(11) and 1609.3(12). The basic design *wind speed*, *V*, for the special wind regions indicated near mountainous terrain and near gorges shall be in accordance with local jurisdiction requirements. The basic design wind speeds, *V*, determined by the local jurisdiction shall be in accordance with Chapter 26 of ASCE 7.

In nonhurricane-prone regions, when the basic design *wind speed*, *V*, is estimated from regional climatic data, the basic design *wind speed*, *V*, shall be determined in accordance with Chapter 26 of ASCE 7.

1609.3.1 Wind speed conversion. Where required, the basic design wind speeds of Figures 1609.3(1) through 1609.3(12) shall be converted to *allowable stress design* wind speeds, V_{asd} , using Table 1609.3.1 or Equation 16-17.

$$V_{asd} = V_{\sqrt{0.6}}$$

(Equation 16-17)

where:

- $V_{asd} = Allowable stress design wind speed applicable to methods specified in Exceptions 4 and 5 of Section 1609.1.1.$
- V = Basic design wind speeds determined from Figures 1609.3(1) through 1609.3(12).



- 1. Values are nominal design 3-second gust wind speeds in miles per hour (m/s) at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours. Point values are provided to aid with interpolation.
- 3. Islands, coastal areas, and land boundaries outside the last contour shall use the last wind speed contour.
- 4. Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.
- 5. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).
- 6. Location-specific basic wind speeds shall be permitted to be determined using www.atcouncil.org/windspeed

FIGURE 1609.3(1)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY I BUILDINGS AND OTHER STRUCTURES



- 1. Values are nominal design 3-second gust wind speeds in miles per hour (m/s) at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours. Point values are provided to aid with interpolation.
- 3. Islands, coastal areas, and land boundaries outside the last contour shall use the last wind speed contour.
- 4. Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.
- 5. Wind speeds correspond to approximately a 3% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).
- 6. Location-specific basic wind speeds shall be permitted to be determined using www.atcouncil.org/windspeed

FIGURE 1609.3(2) BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY III BUILDINGS AND OTHER STRUCTURES



- 1. Values are nominal design 3-second gust wind speeds in miles per hour (m/s) at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours. Point values are provided to aid with interpolation.
- 3. Islands, coastal areas, and land boundaries outside the last contour shall use the last wind speed contour.
- 4. Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.
- 5. Wind speeds correspond to approximately a 1.6% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00033, MRI = 3000 Years).
- 6. Location-specific basic wind speeds shall be permitted to be determined using www.atcouncil.org/windspeed

FIGURE 1609.3(3) BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY IV BUILDINGS AND OTHER STRUCTURES



- 1. Values are nominal design 3-second gust wind speeds in miles per hour (m/s) at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours. Point values are provided to aid with interpolation.
- 3. Islands, coastal areas, and land boundaries outside the last contour shall use the last wind speed contour.
- 4. Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.
- 5. Wind speeds correspond to approximately a 15% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00333, MRI = 300 Years).
- 6. Location-specific basic wind speeds shall be permitted to be determined using www.atcouncil.org/windspeed.

FIGURE 1609.3(4)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY I BUILDINGS AND OTHER STRUCTURES



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the las wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{π} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(5)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY II BÙILDINGS AND OTHER STRUCTURES IN HAWAI



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the las wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{zt} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(6)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY II BUILDINGS AND OTHER STRUCTURES IN HAWAII (OAHU, KAUAI)



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the las wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{a} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 3% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(7)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY III BUILDINGS AND OTHER STRUCTURES IN HAWAII



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C Category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the las wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{x} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 3% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(8)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY III BUILDINGS AND OTHER STRUCTURES IN HAWAII (OAHU, KAUAI)



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the last wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{a} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 1.7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(9)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY IV BUILDINGS AND OTHER STRUCTURES IN HAWAII



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the last wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{zt} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 1.7% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(10)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY IV BUILDINGS AND OTHER STRUCTURES IN HAWAII (OAHU, KAUAI)



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the last wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of Kzt of 1.0 and Kd as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 15% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(12) BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY I BUILDINGS AND OTHER STRUCTURES IN HAWAII (OAHU, KAUAI)



- 1. Values are nominal design 3-second gust wind speeds in miles per hour at 33 feet (10 m) above ground for Exposure C category.
- 2. Linear interpolation between contours is permitted.
- 3. Islands and coastal areas outside the last contour shall use the last wind speed contour of the coastal area.
- 4. It is permitted to use the standard values of K_{a} of 1.0 and K_{d} as given in Table 26.6-1 of ASCE 7.
- 5. Ocean promontories and local escarpments shall be examined for unusual wind conditions.
- 6. Wind speeds correspond to approximately a 15% probability of exceedance in 50 years (Annual Exceedance Probability = 0.00143, MRI = 700 Years).

FIGURE 1609.3(11)

BASIC DESIGN WIND SPEEDS, V, FOR RISK CATEGORY I BUILDINGS AND OTHER STRUCTURES IN HAWAII

WIND SPEED CONVERSIONS ^{4,4,4}											
V	100	110	120	130	140	150	160	170	180	190	200
V_{asd}	78	85	93	101	108	116	124	132	139	147	155

TABLE 1609.3.1 VIND SPEED CONVERSIONS^{a, b, c}

For SI: 1 mile per hour = 0.44 m/s. a. Linear interpolation is permitted.

b. V_{ref} = allowable stress design wind speed applicable to methods specified in Exceptions 1 through 5 of Section 1609.1.1.

c. V = basic design wind speeds determined from Figures 1609.3(1) through 1609.3(12).

1609.4 Exposure category. For each wind direction considered, an exposure category that adequately reflects the characteristics of ground surface irregularities shall be determined for the site at which the building or structure is to be constructed. Account shall be taken of variations in ground surface roughness that arise from natural topography and vegetation as well as from constructed features.

1609.4.1 Wind directions and sectors. For each selected wind direction at which the wind *loads* are to be evaluated, the exposure of the building or structure shall be determined for the two upwind sectors extending 45 degrees (0.79 rad) either side of the selected wind direction. The exposures in these two sectors shall be determined in accordance with Sections 1609.4.2 and 1609.4.3 and the exposure resulting in the highest wind *loads* shall be used to represent winds from that direction.

1609.4.2 Surface roughness categories. A ground surface roughness within each 45-degree (0.79 rad) sector shall be determined for a distance upwind of the site as defined in Section 1609.4.3 from the following categories, for the purpose of assigning an exposure category as defined in Section 1609.4.3.

Surface Roughness B. Urban and suburban areas, wooded areas or other terrain with numerous closely spaced obstructions having the size of single-family dwellings or larger.

Surface Roughness C. Open terrain with scattered obstructions having heights generally less than 30 feet (9144 mm). This category includes flat open country, and grasslands.

Surface Roughness D. Flat, unobstructed areas and water surfaces. This category includes smooth mud flats, salt flats and unbroken ice.

[S] 1609.4.3 Exposure categories. An exposure category shall be determined in accordance with the following:

((Exposure B. For buildings with a mean roof height of less than or equal to 30 feet (9144 mm), Exposure B shall apply where the ground surface roughness, as defined by Surface Roughness B, prevails in the upwind direction for a distance of not less than 1,500 feet (457 m). For buildings with a mean roof height greater than 30 feet (9144 mm), Exposure B shall apply where Surface Roughness B prevails in the upwind direction for a distance of not less than 2,600 feet (792 m) or 20 times the height of the building, whichever is greater.

Exposure C. Exposure C shall apply for all cases where Exposure B or D does not apply.

Exposure D. Exposure D shall apply where the ground surface roughness, as defined by Surface Roughness D, prevails in the upwind direction for a distance of not less than 5,000 feet (1524 m) or 20 times the height of the building, whichever is greater. Exposure D shall apply where the ground surface roughness immediately upwind of the site is B or C, and the site is within a distance of 600 feet (183 m) or 20 times the *building height*, whichever is greater, from an Exposure D condition as defined in the previous sentence.))

Exposure B. Exposure B shall apply for all cases where Exposure C does not apply.

Exposure C. Exposure C shall apply along the shorelines where the ground surface roughness, as defined by Surface Roughness D, prevails in the following conditions:

- 1. The upwind direction of the shoreline is exposed to winds coming from the south through west (180 degrees to 270 degrees), and
- 2. The distance of Surface Roughness D is at least 5,000 feet (1524 m).

Exposure C extends a distance of 600 feet (183 m) from the shoreline as defined in the previous sentence.

Exposure D. Exposure D shall not apply anywhere within the City of Seattle.

Interpretation I1609.4.3: A map of the Exposure C areas is provided at https://www.seattle.gov/sdci/resources/ wind-load-factors.

1609.5 Roof systems. Roof systems shall be designed and constructed in accordance with Sections 1609.5.1 through 1609.5.3, as applicable.

(Equation 16-18)

1609.5.1 Roof deck. The *roof deck* shall be designed to withstand the wind pressures determined in accordance with ASCE 7.

1609.5.2 Roof coverings. Roof coverings shall comply with Section 1609.5.1.

Exception: Rigid tile *roof coverings* that are air permeable and installed over a *roof deck* complying with Section 1609.5.1 are permitted to be designed in accordance with Section 1609.5.3.

Asphalt shingles installed over a *roof deck* complying with Section 1609.5.1 shall comply with the wind-resistance requirements of Section 1504.2.

1609.5.3 Rigid tile. Wind *loads* on rigid tile *roof coverings* shall be determined in accordance with the following equation:

 $M_a = q_h C_L b L L_a [1.0 - G C_p]$

For SI:

$$M_a = \frac{q_h C_L b L L_a [1.0 - G C_p]}{1,000}$$

where:

- b = Exposed width, feet (mm) of the roof tile.
- C_L = Lift coefficient. The lift coefficient for concrete and clay tile shall be 0.2 or shall be determined by test in accordance with Section 1504.3.1.
- GC_p = Roof pressure coefficient for each applicable roof zone determined from Chapter 30 of ASCE 7. Roof coefficients shall not be adjusted for internal pressure.
- L = Length, feet (mm) of the roof tile.
- L_a = Moment arm, feet (mm) from the axis of rotation to the point of uplift on the roof tile. The point of uplift shall be taken at 0.76L from the head of the tile and the middle of the exposed width. For roof tiles with nails or screws (with or without a tail clip), the axis of rotation shall be taken as the head of the tile for direct deck application or as the top edge of the batten for battened applications. For roof tiles fastened only by a nail or screw along the side of the tile, the axis of rotation shall be determined by testing. For roof tiles installed with battens and fastened only by a clip near the tail of the tile, the moment arm shall be determined about the top edge of the batten with consideration given for the point of rotation of the tiles based on straight bond or broken bond and the tile profile.
- M_a = Aerodynamic uplift moment, feet-pounds (N-mm) acting to raise the tail of the tile.
- q_h = Wind velocity pressure, psf (kN/m²) determined from Section 26.10.2 of ASCE 7.

Concrete and clay roof tiles complying with the following limitations shall be designed to withstand the aerodynamic uplift moment as determined by this section.

- 1. The roof tiles shall be either loose laid on battens, mechanically fastened, mortar set or adhesive set.
- 2. The roof tiles shall be installed on solid sheathing that has been designed as components and cladding.
- 3. An *underlayment* shall be installed in accordance with Chapter 15.
- 4. The tile shall be single lapped interlocking with a minimum head lap of not less than 2 inches (51 mm).
- 5. The length of the tile shall be between 1.0 and 1.75 feet (305 mm and 533 mm).
- 6. The exposed width of the tile shall be between 0.67 and 1.25 feet (204 mm and 381 mm).
- 7. The maximum thickness of the tail of the tile shall not exceed 1.3 inches (33 mm).
- 8. Roof tiles using *mortar* set or adhesive set systems shall have not less than two-thirds of the tile's area free of *mortar* or adhesive contact.

SECTION 1610 SOIL LOADS AND HYDROSTATIC PRESSURE

1610.1 Lateral pressures. Foundation walls and retaining walls shall be designed to resist lateral soil *loads* from adjacent soil. Soil *loads* specified in Table 1610.1 shall be used as the minimum design lateral soil *loads* unless determined otherwise by a geotechnical investigation in accordance with Section 1803. Foundation walls and other walls in which horizontal movement is restricted at the top shall be designed for at-rest pressure. Retaining walls free to move and rotate at the top shall be permitted to be designed for active pressure. Lateral pressure from surcharge *loads* shall be added to the lateral soil *load*. Lateral pressure shall be increased if expansive soils are present at the site. Foundation walls shall be designed to support the weight of the full hydrostatic pressure of undrained backfill unless a drainage system is installed in accordance with Sections 1805.4.2 and 1805.4.3.

Exception: Foundation walls extending not more than 8 feet (2438 mm) below grade and laterally supported at the top by flexible *diaphragms* shall be permitted to be designed for active pressure.

LATERAL SOIL LOAD				
UNIFIED SOIL	DESIGN LATERAL SOIL LOAD ^a (pound per square foot per foot of depth)			
CLASSIFICATION	Active pressure	At-rest pressure		
GW	30	60		
GP	30	60		
GM	40	60		
GC	45	60		
SW	30	60		
SP	30	60		
SM	45	60		
SM-SC	45	100		
SC	60	100		
ML	45	100		
ML-CL	60	100		
CL	60	100		
OL	Note b	Note b		
MH	Note b	Note b		
СН	Note b	Note b		
ОН	Note b	Note b		
	ATERAL SOIL LOADUNIFIED SOIL CLASSIFICATIONGWGPGMGCSWSPSMSM-SCSCMLML-CLCLOLMHCHOH	ATERAL SOIL LOADUNIFIED SOIL CLASSIFICATIONDESIGN LATER (pound per square for Active pressure)GW30GP30GM40GC45SW30SP30SM45SM-SC45SC60ML45ML-CL60CL60OLNote bMHNote bOHNote b		

TABLE 1610.1 LATERAL SOIL LOAD

For SI: 1 pound per square foot per foot of depth = 0.157 kPa/m, 1 foot = 304.8 mm.

a. Design lateral soil loads are given for moist conditions for the specified soils at their optimum densities. Actual field conditions shall govern. Submerged or saturated soil pressures shall include the weight of the buoyant soil plus the hydrostatic loads.

b. Unsuitable as backfill material.

c. The definition and classification of soil materials shall be in accordance with ASTM D2487.

1610.2 Uplift loads on floor and foundations. Basement floors, slabs on ground, foundations, and similar approximately horizontal elements below grade shall be designed to resist uplift *loads* where applicable. The upward pressure of water shall be taken as the full hydrostatic pressure applied over the entire area. The hydrostatic *load* shall be measured from the underside of the element being evaluated. The design for upward *loads* caused by expansive soils shall comply with Section 1808.6.

SECTION 1611 RAIN LOADS

1611.1 Design rain loads. Each portion of a roof shall be designed to sustain the *load* of rainwater as per the requirements of Chapter 8 of ASCE 7. The design rainfall shall be based on the 100-year 15-minute duration event, or on other rainfall rates determined from approved local weather data. Alternatively, a design rainfall of twice the 100-year hourly rainfall rate indicated in Figures 1611.1(1) through 1611.1(5) shall be permitted.

 $R = 5.2(d_s + d_h)$

For SI: $R = 0.0098(d_s + d_b)$

where:

- d_h = Additional depth of water on the undeflected roof above the inlet of secondary drainage system at its design flow (in other words, the hydraulic head), in inches (mm).
- d_s = Depth of water on the undeflected roof up to the inlet of secondary drainage system when the primary drainage system is blocked (in other words, the static head), in inches (mm).
- R = Rain load on the undeflected roof, in psf (kN/m²). Where the phrase "undeflected roof" is used, deflections from*loads*(including*dead loads*) shall not be considered when determining the amount of rain on the roof.

(Equation 16-19)



For SI: 1 inch = 25.4 mm. Source: National Weather Service, National Oceanic and Atmospheric Administration, Washington, DC.

FIGURE 1611.1(1) 100-YEAR, 1-HOUR RAINFALL (INCHES) WESTERN UNITED STATES



For SI: 1 inch = 25.4 mm. Source: National Weather Service, National Oceanic and Atmospheric Administration, Washington, DC.

FIGURE 1611.1(2) 100-YEAR, 1-HOUR RAINFALL (INCHES) CENTRAL UNITED STATES



For SI: 1 inch = 25.4 mm. Source: National Weather Service, National Oceanic and Atmospheric Administration, Washington, DC.

FIGURE 1611.1(3) 100-YEAR, 1-HOUR RAINFALL (INCHES) EASTERN UNITED STATES



For SI:1 inch = 25.4 mm. Source: National Weather Service, National Oceanic and Atmospheric Administration, Washington, DC.

FIGURE 1611.1(4) 100-YEAR, 1-HOUR RAINFALL (INCHES) ALASKA



For SI:1 inch = 25.4 mm. Source: National Weather Service, National Oceanic and Atmospheric Administration, Washington, DC.

FIGURE 1611.1(5) 100-YEAR, 1-HOUR RAINFALL (INCHES) HAWAII

1611.2 Ponding instability. *Susceptible bays* of roofs shall be evaluated for ponding instability in accordance with Chapters 7 and 8 of ASCE 7.

1611.3 Controlled drainage. Roofs equipped with hardware to control the rate of drainage shall be equipped with a secondary drainage system at a higher elevation that limits accumulation of water on the roof above that elevation. Such roofs shall be designed to sustain the *load* of rainwater that will accumulate on them to the elevation of the secondary drainage system plus the uniform *load* caused by water that rises above the inlet of the secondary drainage system at its design flow determined from Section 1611.1. Such roofs shall be checked for ponding instability in accordance with Section 1611.2.

SECTION 1612 FLOOD LOADS

1612.1 General. Within *flood hazard areas* as established in Section 1612.3, all new construction of buildings, structures and portions of buildings and structures, including *substantial improvement* and restoration of *substantial damage* to buildings and structures, shall be designed and constructed to resist the effects of flood hazards and *flood loads*. For buildings that are located in more than one *flood hazard area*, the provisions associated with the most restrictive *flood hazard area* shall apply.

1612.2 Design and construction. The design and construction of buildings and structures located in *flood hazard areas*, including *coastal high hazard areas* and *coastal A zones*, shall be in accordance with Chapter 5 of ASCE 7 and ASCE 24.

[S] 1612.3 Establishment of flood hazard areas. ((To establish *flood hazard areas*, the applicable governing authority shall adopt a flood hazard map and supporting data. The flood hazard map shall include, at a minimum, areas of special flood hazard as identified by the Federal Emergency Management Agency in an engineering report entitled "The *Flood Insurance Study* for **[INSERT NAME OF JURISDICTION]**," dated **[INSERT DATE OF ISSUANCE]**, as amended or revised with the accompanying *Flood Insurance Rate Map* (FIRM) and Flood Boundary and *Floodway* Map (FBFM) and related supporting data along with any revisions thereto.)) The ((adopted)) flood hazard maps and supporting data <u>adopted in Seattle Municipal Code Chapter 25 and areas mapped by Seattle Public Utilities</u> are hereby adopted by reference and declared to be part of this section.

1612.3.1 Design flood elevations. Where *design flood elevations* are not included in the *flood hazard areas* established in Section 1612.3, or where *floodways* are not designated, the *building official* is authorized to require the applicant to do one of the following:

- 1. Obtain and reasonably utilize any *design flood elevation* and *floodway* data available from a federal, state or other source.
- 2. Determine the *design flood elevation* or *floodway* in accordance with accepted hydrologic and hydraulic engineering practices used to define special *flood hazard areas*. Determinations shall be undertaken by a *registered design professional* who shall document that the technical methods used reflect currently accepted engineering practice.

1612.3.2 Determination of impacts. In riverine *flood hazard areas* where *design flood elevations* are specified but *floodways* have not been designated, the applicant shall provide a *floodway* analysis that demonstrates that the proposed work will not increase the *design flood elevation* more than 1 foot (305 mm) at any point within the jurisdiction of the applicable governing authority.

[S] 1612.4 Flood hazard documentation. The following documentation shall be prepared and sealed by a *registered design* professional and submitted to the *building official*:

- 1. For construction in *flood hazard areas* other than *coastal high hazard areas* or *coastal A zones*:
 - 1.1. The elevation of the *lowest floor*, including the basement, as required by the lowest floor elevation inspection in Section ((110.3.12.1)) <u>108.9.4</u> and for the final inspection in Section ((110.3.12.1)) <u>108.9.9.1</u>.
 - 1.2. For fully enclosed areas below the *design flood elevation* where provisions to allow for the automatic entry and exit of floodwaters do not meet the minimum requirements in Section 2.7.2.1 of ASCE 24, *construction documents* shall include a statement that the design will provide for equalization of hydrostatic flood forces in accordance with Section 2.7.2.2 of ASCE 24.
 - 1.3. For *dry floodproofed* nonresidential buildings, *construction documents* shall include a statement that the *dry floodproofing* is designed in accordance with ASCE 24 and shall include the flood emergency plan specified in Chapter 6 of ASCE 24.
- 2. For construction in *coastal high hazard areas* and *coastal A zones*:
 - 2.1. The elevation of the bottom of the lowest horizontal structural member as required by the *lowest floor* elevation inspection in Section ((110.3.3)) <u>108.9.4</u> and for the final inspection in Section ((110.3.12.1)) <u>108.9.9.1</u>.
 - 2.2. *Construction documents* shall include a statement that the building is designed in accordance with ASCE 24, including that the pile or column foundation and building or structure to be attached thereto is designed to be anchored to resist flotation, collapse and lateral movement due to the effects of wind and *flood loads* acting simultaneously on all building components, and other *load* requirements of Chapter 16.
 - 2.3. For breakaway walls designed to have a resistance of more than 20 psf (0.96 kN/m²) determined using *allowable stress design, construction documents* shall include a statement that the breakaway wall is designed in accordance with ASCE 24.
 - 2.4 For breakaway walls where provisions to allow for the automatic entry and exit of floodwaters do not meet the minimum requirements in Section 2.7.2.1 of ASCE 24, construction documents shall include a statement that the design will provide for equalization of hydrostatic flood forces in accordance with Section 2.7.2.2 of ASCE 24.

SECTION 1613 EARTHQUAKE LOADS

[S] 1613.1 Scope. Every structure, and portion thereof, including nonstructural components that are permanently attached to structures and their supports and attachments, shall be designed and constructed to resist the effects of earthquake motions in accordance with Chapters 11, 12, 13, 15, 17 and 18 of ASCE 7 as amended by Section 1613.4, as applicable. The *seismic design category* for a structure is permitted to be determined in accordance with Section 1613 or ASCE 7.

Exceptions:

- 1. Detached one- and two-family dwellings, assigned to *Seismic Design Category* A, B or C, or located where the mapped short-period spectral response acceleration, S_s , is less than 0.4 g.
- 2. The *seismic force-resisting system* of wood-frame buildings that conform to the provisions of Section 2308 are not required to be analyzed as specified in this section.
- 3. Agricultural storage structures intended only for incidental human occupancy.
- 4. Structures that require special consideration of their response characteristics and environment that are not addressed by this code or ASCE 7 and for which other regulations provide seismic criteria, such as vehicular bridges, electrical transmission towers, hydraulic structures, buried utility lines and their appurtenances and nuclear reactors.
- 5. References within ASCE 7 to Chapter 14 shall not apply, except as specifically required herein.

1613.1.1 Presubmittal conference. At least 60 days prior to submittal of a building permit application that contains the construction documents for any structural component of the building, the applicant shall arrange a presubmittal conference with the structural engineer of record and the *building official* to review the proposed building structural system when an alternate procedure is used under the provisions in Section 104.4 or 104.5. The purpose of the meeting is to obtain conceptual approval from the *building official* of the proposed structural system.

Note: Projects using non-linear response history analysis methods or using an alternative lateral force resisting system are subject to peer review in accordance with Section 1613.4.2, and ASCE 7 Sections 12.2.1.1 and 16.1.1. Peer reviews require lengthy lead time prior to permit application and issuance. Applicants should contact the building official prior to the start of structural design.

1613.2 Seismic ground motion values. Seismic ground motion values shall be determined in accordance with this section.

1613.2.1 Mapped acceleration parameters. The parameters S_s and S_1 shall be determined from the 0.2 and 1-second spectral response accelerations shown on Figures 1613.2.1(1) through 1613.2.1(10). Where S_1 is less than or equal to 0.04 and S_s is less than or equal to 0.15, the structure is permitted to be assigned *Seismic Design Category* A.



FIGURE 1613.2.1(1)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR THE CONTERMINOUS UNITED STATES OF 0.2-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(2) RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR THE CONTERMINOUS UNITED STATES OF 0.2-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(3)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR THE CONTERMINOUS UNITED STATES OF 1-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)





----- 200 ----------- 175 -----

90 -----

— 70 — - 60 ----

_____40 _____ — 35 ——

- 30 ------- 25 ----

_____ 10 ____

80 ------



0.2 Second Spectral Response Acceleration (5% of Critical Damping)





1.0 Second Spectral Response Acceleration (5% of Critical Damping)

DISCUSSION

Maps prepared by United States Geological Survey (USGS) in collaboration with the Federal Emergency Management Agency (FEMA)-funded Building Seismic Safety Council (BSSC) and the American Society of Civil Engineers (ASCE). The basis is explained in commentaries prepared by BSSC and ASCE and in the references. Ground motion values contoured on these maps incorporate:

- Ground motion values contoured on these maps incorporate: a target risk of structural collapse equal to 1% in 50 years based upon a generic structural fragility deterministic upper limits imposed near large, active faults, which are taken as 1.8 times the estimated median response to the characteristic earthquake for the fault (1.8 is used to represent the 84th percentile response), but not less than 150% and 60% g for 0.2 and 1.0 scc, respectively. As such, the values are different from those on the uniform-hazard 1998 USGS National Seismic Hazard Maps for Hawaii posited at http://earthquake.usgs.gov/hazmaps. Larger, more detailed versions of these maps are not provided because it is recommended that the corresponding USGS web tool (http://earthquake.usgs.ov/desigmaps or tool (http://earthquake.usgs.gov/designmaps or http://content.scinstitute.org) be used to determine the mapped
- value for a specified location

REFERENCES

P-750/2009 Edition, Federal Emergency Management Agency, Washington, DC. Huang, Yin-Nan, Whitaker, A.S., and Luco, Nicolas, 2008, Maximum spectral demands in the near-fault region, Earthquake Spectra, Volume 24, Issue 1, pp. 319-341.Klein, F., Frankel, A.D., Mueller, C.S., Wesson, R.L., and Okubo, P., 2001, Seismic hazard in Hawaii: high rate of large earthquakes and probabilistic ground-motion maps, Bulletin of the Seismological Society of America, Volume 91, pp. 479-498.Luco, Nicolas, Ellingwood, B.R., Hamburger, R.O., Hooper, J.D., Kimball, J.X., and Kircher, C.A., 2007, Risk-Targeted versus Current Seismic Design Maps for the Conteminous United States, Structural Engineers Association of California 2007 Convention Proceedings, pp. 163-175.

- Building Seismic Safety Council, 2009, NEHRP Recommended Seismic Provisions for New Buildings and Other Structures: FEMA P-750/2009 Edition, Federal Emergency Management Agency,

Deterministic zone boundary. The ground motion inside the zone shall be taken as the number shown inside the zone

Areas with a constant spectral response acceleration of 150% g



321

---- 10 ----Contours of spectral response acceleration expressed as a percent of gravity. Hachures point in direction of decreasing values



Areas with a constant spectral response acceleration of 60% g



Deterministic zone boundary. The ground motion inside the zone shall be taken as the number shown inside the zone.

_____10 ____

----- 10 -----Contours of spectral response acceleration expressed as a percent of gravity. Hachures point in direction of decreasing values

FIGURE 1613.2.1(5)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR HAWAII OF 0.2- AND 1-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(6)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR ALASKA OF 0.2-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(7)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR ALASKA OF 1.0-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



1.0 Second Spectral Response Acceleration (5% of Critical Damping)



FIGURE 1613.2.1(8)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR PUERTO RICO AND THE UNITED STATES VIRGIN ISLANDS OF 0.2- AND 1-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(9)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_{R}) GROUND MOTION RESPONSE ACCELERATIONS FOR GUAM AND THE NORTHERN MARIANA ISLANDS OF 0.2- AND 1-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING)



FIGURE 1613.2.1(10)

RISK-TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE_R) GROUND MOTION RESPONSE ACCELERATIONS FOR AMERICAN SAMOA OF 0.2- AND 1-SECOND SPECTRAL RESPONSE ACCELERATION (5% OF CRITICAL DAMPING) **1613.2.2** Site class definitions. Based on the site soil properties, the site shall be classified as *Site Class A*, B, C, D, E or F in accordance with Chapter 20 of ASCE 7.

Where the soil properties are not known in sufficient detail to determine the site class, *Site Class* D, subjected to the requirements of Section 1613.2.3, shall be used unless the *building official* or geotechnical data determines that *Site Class* E or F soils are present at the site.

Where site investigations that are performed in accordance with Chapter 20 of ASCE 7 reveal rock conditions consistent with *Site Class* B, but site-specific velocity measurements are not made, the *site coefficients* F_a and F_v shall be taken at unity (1.0).

1613.2.3 Site coefficients and adjusted maximum considered earthquake spectral response acceleration parameters. The maximum considered earthquake spectral response acceleration for short periods, S_{MS} , and at 1-second period, S_{MI} , adjusted for site class effects shall be determined by Equations 16-20 and 16-21, respectively:

$$S_{MS} = F_a S_S$$
 (Equation 16-20)

$$S_{MI} = F_{v}S_{1}$$

(Equation 16-21)

but S_{MS} shall not be taken less than S_{MI} except when determining the seismic design category in accordance with Section 1613.2.5.

where:

 F_a = Site coefficient defined in Table 1613.2.3(1).

 F_v = Site coefficient defined in Table 1613.2.3(2).

 S_s = The mapped spectral accelerations for short periods as determined in Section 1613.2.1.

 S_1 = The mapped spectral accelerations for a 1-second period as determined in Section 1613.2.1.

Where Site Class D is selected as the default site class per Section 1613.2.2, the value of F_a shall be not less than 1.2. Where the simplified design procedure of ASCE 7 Section 12.14 is used, the value of F_a shall be determined in accordance with ASCE 7 Section 12.14.8.1, and the values of F_v , S_{MS} and S_{MI} need not be determined.

		VALUES	6 OF SITE COEFFIC	SIENT F ^a		
SITE CLASS	MAPPED RISK TARGETED MAXIMUM CONSIDERED EARTHQUAKE (MCE _R) SPECTRAL RESPONSE ACCELERATION PARAMETER AT SHORT PERIOD					
	S _s ≤ 0.25	S _s = 0.50	S _s = 0.75	S _s = 1.00	S _s = 1.25	S _s ≥1.5
А	0.8	0.8	0.8	0.8	0.8	0.8
В	0.9	0.9	0.9	0.9	0.9	0.9
С	1.3	1.3	1.2	1.2	1.2	1.2
D	1.6	1.4	1.2	1.1	1.0	1.0
Е	2.4	1.7	1.3	Note b	Note b	Note b
F	Note b	Note b	Note b	Note b	Note b	Note b

TABLE 1613.2.3(1) ALUES OF SITE COEFFICIENT F_a*

a. Use straight-line interpolation for intermediate values of mapped spectral response acceleration at short period, S,.

b. Values shall be determined in accordance with Section 11.4.8 of ASCE 7.

TABLE 1613.2.3(2) VALUES OF SITE COEFFICIENT F_v^a

SITE CLASS		MAPPED RISK SPECTRAL RESE	TARGETED MAXIMUN PONSE ACCELERATIO	I CONSIDERED EART	HQUAKE (MCE _R) -SECOND PERIOD	
	S ₁ ≤ 0.1	S ₁ = 0.2	S ₁ = 0.3	S ₁ = 0.4	S ₁ = 0.5	S ₁ ≥ 0.6
А	0.8	0.8	0.8	0.8	0.8	0.8
В	0.8	0.8	0.8	0.8	0.8	0.8
С	1.5	1.5	1.5	1.5	1.5	1.4
D	2.4	2.2 ^c	2.0 ^c	1.9 ^c	1.8 ^c	1.7°
Е	4.2	3.3°	2.8 ^c	2.4 ^c	2.2 ^c	2.0 ^c
F	Note b	Note b	Note b	Note b	Note b	Note b

a. Use straight-line interpolation for intermediate values of mapped spectral response acceleration at 1-second period, S₁.

b. Values shall be determined in accordance with Section 11.4.8 of ASCE 7.

c. See requirements for site-specific ground motions in Section 11.4.8 of ASCE 7.

1613.2.4 Design spectral response acceleration parameters. Five-percent damped design spectral response acceleration at short periods, S_{DS} , and at 1-second period, S_{DI} , shall be determined from Equations 16-22 and Equation 16-23, respectively:

$$S_{DS} = \frac{2}{3}S_{MS}$$
 (Equation 16-22)

$$S_{DI} = \frac{2}{3}S_{MI}$$
 (Equation 16-23)

where:

 S_{MS} = The maximum considered earthquake spectral response accelerations for short period as determined in Section 1613.2.3.

 S_{MI} = The maximum considered earthquake spectral response accelerations for 1-second period as determined in Section 1613.2.3.

1613.2.5 Determination of seismic design category. Structures classified as *Risk Category* I, II or III that are located where the mapped spectral response acceleration parameter at 1-second period, S_1 , is greater than or equal to 0.75 shall be assigned to *Seismic Design Category* E. Structures classified as *Risk Category* IV that are located where the mapped spectral response acceleration parameter at 1-second period, S_1 , is greater than or equal to 0.75 shall be assigned to *Seismic Design Category* E. Structures classified as *Risk Category* IV that are located where the mapped spectral response acceleration parameter at 1-second period, S_1 , is greater than or equal to 0.75 shall be assigned to *Seismic Design Category* F. Other structures shall be assigned to a *seismic design category* based on their *risk category* and the design spectral response acceleration parameters, S_{DS} and S_{DI} , determined in accordance with Section 1613.2.4 or the site-specific procedures of ASCE 7. Each building and structure shall be assigned to the more severe *seismic design category* in accordance with Table 1613.2.5(1) or 1613.2.5(2), irrespective of the fundamental period of vibration of the structure, *T*.

	RISK CATEGORY					
	l or ll	III	IV			
<i>S</i> _{<i>DS</i>} < 0.167g	А	А	А			
$0.167g \le S_{DS} < 0.33g$	В	В	С			
$0.33g \le S_{DS} < 0.50g$	С	С	D			
$0.50g \le S_{DS}$	D	D	D			

TABLE 1613.2.5(1) SEISMIC DESIGN CATEGORY BASED ON SHORT-PERIOD (0.2 second) RESPONSE ACCELERATION

TABLE 1613.2.5(2)

SEISMIC DESIGN CATEGORY BASED ON 1-SECOND PERIOD RESPONSE ACCELERATION

VALUE OF S	RISK CATEGORY				
	l or ll	111	IV		
<i>S_{DI}</i> < 0.067g	А	А	А		
$0.067g \le S_{DI} < 0.133g$	В	В	С		
$0.133g \le S_{DI} < 0.20g$	С	С	D		
$0.20g \le S_{DI}$	D	D	D		

1613.2.5.1 Alternative seismic design category determination. Where S_1 is less than 0.75, the *seismic design category* is permitted to be determined from Table 1613.2.5(1) alone where all of the following apply:

- 1. In each of the two *orthogonal* directions, the approximate fundamental period of the structure, T_a , in each of the two *orthogonal* directions determined in accordance with Section 12.8.2.1 of ASCE 7, is less than 0.8 T_s determined in accordance with Section 11.8.6 of ASCE 7.
- 2. In each of the two *orthogonal* directions, the fundamental period of the structure used to calculate the *story* drift is less than T_s .
- 3. Equation 12.8-2 of ASCE 7 is used to determine the seismic response coefficient, C_s .
- 4. The *diaphragms* are rigid or are permitted to be idealized as rigid in accordance with Section 12.3.1 of ASCE 7 or, for *diaphragms* permitted to be idealized as flexible in accordance with Section 12.3.1 of ASCE 7, the distances between vertical elements of the *seismic force-resisting system* do not exceed 40 feet (12 192 mm).

1613.2.5.2 Simplified design procedure. Where the alternate simplified design procedure of ASCE 7 is used, the *seis-mic design category* shall be determined in accordance with ASCE 7.

1613.3 Ballasted photovoltaic panel systems. Ballasted, roof-mounted *photovoltaic panel systems* need not be rigidly attached to the roof or supporting structure. Ballasted non-penetrating systems shall be designed and installed only on roofs

with slopes not more than one unit vertical in 12 units horizontal. Ballasted nonpenetrating systems shall be designed to resist sliding and uplift resulting from lateral and vertical forces as required by Section 1605, using a coefficient of friction determined by acceptable engineering principles. In structures assigned to *Seismic Design Category* C, D, E or F, ballasted nonpenetrating systems shall be designed to accommodate seismic displacement determined by nonlinear response-history or other *approved* analysis or shake-table testing, using input motions consistent with ASCE 7 lateral and vertical seismic forces for nonstructural components on roofs.

[W] 1613.4 Amendments to ASCE 7. The provisions of Section 1613.4 shall be permitted as an amendment to the relevant provisions of ASCE 7. The text of ASCE 7 shall be amended as indicated in Sections 1613.4.1 through 1613.4.2.

1613.4.1. Modify ASCE 7 Section 12.2.5.4 to read as follows:

12.2.5.4 Increased Structural Height Limit for Steel Eccentrically Braced Frames, Steel Special Concentrically Braced Frames, Steel Buckling-Restrained Braced Frames, Steel Special Plate Shear Walls, and Special Reinforced Concrete Shear Walls. The limits on height, $h_{\underline{n}}$, in Table 12.2-1 are permitted to be increased from 160 ft (50 m) to 240 ft (75 m) for structures assigned to Seismic Design Categories D or E and from 100 ft (30 m) to 160 ft (50 m) for structures assigned to Seismic Design Category F, if all of the following are satisfied:

- 1. The structure shall not have an extreme torsional irregularity as defined in Table 12.3-1 (horizontal structural irregularity Type 1b).
- 2. The steel eccentrically braced frames, steel special concentrically braced frames, steel buckling-restrained braced frames, steel special plate shear walls or special reinforced concrete shear walls in any one plane shall resist no more than 60 percent of the total seismic forces in each direction, neglecting accidental torsional effects.
- 3. Where floor and roof diaphragms transfer forces from the vertical seismic force-resisting elements above the diaphragm to other vertical force-resisting elements below the diaphragm, these in plane transfer forces shall be amplified by the overstrength factor, Ω_o , for the design of the diaphragm flexure, shear, and collectors.
- <u>4.</u> The earthquake force demands in foundation mat slabs, grade beams, and pile caps supporting braced frames and/or walls arranged to form a shear-resisting core shall be amplified by 2 for shear and 1.5 for flexure. The redundancy factor, ρ , applies and shall be the same as that used for the structure in accordance with Section 12.3.4.

1613.4.2 ASCE 7 Section 12.6. Amend ASCE 7 Section 12.6 and Table 12.6-1 to read as follows:

12.6 ANALYSIS PROCEDURE SELECTION

12.6.1 Analysis procedure. The structural analysis required by Chapter 12 shall consist of one of the types permitted in Table 12.6-1, based on the structure's seismic design category, structural system, dynamic properties, and regularity, or with the approval of the authority having jurisdiction, an alternative generally accepted procedure is permitted to be used. The analysis procedure selected shall be completed in accordance with the requirements of the corresponding section referenced in Table 12.6-1.

·		_	—	-
		_	_	_
		_	—	-
		_	_	_
		_	_	_
		_	_	_
		· · · · · · · · · · · · · · · · · · ·	_	_
		·	·	_
a				

<u>Note:</u> Building designs using non-linear response history procedures must undergo an independent structural review (peer review) in accordance with ASCE 7 Section 16.1.1.

[W] 1613.4.3 ASCE 7 Section 11.2. Amend ASCE 7 Section 11.2 to include the following definition:

<u>USGS SEISMIC DESIGN GEODATABASE:</u> A US Geological Survey (USGS) database of geocoded values of seismic design parameters and geocoded sets of multi-period 5%-damped risk-targeted maximum considered earthquake (MCE_R) response spectra. The parameters obtained from this database may only be used where referenced by Section 11.4.8.1.

Note: The USGS Seismic Design Geodatabase is intended to be accessed through a USGS Seismic Design Web Service that allows the user to specify the site location, by latitude and longitude, and the site class to obtain the seismic design data. The USGS web service spatially interpolates between the gridded data of the USGS *geodatabase*. Both the USGS *geodatabase* and the USGS web service can be accessed at https://doi.org/10.5066/F7NK3C76. The USGS Seismic Design Geodatabase is available at the ASCE 7 Hazard Tool https://asce7hazardtool.online/ or an approved equivalent.

[W] 1613.4.4 ASCE 7 Section 11.4.8. Amend ASCE 7 Section 11.4.8 to include the following section:

11.4.8.1 Multi-Period Design Response Spectrum. As an alternative to the ground motion hazard analysis requirements of Section 11.4.8, and suitable for all structures other than those designated Site Class F (unless exempted in accordance with Section 20.3.1), a multi-period design response spectrum may be developed as follows:

- 1. For exclusive use with the USGS Seismic Design Geodatabase in accordance with this section, the Site Class shall be determined per Section 20.6.
- 2. Where a multi-period design response spectrum is developed in accordance with this section, the parameters S_{MS^2} S_{MI} , S_{DS^2} , S_{DI} , and T_L as obtained by the USGS Seismic Design Geodatabase shall be used for all applications of these parameters in this standard.
- 3. The S_s and S_l parameters obtained by the USGS Seismic Design Geodatabase are only permitted to be used in development of the multi-period design response spectrum and are not permitted to be used in other applications in this standard. The mapped parameters S_s and S_l as determined by Section 11.4.2 and peak ground acceleration parameter PGA_M as determined by Section 11.8.3 shall be used for all other applications in this standard.
- 4. At discrete values of period, *T*, equal to 0.0 s, 0.01 s, 0.02 s, 0.03 s, 0.05 s, 0.075 s, 0.1 s, 0.15 s, 0.2 s, 0.25 s, 0.3 s, 0.4 s, 0.5 s, 0.75 s, 1.0 s, 1.5 s, 2.0 s, 3.0 s, 4.0 s, 5.0 s, 7.5 s, and 10.0 s, the 5%-damped design spectral response acceleration parameter, S_a, shall be taken as 2/3 of the multi-period 5%-damped MCER response spectrum from the USGS Seismic Design Geodatabase for the applicable site class.
- 5. At each response period, T, less than 10.0 s and not equal to one of the discrete values of period, T, listed in Item 4 above, S_{as} shall be determined by linear interpolation between values of S_{as} of Item 4 above.

- 6. At each response period, T, greater than 10.0 s, $S_{\underline{a}}$ shall be taken as the value of $S_{\underline{a}}$ at the period of 10.0 s, factored by 10/T, where the value of T is less than or equal to that of the long-period transition period, $T_{\underline{l}}$, and shall be taken as the value of $S_{\underline{a}}$ at the period of 10.0 s factored by $10T_{\underline{l}}/T^2$, where the value of T is greater than that of the long-period transition period, $T_{\underline{l}}$.
- <u>7.</u> Where an $MCE_{\mathbb{R}}$ response spectrum is required, it shall be determined by multiplying the multi-period design response spectrum by 1.5.
- 8. For use with the equivalent lateral force procedure, the spectral acceleration $S_{\underline{a}}$ at *T* shall be permitted to replace S_{DI}/T in Equation (12.8-3) and $S_{DI}/T_I/T^2$ in Equation (12.8-4).

[W] 1613.4.5 ASCE 7 Section 20.6. Amend ASCE 7 Chapter 20 to include the following section:

Section 20.6 Site Classification Procedure For Use With Section 11.4.8.1. For exclusive use in determining the Multi-Period Design Response Spectrum and associated spectral parameters in accordance with Section 11.4.8.1, the Site Class shall be determined in accordance with this section. For all other applications in this standard the Site Class shall be determined per Section 20.1.

[W] 20.6.1 Site Classification

The site soil shall be classified in accordance with Table 20.6-1 and Section 20.6.2 based on the average shear wave velocity parameter, v_{s_s} which is derived from the measured shear wave velocity profile from the ground surface to a depth of 100 ft (30 m). Where shear wave velocity is not measured, appropriate generalized correlations between shear wave velocity and standard penetration test (SPT) blow counts, cone penetration test (CPT) tip resistance, shear strength, or other geotechnical parameters shall be used to obtain an estimated shear wave velocity profile, as described in Section 20.6.3. Where site-specific data (measured shear wave velocities or other geotechnical data that can be used to estimate shear wave velocity) are available only to a maximum depth less than 100 ft (30 m), v_{s_s} , shall be estimated as described in Section 20.6.3.

Where the soil properties are not known in sufficient detail to determine the site class, the most critical site conditions of Site Class C, Site Class CD and Site Class D, as defined in Section 20.6.2, shall be used unless the Authority Having Jurisdiction or geotechnical data determine that Site Class DE, E or F soils are present at the site. Site Classes A and B shall not be assigned to a site if there is more than 10 ft (3.1 m) of soil between the rock surface and the bottom of the spread footing or mat foundation.

[W] 20.6.2 Site Class Definitions. Site Class types shall be assigned in accordance with the definitions provided in Table 20.6.2-1 and this section.

20.6.2.1 Soft Clay Site Class E. Where a site does not qualify under the criteria for Site Class F per Section 20.3.1 and there is a total thickness of soft clay greater than 10 ft (3 m), where a soft clay layer is defined by $s_{\underline{u}} < 500 \text{ psf}(s_{\underline{u}} < 25 \text{ kPa})$, $w \ge 40\%$, and PI > 20, it shall be classified as Site Class E. This classification is made regardless of $v_{\underline{s}}$, as computed in Section 20.4.

20.6.2.2 Site Classes C, CD, D, DE and E. The assignment of Site Class C, CD, D, DE, and E soils shall be made based on the average shear wave velocity, which is derived from the site shear wave velocity profile from the ground surface to a depth of 100 ft (30 m), as described in Section 20.4.

20.6.2.3 Site Classes B and BC (Medium Hard and Soft Rock). Site Class B can only be assigned to a site on the basis of shear wave velocity measured on site. If shear wave velocity data are not available and the site condition is estimated by a geotechnical engineer, engineering geologist, or seismologist as Site Class B or BC on the basis of site geology, consisting of competent rock with moderate fracturing and weathering, the site shall be classified as Site Class BC. Softer and more highly fractured and weathered rock shall either be measured on site for shear wave velocity or classified as Site Class C.

20.6.2.4 Site Class A (Hard Rock). The hard rock, Site Class A, category shall be supported by shear wave velocity measurement, either on site or on profiles of the same rock type in the same formation with an equal or greater degree of weathering and fracturing. Where hard rock conditions are known to be continuous to a depth of 100 ft (30 m), surficial shear wave velocity measurements to maximum depths less than 100 ft are permitted to be extrapolated to assess v.

Site Class	v <u>_Calculated Using Measured or Estimated</u> Shear Wave Velocity Profile (ft/s)
<u>A. Hard Rock</u>	\geq 5,000
B. Medium Hard Rock	<u>> 3,000 to 5,000</u>
BC. Soft Rock	<u>> 2,100 to 3,000</u>
C. Very Dense Sand or Hard Clay	> 1,450 to 2,100

TABLE 20.6.2-1 SITE CLASSIFICATION

[W] 20.6.3 Estimation of Shear Wave Velocity Profiles. Where measured shear wave velocity data are not available, shear wave velocity shall be estimated as a function of depth using correlations with suitable geotechnical parameters, including standard penetration test (SPT) blow counts, shear strength, overburden pressure, void ratio, or cone penetration test (CPT) tip resistance, measured at the site.

Site Class based on estimated values of v_s shall be derived using v_s , $v_s/1.3$, and $1.3v_s$ when correlation models are used to derive shear wave velocities. Where correlations derived for specific local regions can be demonstrated to have greater accuracy, factors less than 1.3 can be used if approved by the Authority Having Jurisdiction. If the different average velocities result in different Site Classes per Table 20.6.2-1, the most critical of the site classes for ground motion analysis at each period shall be used.

Where the available data used to establish the shear wave velocity profile extends to depths less than 100 ft (30 m) but more than 50 ft (15 m), and the site geology is such that soft layers are unlikely to be encountered between 50 and 100 ft, the shear wave velocity of the last layer in the profile shall be extended to 100 ft for the calculation of v_s in Equation (20.4-1). Where the data does not extend to depths of 50 ft (15 m), default site classes, as described in Section 20.6.1, shall be used unless another site class can be justified on the basis of the site geology.

[W] 1613.4.6 ASCE 7 Section 21.3.1. Amend ASCE 7 Section 21.3 to include the following section:

Section 21.3.1 Alternate Minimum Design Spectral Response Accelerations. As an alternate approach to Section 21.3, the lower limit of $S_{\underline{a}}$ is permitted to be determined according to this section. The design spectral response acceleration at any period shall not be taken less than 80% of the Multi-Period Design Response Spectrum as determined by Section 11.4.8.1.

For sites classified as Site Class F requiring site-specific analysis in accordance with Section 11.4.8, the design spectral response acceleration at any period shall not be less than 80% of S_{π} determined for Site Class E.

Exception: Where a different site class can be justified using the site-specific classification procedures in accordance with Section 20.6.2.2, a lower limit of 80% of S_{a} for the justified site class shall be permitted to be used.

SECTION 1614 ATMOSPHERIC ICE LOADS

1614.1 General. *Ice-sensitive structures* shall be designed for atmospheric ice *loads* in accordance with Chapter 10 of ASCE 7.

SECTION 1615 TSUNAMI LOADS

[W] 1615.1 General. The design and construction of *Risk Category* III and IV buildings and structures located in the *Tsunami Design Zones* defined in the *Tsunami Design Geodatabase* shall be in accordance with Chapter 6 of ASCE 7<u>-22</u>, except as modified by this code. <u>Wherever ASCE 7 is referenced herein, it shall refer to ASCE 7-22</u>, within the extent of ASCE 7 Chapter 6 and WAC 51-50-1615.

Note: The intent of the Washington state amendments to ASCE 7 Chapter 6 (Tsunami Loads and Effects) is to require use of the *Washington Tsunami Design Zone* maps to determine inundation limits, i.e., when a site is within a tsunami design zone. The Washington State Department of Natural Resources has parameters for tsunami inundation depth and flow velocity available for all of Washington's coastal waters and tidally influenced riverine systems (*WA-TDZ*). These parameters are required to be used in lieu of ASCE Tsunami Design Geodatabase, and as a basis for comparison in the probabilistic tsunami hazard analysis in this chapter.

[W] 1615.2 Modifications to ASCE 7. The text of Chapter 6 of ASCE 7 shall be modified as indicated in this section.

1615.2.1 ASCE 7 Section 6.1.1. Replace the third paragraph of ASCE 7 Section 6.1.1 with the following and remove the associated exception:

The Tsunami Design Zone shall be determined using the Washington Tsunami Design Zone maps (WA-TDZ). The WA-TDZ maps are available at https://www.dnr.wa.gov/wa-tdz.

1615.2.2 ASCE 7 Section 6.1.1. Add new fifth paragraph and user note to ASCE 7 Section 6.1.1 to read as follows:

Whenever a Tsunami Design Zone or Fig. 6.1-1 is referenced in ASCE 7 Chapter 6, the WA-TDZ maps shall be used.

1615.2.3 ASCE 7 Section 6.2. Modify ASCE 7 Section 6.2 definitions to read as follows:

ASCE TSUNAMI DESIGN GEODATABASE: Not Adopted.

Note: The ASCE tsunami design geodatabase is not adopted for design purposes in Washington State.

MAXIMUM CONSIDERED TSUNAMI: A probabilistic tsunami having a two percent probability of being exceeded in a 50-year period or a 2,475-year mean recurrence, or a deterministic assessment considering the maximum tsunami that can reasonably be expected to affect a site.

TSUNAMI DESIGN ZONE MAP: The Washington *Tsunami Design Zone maps (WA-TDZ)* designating the potential horizontal inundation limit of the *Maximum Considered Tsunami* found at www.dnr.wa.gov/wa-tdz.

1615.2.4 ASCE 7 Section 6.2. Add new definitions to ASCE 7 Section 6.2 to read as follows:

WASHINGTON TSUNAMI DESIGN ZONE MAP (WA-TDZ): The Washington department of natural resources maps of potential tsunami inundation limits for the Maximum Considered Tsunami, designated as follows:

<u>The Washington State Department of Natural Resources geodatabase of design parameters for tsunami inundation</u> <u>depth, flow velocity, offshore tsunami amplitude, predominant period, and *tsunami design zone maps* for a *maximum* <u>considered tsunami</u> is available at the Washington TDZ website (https://www.dnr.wa.gov/wa-tdz).</u>

1615.2.5 ASCE 7 Section 6.5.1. Add new second paragraph to ASCE 7 Section 6.5.1 to read as follows:

6.5.1 Tsunami Risk Category II and III buildings and other structures. The *Maximum Considered Tsunami* inundation depth and tsunami flow velocity characteristics at a Tsunami Risk Category II or III building or other structure shall be determined by the *WA-TDZ* maps. Those parameters shall be used as the *Maximum Considered Tsunami* inundation depth and tsunami flow velocity characteristics in lieu of the Energy Grade Line Analysis in Section 6.6.

1615.2.6 ASCE 7 Section 6.5.1.1. Modify the first paragraph of ASCE 7 Section 6.5.1.1 to read as follows:

6.5.1.1 Runup evaluation for areas where no map values are given. For Tsunami Risk Category II and III buildings and other structures where no mapped inundation limit is shown in the *Tsunami Design Zone map*, the ratio of tsunami runup elevation above Mean High Water Level to Offshore Tsunami Amplitude, R/HT, shall be permitted to be determined using the surf similarity parameter ξ 100, according to Eqs. (6.5-2a, b, c, d, or e) and Fig. 6.5-1.

1615.2.7 ASCE 7 Section 6.5.2. Modify the paragraph and the exception, to read as follows:

6.5.2 Tsunami Risk Category IV buildings and other structures. A site-specific Probabilistic Tsunami Hazard Analysis (PTHA) shall be performed for Tsunami Risk Category IV buildings and other structures. Site-specific velocities determined by site-specific PTHA determined to be less than the design flow velocities determined from the *WA-TDZ* maps shall be subject to the limitation in Section 6.7.6.8. Site-specific velocities determined to be greater than the *WA-TDZ* map velocities shall be used. EXCEPTION: For structures other than Tsunami Vertical Evacuation Refuge Structures, a site-specific Probabilistic Tsunami Hazard Analysis need not be performed where the inundation depth determined from the *WA-TDZ* maps is determined to be less than 12 ft (3.66 m) at any point within the location of the Tsunami Risk Category IV structure.

1615.2.8 ASCE 7 Section 6.6.1. Replace ASCE 7 Section 6.6.1 to read as follows:

6.6.1 Maximum inundation depth and flow velocities. The maximum inundation depths and flow velocities associated with the stages of tsunami flooding are determined by the *WA-TDZ* maps. Flow velocity for design purposes shall not be taken as less than 10 ft/s (3.0 m/s) and need not be taken as greater than the lesser of 1.5(ghmax) 1/2 and 50 ft/s (15.2 m/s).

1615.2.9 ASCE 7 Section 6.7. Replace ASCE 7 Section 6.7 with the following and add a user note:

When required by Section 6.5, the inundation depths and flow velocities shall be determined by site-specific inundation studies complying with the requirements of this section. Site-specific analyses shall use an integrated generation, propagation, and inundation model that replicates the given offshore tsunami waveform amplitude and period from the seismic sources given in Section 6.7.2.

1615.2.10 ASCE 7 Table 6.7-2. Modify ASCE 7 Table 6.7-2 to read as follows:

	-
·	_

1615.2.11 ASCE 7 Section 6.7.5.1. Modify ASCE 7 Section 6.7.5.1 Item 4, Item 5, and Item 6 to read as follows:

<u>6.7.5.1 Offshore tsunami amplitude for distant seismic sources.</u> Offshore tsunami amplitude shall be probabilistically determined in accordance with the following:

- 4. The extent of offshore tsunami amplitude points considered for the site shall include the following:
 - (a) For outer coast sites, the extent shall include points within at least 40 mi (64.4 km) but not exceeding 50 mi (80.5 km) of projected length along the coastline, centered on the site within a tolerance of plus or minus 6 mi (9.7 km);
 - (b) Reserved;
 - (c) For sites within bays or inland waterways (such as the Strait of Juan de Fuca), the designated center of the computed offshore tsunami amplitude points shall be taken offshore of the mouth of the bay or waterway centered in accordance with criteria (a) above;
 - (d) For island locations where the projected width of the island is less than 40 mi (64.4 km), it shall be permitted to consider the extent of offshore tsunami amplitude points corresponding to the projected width of the island. Shorter extents of offshore tsunami amplitude points shall be permitted for island locations, but shall not be less than 10 mi (16.1 km);
 - (e) In addition to the above, the tsunami source development and inundation modeling are subject to an independent peer review by a tsunami modeler approved by the Authority Having Jurisdiction, who shall present a written report to the Authority Having Jurisdiction as to the hazard consistency of the modeling with the requirements of Section 6.7.
- 5. The mean value of the computed offshore tsunami wave amplitudes shall be not less than 100 percent of the mean value for the coinciding offshore tsunami amplitude data given by the *WA-TDZ* maps.
- 6. The individual values of the computed offshore tsunami wave amplitude shall be not less than 80 percent of the coinciding offshore tsunami amplitude values given by the *WA-TDZ* maps.

1615.2.12 ASCE 7 Section 6.7.5.3. Modify ASCE 7 Section 6.7.5.3.1(b) and (c) to read as follows:

- (b) The mean value of the computed offshore tsunami amplitudes is at least 85 percent of the mean value for the coinciding offshore tsunami amplitude data of the *WA-TDZ* maps.
- (c) The values of the computed offshore tsunami wave amplitude are not less than 75 percent of the coinciding offshore tsunami amplitude values of the *WA-TDZ* maps.

1615.2.13 ASCE 7 Section 6.7.6.2. Modify ASCE 7 Section 6.7.6.2 and add a user note to read as follows:

6.7.6.2 Seismic subsidence before tsunami arrival. Where the seismic source is a local earthquake event, the *Maximum Considered Tsunami* inundation shall be determined for an overall elevation subsidence value directly computed for the seismic source mechanism.

1615.2.14 ASCE 7 Figure 6.7-3. Remove Figure 6.7-3 and the associated note.

Note: WA-TDZ maps include computed subsidence and uplift (where applicable) in the inundation results. See https://www.dnr.wa.gov/wa-tdz.

1615.2.15 ASCE 7 Section 6.8.9. Modify the first sentence of ASCE 7 Section 6.8.9 to read as follows:

6.8.9 Seismic effects on the foundations preceding *maximum considered tsunami*. Where designated in the *Tsunami Design Zone map* as a site subject to a tsunami from a local earthquake, the structure shall be designed for the preceding coseismic effects.

SECTION 1616 STRUCTURAL INTEGRITY

1616.1 General. *High-rise buildings* that are assigned to *Risk Category* III or IV shall comply with the requirements of Section 1616.2 if they are frame structures, or Section 1616.3 if they are *bearing wall structures*.

1616.2 Frame structures. Frame structures shall comply with the requirements of this section.

1616.2.1 Concrete frame structures. *Frame structures* constructed primarily of reinforced or prestressed concrete, either cast-in-place or precast, or a combination of these, shall conform to the requirements of Section 4.10 of ACI 318. Where ACI 318 requires that nonprestressed reinforcing or prestressing steel pass through the region bounded by the longitudinal column reinforcement, that reinforcing or prestressing steel shall have a minimum nominal tensile strength equal to two-thirds of the required one-way vertical strength of the connection of the floor or roof system to the column in each direction of beam or slab reinforcement passing through the column.

Exception: Where concrete slabs with continuous reinforcement having an area not less than 0.0015 times the concrete area in each of two *orthogonal* directions are present and are either monolithic with or equivalently bonded to beams, girders or columns, the longitudinal reinforcing or prestressing steel passing through the column reinforcement shall have a nominal tensile strength of one-third of the required one-way vertical strength of the connection of the floor or roof system to the column in each direction of beam or slab reinforcement passing through the column.

1616.2.2 Structural steel, open web steel joist or joist girder, or composite steel and concrete *frame structures*. *Frame structures* constructed with a structural steel frame or a frame composed of open web *steel joists*, joist girders with or without other *structural steel elements* or a frame composed of composite steel or composite *steel joists* and reinforced concrete elements shall conform to the requirements of this section.

1616.2.2.1 Columns. Each column splice shall have the minimum *design strength* in tension to transfer the design dead and *live load* tributary to the column between the splice and the splice or base immediately below.

1616.2.2.2 Beams. End connections of all beams and girders shall have a minimum nominal axial tensile strength equal to the required vertical shear strength for *allowable stress design* (ASD) or two-thirds of the required shear strength for *load and resistance factor* design (*LRFD*) but not less than 10 kips (45 kN). For the purpose of this section, the shear force and the axial tensile force need not be considered to act simultaneously.

Exception: Where beams, girders, open web joist and joist girders support a concrete slab or concrete slab on metal deck that is attached to the beam or girder with not less than 3/8-inch-diameter (9.5 mm) headed shear studs, at a spacing of not more than 12 inches (305 mm) on center, averaged over the length of the member, or other attachment having equivalent shear strength, and the slab contains continuous distributed reinforcement in each of two *orthogonal* directions with an area not less than 0.0015 times the concrete area, the nominal axial tension strength of the end connection shall be permitted to be taken as half the required vertical shear strength for ASD or one-third of the required shear strength for *LRFD*, but not less than 10 kips (45 kN).

1616.3 Bearing wall structures. *Bearing wall structures* shall have vertical ties in all *load-bearing walls* and longitudinal ties, transverse ties and perimeter ties at each floor level in accordance with this section and as shown in Figure 1616.3.



FIGURE 1616.3 LONGITUDINAL, PERIMETER, TRANSVERSE AND VERTICAL TIES

1616.3.1 Concrete wall structures. Precast *bearing wall structures* constructed solely of reinforced or prestressed concrete, or combinations of these shall conform to the requirements of Sections 16.2.4 and 16.2.5 of ACI 318.

1616.3.2 Other bearing wall structures. Ties in *bearing wall structures* other than those covered in Section 1616.3.1 shall conform to this section.

1616.3.2.1 Longitudinal ties. Longitudinal ties shall consist of continuous reinforcement in slabs; continuous or spliced decks or sheathing; continuous or spliced members framing to, within or across walls; or connections of continuous framing members to walls. Longitudinal ties shall extend across interior load-bearing walls and shall connect to exterior *load-bearing walls* and shall be spaced at not greater than 10 feet (3038 mm) on center. Ties shall have a minimum nominal tensile strength, T_{T} , given by Equation 16-24. For ASD the minimum nominal tensile strength shall be permitted to be taken as 1.5 times the allowable tensile stress times the area of the tie.

$$T_T = w LS \le \alpha_T S$$

(Equation 16-24)

where:

- L = The span of the horizontal element in the direction of the tie, between bearing walls, feet (m).
- w = The weight per unit area of the floor or roof in the span being tied to or across the wall, psf (N/m²).
- S = The spacing between ties, feet (m).
- α_T = A coefficient with a value of 1,500 pounds per foot (2.25 kN/m) for masonry *bearing wall structures* and a value of 375 pounds per foot (0.6 kN/m) for structures with bearing walls of cold-formed steel *light-frame construction*.

1616.3.2.2 Transverse ties. Transverse ties shall consist of continuous reinforcement in slabs; continuous or spliced decks or sheathing; continuous or spliced members framing to, within or across walls; or connections of continuous framing members to walls. Transverse ties shall be placed not farther apart than the spacing of *load-bearing walls*. Transverse ties shall have minimum nominal tensile strength T_T , given by Equation 16-24. For ASD the minimum nominal tensile strength as 1.5 times the allowable tensile stress times the area of the tie.

1616.3.2.3 Perimeter ties. Perimeter ties shall consist of continuous reinforcement in slabs; continuous or spliced decks or sheathing; continuous or spliced members framing to, within or across walls; or connections of continuous framing members to walls. Ties around the perimeter of each floor and roof shall be located within 4 feet (1219 mm) of the edge and shall provide a nominal strength in tension not less than T_p , given by Equation 16-25. For ASD the minimum nominal tensile strength shall be permitted to be taken as 1.5 times the allowable tensile stress times the area of the tie.

$$T_p = 200w \le \beta_T$$

For SI: $T_p = 90.7w \le \beta_T$

where:

- w = As defined in Section 1616.3.2.1.
- β_T = A coefficient with a value of 16,000 pounds (7200 kN) for structures with masonry bearing walls and a value of 4,000 pounds (1300 kN) for structures with bearing walls of cold-formed steel *light-frame construction*.

1616.3.2.4 Vertical ties. Vertical ties shall consist of continuous or spliced reinforcing, continuous or spliced members, wall sheathing or other engineered systems. Vertical tension ties shall be provided in bearing walls and shall be continuous over the height of the building. The minimum nominal tensile strength for vertical ties within a bearing wall shall be equal to the weight of the wall within that *story* plus the weight of the *diaphragm* tributary to the wall in the *story* below. Not fewer than two ties shall be provided for each wall. The strength of each tie need not exceed 3,000 pounds per foot (450 kN/m) of wall tributary to the tie for walls of masonry construction or 750 pounds per foot (140 kN/m) of wall tributary to the tie for walls of cold-formed steel *light-frame construction*.