

GENERAL PSE NOTES

1. Contact maprequest@pse.com for updated gas maps of area.
2. Maintain a minimum 1' vertical separation when crossing gas mains or services.
3. Maintain a minimum 3' horizontal separation when running parallel to gas mains or services.
4. If HP or > 4" Pipe is encountered, please contact PSE PI Inspector before working near HP or > 4" gas mains:

Downtown Seattle:

Glenn Huden | 206-396-4159 | glenn.huden@pse.com

South Seattle:

Troy Peterson | 206-396-0730 | troy.peterson@pse.com

North Seattle:

Mitch Balzer | 253-377-9539 | mitchell.balzer@pse.com

5. Coordinate with PSE Customer Construction Services at 1-888-321-7779 and a PSE project manager for relocation of gas mains and services as needed.
6. Locate and protect all gas facilities in the field.

