



Department of Commerce



EVERGREEN SUSTAINABLE DEVELOPMENT STANDARD VERSION 3.0.1

UPDATED 2/2018



PREFACE to 2/2018 UPDATE

This update of Version 3.0 of the Evergreen Sustainable Development Standard (ESDS) was developed in response to feedback and questions received subsequent to the release of v3.0. All point values have remained the same, as have the vast majority of requirements. Clarifying text has been added to several Criteria that have proven to need additional or alternate explanation, several spelling and grammatical errors have been corrected, as have incorrect internal references, and broken links have been updated.

The following have also been added:

1. **Compliance Paths.** This provides more nuanced direction to projects proposing rehabilitation of existing housing, including relating the overall point requirements for Rehab projects to their actual scope, rather than a single point minimum. Also new is the determination that “gut rehab” projects will be held to the New Construction point minimum.
2. **Seasonal Farmworker Exception.** The minimum point requirement for Seasonal Farmworker projects is officially set at 35, regardless of whether a project is Rehab or New Construction.
3. **7.3a-7.5 General Ventilation Guidance.** This multi-criterion guidance is provided to emphasize performance goals, rather than product certifications.
4. **The Post Occupancy Evaluation.** Additional guidance is provided covering the form that data collection and reporting under Criterion 8.4 is expected to take
5. **Appendix C.** The Evergreen section of the Housing Trust Fund Handbook (i.e., Chapter 2, Section 207), Version: March 28,2017, has been included in its entirety for ease of reference.

We hope that these changes make v3.0 easier to use. For any questions, please contact Sean Harrington, Evergreen Standard Manager, at (360) 725-2995, or via email at sean.harrington@commerce.wa.gov.

Acknowledgements

The Evergreen Sustainable Development Standard (ESDS) was developed in collaboration with agencies and organizations throughout Washington State. We thank the following individuals and organizations for their insights and assistance with the ESDS v3.0.

Dan Baldner
Environmental Works

Lynda Carey
Falkin Associates

Ainsley Close
WA State Housing Finance Commission

John deChadenedes
King County Housing Finance Program

Krista Egger
Green Communities

Harlan Falkin
Falkin Associates

Whitney Goetter
WA State Housing Finance Commission

Sean Harrington
WA Department of Commerce

Dena Harris
WA Department of Commerce

Lyle Harris
NW EcoDesign, LLC

Matthew Horwitz
MDHworksLLC

Alistair Jackson
O'Brien & Company

Jason Manges
Beacon Development Group

Alyssa Mehl
Bellwether Housing

Chuck Murray
WA Department of Commerce

Doug Ogden
WA Department of Commerce

Nathan Poel
Office of Rural and Farmworker Housing

John Probst
Catholic Charities Housing Services

Joanne Quinn
City of Seattle Office of Housing

Gomer Roseman
Habitat for Humanity

Scott Starr
SMR Architects

Special thank you to Enterprise Community Partners for allowing the use of Green Communities™ Criteria as the basis for ESDS.

Special thanks to all the Housing Trust Fund (HTF) stakeholders who provided invaluable input throughout the revision process. Department of Commerce staff also gave helpful guidance and support to the ESDS v3.0 Criteria. The review, revision and comment process was overseen by Dena Harris.

Thank you to the following individuals and firms for the photos used in this publication: William Wright Photography, Makah Tribe, SMR Architects, Doug Ogden, Imagine Housing, Reach CDC, YWCA Family Village, Environmental Works, Capitol Hill Housing, and Imagine Housing.

CONTENTS

Introduction	3
Compliance Paths	3
Quick Reference Guide.....	6
1.1a Integrative Process & Green Development Plan	14
1.1b Integrative Process- Advanced tools	18
1.2 Universal Design	20
1.3a Performance Verification	22
1.3b Commissioning	24
1.4 Socially Sustainable Living patterns	25
2.1 Site Protection	28
2.2 Connections to existing development & infrastructure	29
2.3 Compact development	30
2.4 Maximizing Density	31
2.5 Access to services and Public Transportation	32
2.6 Preservation of & Access to open space	34
2.7a Walkable neighborhoods- sidewalks & pathways	36
2.7b Walkable Neighborhoods- Connections to surrounding Neighborhoods	37
2.8 Improving Connectivity to the Community	38
2.9 Greyfield, Brownfield, or Adaptive Reuse Site	41
2.10 Access to Fresh, Local Foods	42
3.1 Environmental Remediation	44
3.2 Erosion & Sedimentation Control	46
3.3a Landscaping	47
3.3b Landscaping	49
3.3c Landscaping- Significant Trees	50
3.4 Efficient Irrigation	52
3.5 Surface Water Management	54
3.6 Storm Drain Labels	57
4.1a Water-Conserving Fixtures	59
4.1b Advanced Water-Conserving Fixtures	61
4.2 Water Metering	63
4.3 Water Reuse	65
4.4 Efficient Plumbing Layout & Design	68
5.1a Building Performance Standard- New Construction	71
5.1b Building Performance Standard- Rehab	73
	0

5.2a Additional Reduction in Energy Use- New Construction	74
5.2b Additional Reduction in Energy Use- Rehab	76
5.3 Shading for South Facing Windows	77
5.4 Energy Star Appliances	79
5.5 Central Laundry	80
5.6 Efficient Lighting	81
5.7a Electricity Meter- New Construction	82
5.7b Electricity Meter- Rehab	83
5.8a Renewable Energy	84
5.8b Photovoltaic/Solar Hot Water Ready	86
5.8c Solar Water Heating	87
5.9 Domestic Water Heating	89
5.10 Domestic Water Heating	90
5.11 Performance Tested Building Air Sealing	91
5.12 Performance Tested Duct Sealing	93
5.13 Space Heating & Cooling Equipment Replacement	94
6.1 Low/No VOC Paints & Primers	97
6.2 Low/No VOC Adhesives & Sealants	98
6.3 Construction Waste Management	100
6.4 Environmentally Preferable Materials	102
6.5a Reduced Heat-Island Effect: Roofing	104
6.5b Reduced Heat-Island Effect: Paving	106
6.6 Socially Sustainable Products	107
7.1 Composite Wood Products That Emit Low/No Formaldehyde	109
7.2a Healthy Flooring Materials	110
7.2b Healthy Flooring Materials	112
7.3a-7.5 General Ventilation Guidance	113
7.3a Exhaust Fan-Bathroom	113
7.3b Exhaust Fans-Bathroom	114
7.4a Exhaust Fans-Kitchen	115
7.4b Exhaust Fans-Kitchen	116
7.5 Ventilation	117
7.6 Clothes Dryer Exhaust	118
7.7 Combustion Equipment	119
7.8 Mold Prevention: Surfaces	120
7.9 Mold Prevention: Tub & Shower Enclosures	121
7.10 Vapor Barrier Strategies	122

7.11 Radon Mitigation	124
7.12 Water Drainage	126
7.13a Enhanced Building Envelope Design.....	128
7.13b Enhanced Building Envelope Design	129
7.14 Garage Isolation	131
7.15 Integrated Pest Management.....	132
7.16 Lead-Safe Work Practices	133
7.17 Smoke-Free Building	134
8.1a Building Maintenance Manual & Unit Turnover Plan.....	137
8.1b O&M Instructions for Maintenance Staff	141
8.2 Emergency Management Plan.....	143
8.3 Resident Manual & Orientation	145
8.4 Project Data Collection	148
8.5 Educational Signage	151
Appendix A: Reserved.....	153
Appendix B	154
Appendix C	161
Glossary.....	166

INTRODUCTION

Overview

The Evergreen Sustainable Development Standard (“ESDS”) is a building performance standard required of all affordable housing projects or programs receiving capital funds from the Housing Trust Fund after July 1, 2008. The ESDS aligns Washington State’s affordable housing investment strategies with environmentally responsible building practices. Green building improves the economics of managing affordable housing and promotes environmental quality while enhancing quality of life for residents.

The ESDS was developed in compliance with [RCW 39.35D.080](#) and contains criteria that safeguard health and safety, increase energy and water efficiency, promote sustainable living, and preserve the environment.

In the creation of the ESDS, technical experts in the field of sustainable development were chosen to meet and recommend the best existing green building standard; they chose Green Communities™ Criteria developed by Enterprise Community Partners. Modifications were needed in order to accommodate the diversity of projects funded by the Housing Trust Fund and to focus the criteria on building practices, codes, climate and communities in Washington State. The ESDS has been reviewed by Housing Trust Fund stakeholders with widespread agreement that this standard is the best first step for affordable sustainable development in Washington State.

Revisions to the Green Communities™ Criteria (2015), changes to the Washington State Energy Code (2015), and stakeholder recommendations for improvement necessitated significant revisions to the ESDS. ESDS 3.0 was published in February 2016 and is required of all projects receiving Housing Trust Fund awards after March 1, 2016.

Important Definitions

Applicants must determine the construction type (new construction, substantial rehab, moderate rehab) of the project and if the site is located in a rural or urban area. See the Glossary at the end of this document for definitions.

ESDS Policies & Procedures

The ESDS policies and procedures, which also include the step-by-step process of ESDS, can be found in Chapter 2 of the Washington State Housing Trust Fund [Handbook](#), section 207.

COMPLIANCE PATHS

In addition to complying with all applicable mandatory requirements, different project types are required to achieve different optional point totals. Projects in rural areas are subject to a different

set of mandatory requirements than projects in urban areas. See the glossary for the definition of each.

New Construction

New construction projects must achieve **50** points from the optional criteria. Rehab projects with a large enough scope to be considered “gut rehab” will be considered new construction for the purposes of the Standard. Project scopes that include opening up of the exterior walls (whether on the inside or outside of the building), for instance, are extensive enough to be considered “gut rehab.”

Rehabilitation

For the purposes of Evergreen, two levels of rehab are recognized: Substantial and Moderate. See the Glossary for the definition of each.

- Substantial Rehabilitation projects must achieve **40** points from the optional criteria
- Moderate Rehabilitation projects have a more complex point requirement, owing to the fact the availability of points is affected by the project scope. Broad-scope projects will be held to the **40** point minimum.

If a Mandatory criterion is determined to be outside of the intended scope of the rehab, it may be considered “not applicable,” and hence waived, for the purpose of the project. For systems that are touched by a project’s scope, a reasonable attempt must be made to maximize the points pursued.

- Example: A Rehab project scope includes replacement of bathroom fixtures. All fixtures should, absent of well-documented reasons why not, be sufficient to achieve the full 6 points under Criterion 4.1b (Advanced Water-Conserving Features).

For scopes which apply only to a portion of a project, all mandatory criteria should be seen to apply within the affected portion.

- Example: if the project above proposes to rehab only 20 units of the 40 units in the example above, and the scope includes painting within the units, all paints and primers used must meet the thresholds for low or no VOC under Criterion 6.1. Hallways and common areas outside the scope of the rehab are not required to be repainted.

For project scopes which include replacement of installed products, but those products are found to have a substantial remaining useful life, those products will not be required to be replaced immediately. Rather, such systems *will* be required to be replaced according to the applicable Criterion/ Criteria when the end of the useful life is achieved.

- Example: if the scope of the project would otherwise mandate replacement of appliances with Energy Star labeled versions (i.e. Criterion 5.4 applies), but the installed appliances are relatively new (i.e. more than half of their estimated useful life remains), replacement of those appliances will not be required immediately. The long-term management plan of the project must include, however, a listing of the identified appliances, their estimated remaining useful life, and a directive to replace them only with Energy Star certified appliances.

A project replacing a building's siding would not, for example, be required to replace all plumbing fixtures with WaterSense-labeled fixtures. Similarly, non-EnergyStar appliances with a remaining useful life will not be required to be immediately replaced. Replacement with EnergyStar appliances *will* be required at the end of the currently-installed appliances' useful lives if appliance replacement is within the project's scope.

Seasonal Farmworker Exception

Regardless of whether a project intended to house Seasonal Farmworkers is New Construction or Rehab, the project must achieve **35** optional points.

QUICK REFERENCE GUIDE

This guide provides a quick overview of the technical requirements of the ESDS Criteria. Applicants must refer to the ESDS criteria for a complete understanding of the requirements.

Integrative Process

M	1.1a Integrative Process & Green Development Plan Use Integrative Process (IP) to achieve the highest possible performance goals over the long term.
10 max	1.1b Integrative Process- Advanced Tools Utilize any of the following measures to enhance and increase the accountability of the Integrated Process for your project: Energy and water modeling, Life Cycle Cost Analysis, or Capital Needs Assessment.
3 max	1.2 Universal Design Incorporate Universal Design by choosing one of three options.
M	1.3a Performance Verification The Evergreen Coordinator, or independent consultant, will verify that specific building systems were installed correctly, operate as intended and perform in accordance with the Evergreen Requirements.
12 max	1.3b Commissioning Hire a qualified independent consultant, to commission specific building systems operate as intended and according to the applicable Evergreen Requirements.
6 max	1.4 Socially Sustainable Living Patterns Provide opportunities for residents to develop strong support networks and promote social sustainability using up to two options.

Location & Neighborhood Fabric

M	2.1 Sensitive Site protection Verify that the project site: (1) Can comply with local critical area ordinances which include protection of: wetlands, fish and wildlife habitat, geologically hazardous areas, aquifer recharge areas and frequently flooded areas. AND (2) Is not located on land designated by the county as agricultural or forest land of long-term commercial significance under the GMA. (RCW 36.70A.060) (3) Do not build in areas designated as “Rural lands” under the Growth Management Act.
M and 2	2.2 Connections to existing development & Infrastructure Mandatory for Urban New Construction. Optional 2 points for Rural New Construction Provide site map demonstrating that the development is located on a site: With access to existing roads, water, sewers and other infrastructure within or contiguous (having at least 25 percent of the perimeter bordering) to existing development; and within the Urban Growth Area designated by an adopted Comprehensive Plan. Do not build on tracts of land that require installing a septic tank or a sanitary sewer line extension of 1,000 feet or greater from the property line of the tract being developed.
M	2.3 Compact development Design and build the project to the density required for the location type: Urban: minimum net density of at least 7 dwelling units per acre & consistent with local zoning.

	Rural and/or Tribal: Comply with local zoning.
5	2.4 Maximizing Density Design and build the project to the maximum density allowed per local zoning.
M and 5	2.5 Access to services & Public Transportation Mandatory & option to achieve additional 5pts Locate the project within walking distance of services or public transportation. Projects are required to provide at least one option from the options listed (see criterion for options). Projects that achieve both options will receive 5 points.
M	2.6 Preservation of & Access to Open Space Set aside common, outdoor open space for use by residents.
M	2.7a Walkable neighborhoods- Sidewalks & pathways Mandatory for urban projects Provide a site map indicating that sidewalks or all-weather pathways will be created or preserved within a multifamily property or single-family subdivision to link the residential development to public spaces, open spaces and adjacent development.
3, 5	2.7b Walkable neighborhoods- connections to surrounding neighborhood Optional 3 or 5 points for Rural & Tribal projects only Connect the project to public and open spaces and adjacent development by providing at least three separate connections (excluding entrances/exits from a single building) from the project to sidewalks or pathways in surrounding neighborhoods and natural areas. Types of connections can include roadways, bike trails, sidewalks, footpaths, and the like.
2	2.8 Improving Connectivity to Community Improve access to community amenities by enhancing access to transit or shared autos, and/or incentivizing biking mobility.
5	2.9 Greyfield, Brownfield, or Adaptive reuse site Locate the project on a greyfield, brownfield, or adaptive reuse site.
3	2.10 Access to Fresh, Local Foods Provide access to fresh local foods by choosing one of three options: Neighborhood Farms and Gardens, Proximity to Farmers Market, or Community-Supported Agriculture.

Site Improvements

M	3.1 Environmental Remediation Conduct and provide a Phase I Environmental Site Assessment according to the American Society for Testing and Materials (ASTM) E1527-13 standard and any additional assessments required to determine whether any hazardous materials are present on site.
M	3.2 Erosion & Sedimentation Control Implement EPA's Best Management Practices (BMP) for erosion and sedimentation control during construction, referring to the EPA document, Storm Water Management for Construction Activities (EPA 832-R-92-005). <u>Or</u> comply with local erosion and sedimentation control standards if the local standards are more stringent than EPA. See criterion for erosion control measures that must be included.
M	3.3a Landscaping Provide a landscape plan (including trees, shrubs, and groundcover) showing that 50% of the newly landscaped area includes a selection of trees and plants that is native and/or adaptive species.
5	3.3b Landscaping Provide a landscape plan (including trees, shrubs, and groundcover) showing that 100% of the newly landscaped area includes a selection of trees and plants that is native and/or adaptive species.

5 max	3.3c Landscaping- Significant Trees Provide a landscape plan demonstrating the preservation of existing significant trees within the buildable area of the site.
M	3.4 Efficient Irrigation If irrigation is utilized, install an efficient irrigation system as defined in the criterion.
6 max	3.5 Surface Water Management Implement a comprehensive stormwater management plan by using Low Impact Development Best Management Practices to retain rainfall volumes as listed in the criterion.
M	3.6 Storm Drain Labels Label all storm drains or storm inlets to clearly indicate where the drain or inlet leads.

Water Conservation

M	4.1a Water-Conserving Fixtures Install WaterSense water-conserving fixtures with the following specifications: Toilets: 1.28 GPF or less, WaterSense certified with MaP test performance at minimum 500g Urinals: 0.5 gpf or less, WaterSense labeled Showerheads: 2.0 GPM or less, WaterSense labeled Bathroom faucets: 1.5 GPM or less, WaterSense labeled Kitchen faucets: 2.0 GPM or less
6 max	4.1b Advanced Water-Conserving Fixtures Install WaterSense water-conserving fixtures with the following specifications: Toilets: 1.1 GPF (gallons per flush) or less WaterSense certified and with a MaP test performance at minimum 500g. Or a toilet with dual flush, one of the options being less than 1 GPF, 500g WaterSense labeled Showerheads: 1.75 GPM (gallons per minute) or less, WaterSense labeled Bathroom faucets: 1 GPM or less, WaterSense labeled Kitchen Faucets: 1.75 GPM or less New constructions projects must comply with optional 4.4
2-4 max	4.2 Water Metering Meter or sub-meter each dwelling unit with a technology capable of tracking water use.
12 max	4.3 Water Reuse Install rainwater and greywater reuse strategies as outlined in the criterion.
7	4.4 Efficient Plumbing Layout and Design Save water and energy by efficiently designing hot water delivery systems to reduce the amount of time it takes hot water to reach a fixture.

Energy Efficiency	
M	<p>5.1a Building Performance Standard <i>Mandatory for New Construction</i></p> <p>Meet the minimum requirements of the most recent edition of the Washington State Energy Code and incorporate the following additional requirements:</p> <ul style="list-style-type: none"> • Single Family Homes, duplexes, townhomes or multi-family buildings three stories or less: Obtain one additional credit from 2015 WSEC Table R406.2, Energy Credits. Or, use the 2015 WSEC section R405.3 Performance-based compliance to demonstrate an additional 7% reduction in energy use compared to code. • Multifamily buildings greater than three stories: Obtain one additional credits from 2015 WSEC Section C406—Additional efficiency package options. Or, use the 2015 WSEC section C407—Performance-based compliance to demonstrate and additional 4 % reduction in energy use compared to the code.
M	<p>5.1b Building Performance Standard <i>Mandatory for Moderate and Substantial Rehab only</i></p> <p>Provide insulation and air sealing improvements as prescribed in Appendix by employing one of three methods: a prescriptive list of measures, a method for calculating a simple 10-year payback, or a more complex savings-to-investment ratio (SIR) calculation.</p>
Up to 25	<p>5.2a Additional Reduction in Energy Use <i>New construction only</i></p> <p>Reduce the project’s overall energy usage more than required in 5.1a.</p>
5	<p>5.2b Additional Reduction in Energy Use <i>Optional for moderate & substantial Rehab only</i></p> <p>Use the method in Appendix B for the simple 10-year payback except extend the payback period to at least 14 years</p>
4	<p>5.3 Shading for South Facing Windows</p> <p>Providing solar access to south facing windows to reduce the space heating loads of the building.</p>
M	<p>5.4 Energy Star Appliances</p> <p>If providing appliances, install ENERGY STAR-labeled clothes washers, dishwashers, and refrigerators.</p>
3	<p>5.5 Central Laundry</p> <p>Provide centralized laundry facilities. Do not install in-unit washers or dryers. If residential scale washers are provided in the centralized laundry facilities, they must be ENERGY STAR-labeled.</p>
M	<p>5.6 Efficient Lighting- Interior Units</p> <p>90% of lighting shall be fitted with LED lamps or luminaires.</p>
M	<p>5.7a Electricity Meter <i>Mandatory for New Construction only</i></p> <p>Install an individual or a sub-metered electric meter for each individual unit.</p>
2	<p>5.7b Electricity Meter <i>Rehab only</i></p> <p>Install an individual or a sub-metered electric meter for each individual unit.</p>
15 max	<p>5.8a Renewable Energy <i>Rehab only</i></p> <p>Install photovoltaic (PV) panels, wind turbines, or other electric-generating renewable energy source to provide a specified amount of energy generation.</p>
1	<p>5.8b Photovoltaic/Solar Hot Water Ready</p> <p>Site, design, engineer, and/or plumb the development to accommodate installation of photovoltaic (PV) or solar hot water system in the future.</p>
10 max	<p>5.8c Solar Water Heating <i>Rehab only</i></p> <p>Provide domestic water heating using solar collectors.</p>

M	5.9 Domestic Water Heating Provide residential or commercial water heaters with the minimum energy performance expectations outlined in the criterion.
2,3,5	5.10 Domestic Water Heating Rehab only Select a Residential Energy Star Water Heater, or upgrade commercial water heating combustion efficiency to a condensing boiler or water heater, or heat pump. See criterion for point structure.
3,7	5.11 Performance Tested Building Air Sealing Moderate and Substantial Rehab only In addition to the prescriptive air sealing measures (see Appendix B), conduct a blower door air sealing protocol that achieves the outlined performance objectives.
10	5.12 Performance Tested Duct Sealing Moderate and Substantial Rehab only Conduct performance tested duct sealing.
2,5,7	5.13 Space heating & Cooling Equipment Replacement Moderate and Substantial Rehab only Install Space Heating and Cooling Equipment Replacement to the specified standards.

Materials Beneficial to the Environment

	6.1 Low/No VOC Paints & Primers All interior paints, varnishes and primers will be less than or equal to the specified.
M	6.2 Low/No VOC Adhesives & sealants All adhesives & sealants (including caulks) must have volatile organic compound (VOC) levels, in grams per liter, less than or equal to the thresholds established by the South Coast Air Quality Management District Rule 1168.
5 max	6.3 Construction Waste Management Reduce the amount of waste and sent to the landfill. Choose one of the following methods. (1)Measured by percentage, (2)Material Specific, or (3)Minimizing Construction Waste (New Construction only).
10 max	6.4 Environmentally Preferable Materials Use environmentally preferable materials and/or materials that are produced (extracted, harvested, manufactured and processed) within 500 miles of the construction site.
2	6.5a Reduced Heat-Island Effect: Roofing Choose one of the following options: (1) Use an ENERGY STAR–certified roofing product for 100% of the roof area. (2) use a “green” (vegetated) roof for at least 50 percent of the roof area. (3) use combinations of ENERGY STAR–certified roofing product and vegetated roof can be used, providing they collectively cover 75 percent of the roof area.
2	6.5b Reduced Heat-Island Effect: Paving Use light-colored/high-albedo materials and/or an open-grid pavement, with a minimum Solar Reflective Index of 30 over at least 50 percent of the site’s hardscaped area.
3 max	6.6 Socially Sustainable Products Choose building products from local manufactures (within 500 mile radius) that support a broader socially sustainable mission, outside of their environmental mission, including the safety and health of their own workers.

Healthy Living Environments

M	7.1 Composite Wood Products that Emit Low/No Formaldehyde All composite wood products exposed to the interior (inside the weather resistive barrier), including particle board, plywood, OSB, MDF, cabinetry, and any other applicable wood product, must be certified as compliant with California 93120 Phase 2.
---	--

M	7.2a Healthy Flooring Materials Mandatory if providing floor coverings Do not install carpets within three feet of entryways, or in laundry rooms, bathrooms, kitchens / kitchenettes, and utility rooms. Do not install carpet on slab on grade.
6	7.2b Healthy Flooring Materials Use non-vinyl, non-carpet floor coverings throughout each building in the project. In addition, do not install flooring containing PVC or chlorine.
M	7.3a Exhaust Fans- Bathroom New Construction & Substantial Rehab only Install Energy Star-labeled bathroom fans that exhaust to the outdoors and are equipped with an automatic timer, motion sensor, humidistat sensor, or that operate continuously.
3	7.3b Exhaust Fans- Bathroom Moderate Rehab only Install Energy Star-labeled bathroom fans that exhaust to the outdoors and are equipped with an automatic timer, motion sensor, humidistat sensor, or that operate continuously.
M	7.4a Exhaust Fans- Kitchen New Construction only Install Energy Star labeled power vented fans or range hoods that exhaust to the exterior.
3	7.4b Exhaust Fans- Kitchen Moderate/Substantial Rehab only Install Energy Star labeled power vented fans or range hoods that exhaust to the exterior.
M	7.5 Ventilation Install a ventilation system for each dwelling unit that that meets the Washington State Amendments to the International Mechanical Code Section 403. Ventilation system energy use shall meet the fan power limits in the Washington State Energy Code, Section R403 or C403.
M	7.6 Clothes Dryer Exhaust Clothes dryers must be exhausted directly to the outdoors using rigid-type ductwork (from the connection point to the exterior exhaust), except for condensing and heat pump dryers, which must be plumbed to a drain. Do not vent to attic or crawl space.
M	7.7 Combustion Equipment If using fossil fuel fired water heaters, specify direct power vented or combustion sealed appliances when the heater is located in a conditioned space.
M	7.8 Mold Prevention: Surfaces Use materials that have durable, cleanable surfaces throughout bathrooms, kitchens and laundry rooms. Materials installed in these rooms should not be prone to deterioration due to moisture intrusion or encourage the growth of mold.
M	7.9 Mold Prevention: Tub & Shower Enclosures Use moisture-resistant backing materials such as cement board, fiberglass faced gypsum board or equivalent behind tiled/grouted or multi-piece shower and tub enclosures. Projects using one piece fiberglass/plastic shower/tub enclosures may use paper-faced gypsum backer board that meets mold-resistant requirements per ASTM #D3273 with a score of at least 10, on all walls and ceiling facing the shower.
M	7.10 Vapor Barrier Strategies Mandatory for New Construction & Moderate/Substantial Rehab projects with foundation work only Install vapor barriers that meet the specified criteria appropriate for the foundation type.
M	7.11 Radon Mitigation For New Construction in high risk radon counties, provide radon mitigation as required by code. For Rehab projects in those counties, conduct radon testing using the protocols described.
M	7.12 Water Drainage Provide drainage of water away from windows, walls, and foundations by implementing list of techniques.

M	<p>7.13a Enhanced Building Envelope Design Mandatory for New Construction Provide a building envelope design that makes it possible to remove and replace windows without compromising the performance of the building envelope.</p>
8/10 Max	<p>7.13b Enhanced Building Envelope Design Utilize any of the three listed measures to enhance the building envelope design for durability.</p>
M	<p>7.14 Garage Isolation Follow the list of criteria for projects with garages.</p>
M	<p>7.15 Integrated Pest Management Utilize the sealing methods outlined in the criterion. Develop an integrated pest management (IPM) policy with resident guidance related to pesticide use, housekeeping, and prompt reporting of pest problems to be included in the Maintenance and Resident Manuals.</p>
M	<p>7.16 Lead-Safe Work Practices For properties built before 1978, use lead-safe work practices during renovation, remodeling, painting and demolition. The contractor performing the work must be Renovation, Repair and Painting certified at a minimum.</p>
M	<p>7.17 Smoke-Free Building Implement and enforce a smoke-free policy in all common and individual living areas, including decks and patios, in unit leases and within 25 feet of building entries or ventilation intakes.</p>

Operations and Maintenance

M	<p>8.1a Building Maintenance Guidance & Unit Turnover Plan Develop a manual with thorough building operations & maintenance guidance and a complementary Unit Turnover Plan. In addition, provide a comprehensive walk-through and orientation for the maintenance and property manager(s) to review the Building Operations and Maintenance Manual and Unit Turnover Plan.</p>
7	<p>8.1b O&M Instructions for Maintenance Staff Develop Building Operations and Maintenance instructions that will be permanently affixed to the building according to the outlined requirements.</p>
M	<p>8.2 Emergency Management Plan Mandatory for Multifamily Provide a Plan on emergency operations targeted toward operations and maintenance staff and other building-level personnel.</p>
M	<p>8.3 Resident Manual and Orientation Provide a guide for homeowners and renters that explains the intent, benefits, use and maintenance of green building features. In addition, provide a comprehensive walk-through and orientation for residents to review the details of the manual.</p>
8 Max	<p>8.4 Project Data Collection Collect and monitor project performance data on energy, water, and, if possible, healthy living environments for a one year, post occupancy. Provide a post occupancy report to Commerce.</p>
M	<p>8.5 Educational Signage Post current, durable and permanent educational signage throughout the building and/or provide educational material to communicate the green efforts of the project to the community, residents and building operators.</p>

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

INTEGRATIVE PROCESS

A successful integrative process facilitates the design and development team's achievement of their objectives throughout the project life cycle.

1.1A INTEGRATIVE PROCESS & GREEN DEVELOPMENT PLAN

Mandatory

REQUIREMENTS

Use an Integrative Process (IP) from design through to building operations, to achieve strong performance goals over the long term. Document a Green Development plan as outlined below.

Integrative Process enables developers to optimize the performance of buildings by focusing throughout the development process on clearly defined functional, environmental, and financial goals. The result of the IP will be buildings that optimize the value of the public investment in affordable housing by achieving very high standards of sustainability, measured primarily in terms of long-term durability, low maintenance, healthy indoor and outdoor environment, and high efficiency in energy and water use.

A fully integrative process as applied to affordable housing will typically include the following elements:

- Identifying development team members who can deliver a high-performing product
- Defining performance goals for the project early in the process
- Modeling various aspects of performance for design alternatives
- Using life cycle cost analysis to make decisions about major design elements
- Developing a well-defined metric for total cost of ownership per unit
- Holding a series of meetings with essential team members throughout design and construction to make sure the process is on target and document the process and results.

It is not expected that all organizations pursuing public financing for housing projects will have the expertise and resources to adopt all elements of a fully integrated process immediately. Rather, this ESDS criterion is established as a goal toward which all developers of affordable housing will be expected to work over a period of time.

Green Development Plan

At a minimum, document the following elements in your Green Development Plan:

1. Identify members of the integrative process team, with an explanation of the role of each person and their contribution to the overall sustainability of the project.
2. A summary of the integrative process used thus far, to select the green building strategies, systems, and materials that will be incorporated into the project.
3. A statement of the functional, environmental, and financial goals of the project. Also state the expected outcomes from addressing those goals through the design, construction, and operation phases.
4. A description of how progress and success towards these goals will be measured throughout the completion of design, construction and operation to ensure that the

1: Integrative Process

green features are included and correctly installed, including a plan for co-ordination with the Third Party Verifier (3PV). It is highly recommended that the plan include at least one pre-construction meeting between the ESDS Coordinator and 3PV to review the approved EPP together, and that the occurrence of the meeting is documented.

5. Plans for how issues will be resolved, if the project teams finds that certain goals are not meeting targets.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach to the EPP the completed Green Development Plan as outlined above.

RATIONALE

The over-arching purpose of the Evergreen Sustainable Development Standard (ESDS) is to improve the life outcomes of people with low incomes by enhancing the quality of affordable housing in Washington State. We do this by pushing developers to create healthier and more cost-effective residences that help them take advantage of life opportunities. The ESDS supports excellence in sustainable development practices from design through building operations by challenging developers, owners, and managers to achieve four core Green Development Goals: high levels of energy and water efficiency, healthy living environments, long-term durability and low maintenance.

Seventy percent of design decisions are made in the first ten percent of a typical project. The integrated process establishes and maintains a focus on green objectives throughout the project life cycle. The outcomes of an integrative process can include lower development and operating costs, fewer change orders, lower utility and other operating costs, and greater health, economic, and environmental benefits for residents, property owners, and communities.

Integrative Process (IP)

IP is a highly collaborative process in which the project team thinks and consults about the entire building and all of its systems together from design through occupancy. Conventional project management processes often fail to recognize that buildings are part of larger, complex systems. As a result, solving for one goal, or problem, may create problems elsewhere in the system. An integrated design process creates a team of professionals who may have traditionally worked as separate entities. An IP team might include the sponsor (Development manager AND Property/Asset manager), Evergreen Coordinator, a building performance analysis consultant, the architect, the mechanical engineer, and the contractor. This team will analyze and develop integrated solutions to complex design challenges and maintain close collaboration throughout the entire development process to ensure that the green development goals are met.

Community Meetings

Community meetings can be powerful opportunities to educate and align stakeholders with the goals and objectives of a project. This is also an opportunity for the integrative process team to tap into collective wisdom of the group- the future resident community, the surrounding

neighborhood and other critical details. This is also an opportunity to ensure that lessons learned through maintenance of other projects are woven into design decisions of current projects. Examples of group meeting participants can include:

- Prospective or current residents, including potential community and/or neighborhood stakeholders
- Architecture or residential building design
- Mechanical or energy engineering
- Building science or performance testing
- Civil engineering, landscape architecture, habitat restoration or land-use planning
- General contractor
- Building management and maintenance staff
- Asset managers
- Planning and building officials with jurisdiction over the project, or city green building reps
- Funders and key donors
- Resident services staff
- Environmental science experts
- Local public health officials

For best results, these meetings should be coordinated by a skilled facilitator who is familiar with ESDS requirements and strategies to achieve them.

RECOMMENDATIONS

- **Benchmarking:** Use data on actual operations from projects in your portfolio as baselines to inform the performance goals for your current project. Examples: portfolio energy and water consumption per bedroom, maintenance costs per unit per year, small repair costs, health needs assessment data and financial data, other pro forma assumptions broken down more finely regarding operating expense categories.
- **Life cycle cost analysis:** Use life cycle cost analysis tools to model the initial cost and maintenance/replacement costs of similar purpose materials and products to identify what will promote the increased service life of the building, be healthier for the residents and lower maintenance, operations and replacement costs.
- **Performance modeling:** Engage consultants with expertise in energy and water consumption modeling to assess design alternatives and inform decisions about the most cost-effective options for major building elements over the long term.
- **Energy efficiency and water use:** Identify specific consumption thresholds or goals for your project that will be evaluated after project completion and occupancy. Create a Measurement and Verification plan that identifies what information you will need to track performance, and how you will gather and manage in the data.
- **Performance specification:** Add building envelope and mechanical installation details to your plans and specifications for the most critical project components, paying particular

1: Integrative Process

attention to: air handler closet air sealing, floor system and band air sealing, party wall air sealing, proper insulation installation, ventilation system installation, and duct sealing with “bucket” mastic. Wherever possible, use tangible targets and specific metrics (such as building envelope leakage, duct leakage and exhaust fan flow rate) and require that it be field verified.

Also provide the construction team with installation guides for the measures above.

- **Operating manual for property managers and residents:** Develop a simple and highly useful manual that will enable property managers and residents to operate your high-performance building to its optimum standard. Consider making essential operating information available in the location it is needed – on the equipment, rather than just in a manual, for example.
- **Incentives for effective integration:** Consider creating incentives for your design and construction team that reward superior performance at completion of construction and in occupancy.

RESOURCES

- Enterprise Green Communities offers a variety of resources to support the integrative process, particularly the Pre-Development Design Toolkit, Green Charrette Toolkit, Green Development Plan and Project Management Guide.
www.enterprisecommunity.org/resources
- Whole Building Design Guide: This website describes the core elements of “whole building design,” which includes the combination of an integrative approach and an integrative team process. This site helps users identify design objectives and organize their processes to meet those objectives.
<http://www.wbdg.org/resources/whole-building-design>
- *The Integrative Design Guide to Green Building: Redefining the Practice of Sustainability.* 7group and Bill Reed (2009). This book provides guidance to building professionals on incorporating integrative process into every phase of a project.
- Green Building 101: What is an integrated process? <http://www.usgbc.org/articles/green-building-101-what-integrated-process>

1.1B INTEGRATIVE PROCESS- ADVANCED TOOLS

Optional up to 10 points

REQUIREMENTS

Utilize any of the following 3 options to enhance and increase the accountability of the Integrated Process for your project.

Option #1 (4 points): Include a building performance consultant on your project team who will provide building energy and water modeling. The services should include research into technologies for efficiency, and strategies for post-occupancy monitoring and quantification of performance in relation to the owner's project goals. Provide documentation of how these services have informed your decisions about design, construction, and post-occupancy monitoring.

Option #2 (4 points): Early in the design process, incorporate the use of the ESDS Life Cycle Cost Tool <http://www.commerce.wa.gov/wp-content/uploads/2016/11/hfu-lifecycle-cost-tool-2015.xlsb> to refine design decisions. Include the total cost of ownership on a per-unit basis for your project, encompassing all development costs, maintenance costs and utility costs over a 25-year period. Provide a narrative detailing how the design team incorporated the use of the tool into their process, how, or if, design decisions were influenced by the process of using the tool, and suggestions for enhancements to the tool.

Option #3 (new construction only, 2 points): Identify IP team members who are able to develop a 25-year capital needs assessment (CNA) during the design phase of the project and provide a copy of the CNA with your funding application.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the option(s) chosen. Provide the following for each option:
 - Option #1- Attach energy and water modeling documentation and a narrative explaining how these services informed decisions about design, construction and post-occupancy.
 - Option #2- Attach the life cycle cost analysis. Use the LCCA tool provided [here](#). In addition,
 - attach a narrative detailing how the design team incorporated the use of the tool into their process,
 - how, or if, design decisions were influenced by the process of using the tool, and
 - suggestions for enhancements to the tool.
 - Option #3- State that a 25-year CNA was provided with your funding application. If not, provide the report.

RATIONALE

Using data and analysis during design helps compare the effect of choices over the lifetime of a building to support responsible resource management while also comparing costs.

RESOURCES

- Use the ESDS Life Cycle Cost Tool:
<http://www.commerce.wa.gov/wp-content/uploads/2016/11/hfu-lifecycle-cost-tool-2015.xlsb>
- Whole Building Design Guide description of Life-Cycle Cost Analysis:
<http://www.wbdg.org/resources/life-cycle-cost-analysis-lcca>

1.2 UNIVERSAL DESIGN

Optional up to 3 points

REQUIREMENTS

Option #1 **(1 point)**: will be awarded for including the following features:

- All unit entries on an accessible route of travel.
- All door hardware (including closet doors) accessible lever or loop style handles. Bi-pass or sliding doors are exempt.
- All doors to provide 32 inches clear or 36 inches rough opening. This includes all doors designed to allow passage through the unit; this includes entry doors, doors to habitable rooms or hallways, doors in walk in closets, patio doors and doors in utility/storage rooms larger than 48"x48" in size."
- All closets to have shelves and rods (or combination shelf / clothes rod) able to be moved between 42 and 60 inches above the finished floor.

Option #2 **(2 points)**: will be awarded for including the previous features, plus:

- Accessible appliances including front or side control ranges, side-by-side front-load washers and dryers (if provided) and side-by-side or accessible top-freezer refrigerators.
- Accessible controls, which includes rocker light switches and digital thermostats. All controls between 36 and 44 inches above the finished floor.
- All faucets in kitchens and bathrooms to have single lever anti-scald accessible controls, with a clear knee space under the sink. The clear knee space shall be 30" wide, 11" deep and 27" high. All pipes in the knee space shall be insulated. The clear knee space can be accommodated with removable doors and deck in the base cabinet.

Option #3 **(3 points)**: will be awarded for including the previous features, plus:

- Locate toilet so centerline of toilet is 15 to 18 inches from parallel wall on the side of the toilet, and so that 24 inches of clear floor space is located to the other side of the toilet.
- All hallways or routes of travel to be a minimum of 48" clear.
- Kitchen to include a minimum 30" wide accessible work surface 30 to 34 inches above the finished floor with a clear knee space below. The clear knee space shall be 30" wide, 11" deep and 27" high.
- At least half of the base cabinets in kitchens (excluding sink bases) to have full extension pull out drawers. Counter top to be 34 inches above the finished floor, and the bottom of upper cabinets to be a maximum of 48 inches above the finished floor.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state which option will be incorporated and list the features.

RATIONALE

Universal design features result in a building that is sensitive to a wide range of resident needs, including those who have temporary or permanent disabilities. The creation of comfortable environments for a diverse population increases the likelihood of dynamic, diverse communities.

RECOMMENDATIONS

Universal design features should be considered during the integrative process, based on the sustainability goals of the project.

RESOURCES

- ICC/ANSI A117.1 Standard:
<http://webstore.ansi.org/RecordDetail.aspx?sku=ICC%2FANSI+A117.1-2003>

and

<http://shop.iccsafe.org/icc-ansi-a117-1-2003-accessible-and-usable-buildings-and-facilities.html>

1.3A PERFORMANCE VERIFICATION

Mandatory

REQUIREMENTS

The Evergreen Coordinator, or independent consultant, will verify that applicable ESDS criteria:

1. Were installed correctly;
2. Operate as intended;
3. Perform in accordance with the Evergreen Requirements:

Applicable ESDS Criteria	Performance Testing	Size of the sample	
4.1a or 4.1b Water Conserving Fixtures	Bag testing or bucket testing showerheads and faucets.	Minimum of 15% of units spread across the project.	
4.2 (if applicable) Water Metering	Require the vendor to provide documentation of accuracy.	Entire Water Metering System	
7.5 Ventilation	Test the airflow to individual housing units to verify that they meet minimum standards, but do not exceed the design airflow by more than 20%. Verify performance using a flow hood, pressure pan, or similar method.	Project Size	# of units to test
		0-24	8
		25-49	10
		50-74	12
		75+	15

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state:
 - Which ESDS criterion will require Performance Verification.
 - Construction documents will include the Performance Verification requirements.
 - The installer will provide written verification that the systems operate as required, available on the jobsite.
 - Post installation, the Evergreen Coordinator, or independent consultant, will conduct performance testing & provide a summary report, available on the jobsite.

RATIONALE

Commissioned buildings are more likely to perform as intended and avoid operational problems. Poorly performing buildings inherently have high costs. Benefits from commissioning include a smoother construction process (from improved communication, fewer change orders, and avoided litigation), reduced operation and maintenance costs, lower energy costs (through improved energy efficiency) and satisfied building occupants and tenants (through improved indoor air quality and thermal comfort).

RESOURCES

Building Commissioning for New Buildings:

<http://www.energy.wsu.edu/Documents/BuildingCommissioning.pdf>

1.3B COMMISSIONING

Optional up to 12 points

REQUIREMENTS

Hire a qualified independent consultant, as a commissioning agent, to verify that the following building systems operate as intended and according to the applicable ESDS Requirements:

ESDS #	Building System	Points
5.2a or 5.10	Domestic Water Heating	2 points
5.6	Lighting Controls	2 points
5.2a or 5.8a	Renewable Energy systems	2 points
5.2a or 5.8b	Solar Water Heating	2 points
several	HVAC	2 points
several	Any other automated building systems controls	2 points

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state

- Which applicable systems will be included in the commissioning plan.
- That a final commissioning report will be submitted to the Commerce's Third Party Verifier upon completion.
- Compliance with the following requirements:
 - The architect and MEP consultants will develop a Basis of Design (BOD) that will meet the Owner's Project Requirements (at a minimum, the performance requirements established in 1.1);
 - Commissioning requirements will be incorporated into the construction documents.

RATIONALE

Commissioned buildings are more likely to perform as intended and avoid operational problems. Poorly performing buildings inherently have high costs. Benefits from commissioning include a smoother construction process (from improved communication, fewer change orders, and avoided litigation), reduced operation and maintenance costs, lower energy costs (through improved energy efficiency) and satisfied building occupants and tenants (through improved indoor air quality and thermal comfort).

RESOURCES

Building Commissioning for New Buildings:

<http://www.energy.wsu.edu/Documents/BuildingCommissioning.pdf>

1.4 SOCIALLY SUSTAINABLE LIVING PATTERNS

Optional up to 6 points

REQUIREMENTS

Provide opportunities for residents to develop strong support networks and promote social responsibility.

Option #1 (3 points): Design spaces or features that promote social sustainability. Describe how the project design team studied living patterns of end users and designed spaces or features that will help residents develop an inclusive sense of community and cultivate meaningful support networks. In addition, create a plan that on-site staff will follow to encourage residents to use the spaces as intended.

Option #2 (3 points): Create opportunities for the resident population to participate in discussions regarding the sustainability of the project. Form an advisory board or governance structure that allows users to have a perpetual voice in providing guidance for maintenance, operations, and programming. Consideration of the target population should be taken into account.

Note: Project teams may not use mandatory or optional criteria within the ESDS standard to gain points for this criterion.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. For Option #1, attach a description of how the project design team intentionally developed spaces or features that help residents develop an inclusive sense of community and cultivate meaningful support networks. Describe the plan that on-site staff will follow to encourage residents to use the spaces as intended.
2. For Option #2, attach a description for how the resident population will participate in discussions regarding the sustainability of the project. Describe how the advisory board or governance structure will be formed, who will be responsible for managing the process, and how the resident population might participate.

RATIONALE

The three pillars of sustainability consist of economic development, social development and environmental protection. Social sustainability is about people and our ability to provide for our own social wellbeing and future.

RECOMMENDATIONS

Study, and seek public participation, on how communities with similar resident populations function socially and how other communities establish resident advisory boards. Try to determine how particular design choices will affect social issues.

Introduction

1 Integrative Process

**2 Location &
Neighborhood Fabric**

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

LOCATION & NEIGHBORHOOD FABRIC

A Locating a project within an existing neighborhood and in close proximity to infrastructure, transportation and services encourages more resource-efficient development of land, reduces development costs, conserves energy and adds to the vitality of the overall community.

2.1 SITE PROTECTION

Mandatory

REQUIREMENTS

Verify that the project site:

1. Can comply with local critical area ordinances which include protection of: wetlands, fish and wildlife habitat, geologically hazardous areas, aquifer recharge areas and frequently flooded areas.
2. Is not located on land designated by the county as agricultural or forest land of long-term commercial significance under the GMA. ([RCW 36.70A.060](#)).
3. Is not built in areas designated as “Rural lands” under the Growth Management Act. Rural lands are those lands in a county that have not been designated as natural resource lands of long-term commercial significance and have not been designated for urban growth. Rural lands do not include incorporated rural towns or cities, but can include existing rural communities that have not been incorporated. County planning for development in rural areas needs to include goals and policies to provide for a variety of rural densities and to protect rural character.

Exemption: Seasonal Farmworker and Tribal projects are exempt from this criterion

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach documentation from the local jurisdiction stating the zoning for the property, identification of any known critical areas or resource lands within 300 feet and any resulting development restrictions.

RATIONALE

Proper site selection avoids development of inappropriate sites and damage to or loss of fragile and scarce environmental resources.

2.2 CONNECTIONS TO EXISTING DEVELOPMENT & INFRASTRUCTURE

Applies to New Construction projects only:

- Urban: Mandatory
 - Rural: Optional 2 points
-

REQUIREMENTS

Provide site map demonstrating that the development is located on a site:

- With access to existing roads, water, sewers and other infrastructure within or contiguous (having at least 25 percent of the perimeter bordering) to existing development; and
- Within the Urban Growth Area designated by an adopted Comprehensive Plan.

Do not build on tracts of land that require installing a septic tank.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach a clear and detailed Site & Vicinity Map with explanations. Clearly label and indicate on the map the areas specific to this criterion.

RATIONALE

Locating a project within an existing neighborhood and in close proximity to infrastructure encourages more resource-efficient development of land, reduces development costs, conserves energy, and adds to the vitality of the overall community.

2.3 COMPACT DEVELOPMENT

Mandatory

REQUIREMENTS

Design and build the project to the density required for the location type:

- *Urban*: A minimum net density of at least 7 dwelling units per acre, or consistent with local zoning.
- *Rural and/or Tribal*: Comply with local zoning.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the architect's density calculation and statement of correctness.

RATIONALE

Compact development encourages more resource-efficient development of land, reduces development costs and can reduce automobile dependence. It also can contribute to creating more walkable communities, while helping restore, invigorate and sustain livable development patterns.

RESOURCES

Smart Growth Network: this website outlines smart growth principles, provides a guide through smart growth terms and technical concepts, and hosts a searchable catalogue of reports, websites, tools, and case studies: <https://smartgrowth.org/>

2.4 MAXIMIZING DENSITY

Optional 5 points

REQUIREMENTS

Design and build the project to the maximum density allowed per local zoning.

- In areas where local zoning does not specify maximum density: exceed the residential density (dwelling units /acre) of the census block group in which your project is located by a multiple of 2. Find the density of your census block group by typing your project address into the Center for Neighborhood Technology “Residential Density of a Location” calculator found at <http://apps.cnt.org/residential-density/>. Then multiple the net density by 2.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the architect’s density calculation and statement of correctness.

RATIONALE

Compact development encourages more resource-efficient development of land and supports demand for other infrastructure such as public transportation and commercial development.

2.5 ACCESS TO SERVICES AND PUBLIC TRANSPORTATION

Mandatory plus an option to achieve an additional 5 points

REQUIREMENTS

Locate the project within walking distance of services or public transportation. Projects are required to provide at least one option from the options below. Projects that achieve both options will receive 5 points. NOTE:

- Facilities used to meet this criterion must be built at the time of EPP approval.
- Each establishment must be a separate and distinct business and may only count as one facility. Separate and distinct businesses under one roof will each count as a facility. For example, a Safeway that also houses a Wells Fargo Bank and a Starbucks will count as 3 facilities.

Option #1: Proximity to Services. Locate the project within:

- *Urban*: 0.25-mile distance of at least two or a 0.5-mile distance of at least four facilities.
- *Rural / Tribal*: 1 mile of at least two facilities, 2 miles for at least four facilities.

CIVIC & COMMUNITY FACILITIES		SERVICES	RETAIL
Medical clinic or office	Police or fire station	Bank	Supermarket
Licensed Adult or senior care	Public Library	Restaurant, café, diner	Other food store with produce
Licensed Childcare	Public park	Laundry, dry cleaner	Farmers market
Community or recreation center	Post office	Gym, health club, exercise studio	Hardware store
Entertainment venue (theater, sports)	Place of worship	Hair care	Pharmacy
Employment Center	Government office that serves public on-site		Clothing retail
Educational facility (including k-12 school, university, adult education, vocational school, community college)	Social services center		Other retail
Cultural arts facility (museum, performing arts)			

List taken from LEED 2009 Neighborhood Development Rating System

Option #2: Access to Public Transportation. Locate project within:

- *Urban*: 0.5-mile distance of transit service (bus stop, rail stop, or ferry terminal).
- *Rural / Tribal*: 5-mile distance of the following transit options: 1) vehicle share program; 2) dial-a-ride program; 3) employer vanpool 4) Park & Ride lot; and 5) public-private regional transportation.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state which option(s) the project will be able to access.
2. If both options are provided, award 5 points. Attach the following documents for the applicable option(s):

2: Site Improvements

- For Option #1: Attach a context map demonstrating that the center of the site is within the required walk distances of the required number of services. Google Maps offers a function to demonstrate walk distance. On Google Maps, go to “Directions” and select “Walk Directions” to obtain this information.
- For Option #2: Attach a context map to demonstrate that the center of the site is within the required distance of transit options. Google Maps offers a function to demonstrate walk distance. On Google Maps, go to “Directions” and select “Walk Directions” to obtain this information.

RATIONALE

Projects located near transit and/or services reduce residents’ need to own a car, thereby eliminating or lowering the costs of auto ownership, a significant assistance to low-income populations. Additionally, it strengthens those communities and residents’ ties to society and creates walkable communities that promote human health while reducing transit related emissions of air pollutants and carbon dioxide.

RESOURCES

- Safe Routes to School National Partnership: <http://www.saferoutespartnership.org/home> This network of more than 300 nonprofit organizations, government agencies, schools, and professionals works to advance the Safe Routes to School (SRTS) movement in the United States. SRTS can provide a variety of important benefits to children and their communities, including increasing physical activity, reducing traffic congestion, improving air quality, and enhancing neighborhood safety.
- Reconnecting America: <http://www.reconnectingamerica.org/> This national nonprofit organization provides both the public and the private sectors with a fact-based perspective on development-oriented transit and transit-oriented development.

2.6 PRESERVATION OF & ACCESS TO OPEN SPACE

Mandatory

REQUIREMENTS

Set aside common, outdoor open space for use by residents. Open space does not include streets, roadways, tenant private outdoor areas, or areas inaccessible to residents. Provide one of the following options:

Option #1: Set aside 10% common, outdoor open space for use by residents. Open spaces should be safe and designed to enhance physical activity and or/social interaction.

Option #2: Locate project within a 0.5-mile distance of dedicated public open space that is a minimum of 0.75 acres. The open space requirement may be met by either one large open space or two smaller spaces totaling 0.75 acre.

To calculate open space: deduct buildings, private outdoor areas, streets and roadways from your total site area and then multiply by 10%.

- Land that is set aside for future development cannot be included as open space in these calculations.

Open space: Undeveloped land that is permanently set aside for public use. Open space may be used as community open space or preserved as green space, and includes parcels in conservation easement or land trust, park or recreation areas, and community gardens.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP, state the option chosen and how the design will meet the requirement.
2. Attach a clear and detailed Site & Vicinity Map and indicate on the map the areas designated as open space for residents. Open space does not include streets, roadways, or tenant private outdoor areas, or areas inaccessible to residents.

RATIONALE

Access to open space and natural resources improves quality of life by providing physical and psychological health benefits, by promoting social interactions, and by supplying the opportunity to better understand the importance of the natural environment.

RECOMMENDATIONS

- For single family, front lawn space can be used to meet this criterion.
- Create a site plan with total acres and the number of acres of the proposed open space, and a narrative plan for security and maintenance for the preservation of the open space.

2: Site Improvements

- Open spaces should be safe and designed to promote active use by residents. Features such as active bike and walking trails/paths, lighting, seating options, native plantings and recreation facilities to make open space a community amenity. Open spaces should complement the cultural preferences of the local population and accommodate people of all ages.

RESOURCES

- U.S. Environmental Protection Agency, Smart Growth and Open Space Conservation: <https://www.epa.gov/smartgrowth/smart-growth-and-open-space-conservation>
- The Trust for Public Land, ParkScore Index: A rating system developed to measure how well U.S. cities are creating parks. <http://parkscore.tpl.org/>

2.7A WALKABLE NEIGHBORHOODS- SIDEWALKS & PATHWAYS

Mandatory for urban projects only

REQUIREMENTS

Provide a site map indicating that sidewalks or all-weather pathways will be created or preserved within a multifamily property or single-family subdivision to link the residential development to public spaces, open spaces and adjacent development.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach a site map clearly illustrating the existing and proposed sidewalks and all-weather pathways and where they lead to.

RATIONALE

Making the streetscape safer and more inviting for walkers and bicyclists encourages alternative transportation choices to the automobile. This promotes physical activity and public health, while creating opportunities for social interaction and increased safety by bringing more eyes on public spaces.

RECOMMENDATIONS

Consider porous pavement for sidewalks and other paved surfaces to reduce storm-water runoff and the distribution of pollutants to streams, rivers and water bodies. Design sidewalks to distribute storm water to open space for recharge and to prevent flooding.

2.7B WALKABLE NEIGHBORHOODS- CONNECTIONS TO SURROUNDING NEIGHBORHOODS

Rural & Tribal projects only: Optional 3 or 5 points

REQUIREMENTS

Connect the project to public and open spaces and adjacent development by providing at least three separate connections (excluding entrances/exits from a single building) from the project to sidewalks or pathways in surrounding neighborhoods and natural areas. Types of connections can include roadways, bike trails, sidewalks, all-weather footpaths, and the like.

(3 points) for providing two separate connections.

(5 points) for providing three separate connections.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state how many separate connections the project will provide.
2. Attach a site map demonstrating at least three separate connections to sidewalks or all-weather pathways in surrounding neighborhoods.

RATIONALE

Providing choices for pedestrians to connect to adjacent development and public and open spaces promote walking, biking, and other healthy lifestyles.

RECOMMENDATIONS

Pedestrian activity and improved safety can be encouraged in single family residences by locating the garage in the rear or on the side of the home. Consider using porous pavement for sidewalks and other paved surfaces to reduce stormwater runoff and the distribution of pollutants to streams, rivers, and water bodies. Design sidewalks to distribute stormwater to open space for recharge and to prevent flooding.

2.8 IMPROVING CONNECTIVITY TO THE COMMUNITY

Optional 2 points

REQUIREMENTS

Improve access to community amenities by selecting at least two of the measures below:

Improving Access

Transit

- Provide residents with discounted transportation passes for a period of at least 12-months.
- Provide residents with free transportation passes for a period of at least 12-months.

Auto

- Include car-share services (parking) on property.
- Provide all eligible residents with discounted car-share memberships for a period of at least 12-months.
- Provide a minimum of 50% of eligible residents with free car-share memberships for a period of at least 12-months.

Incentivize Biking Mobility

- Provide outdoor bicycle racks that are accessible for visitors and residents.
- Provide secure, lockable, sheltered and accessible bicycle storage. Provide one bicycle parking space for every two residential units. Post signage directing residents to bicycle parking areas and programs.
- Provide bicycles and equipment (e.g., helmets, locks, tire pumps, maintenance equipment) for resident use.
- Promote use of, and access to, one or more bicycle-share programs within 0.25-mile of the building. Bicycles need to be accessible to occupants at all hours. Maps to the nearest bike station should be posted in a visible location within a common area in the building and included in the Resident Manual (Criterion 8.3).
- Provide residents with discounted or free bicycle-share memberships for a period of at least 12-months

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:
 - State which two measures will be used.
 - Describe the implementation plan.
2. If choosing car-sharing services or bicycle racks/storage, attach a site map identifying the space that will dedicated for the amenities.

RATIONALE

Connections to adjacent development and public, open spaces promote recreational walking, biking and other healthy lifestyle choices, as well as promoting alternative means of commuting.

RECOMMENDATIONS

- Pedestrian activity and improved safety should be encouraged when considering opportunities for biking, walking, driving and parking.
- Provide orientation materials and maps to the nearest bus, transit stations and car-share facilities (general orientation materials are acceptable for floating car-share services such as Car2go). Information about these amenities should be posted in a visible location in a common area in the building and included in the Resident Manual (Criteria 8.3).
- Consider including a small amount of credit (\$10) for residents to try their local car-share service. Contact the car-share services to see if they would like to offer discount or credit to encourage use.
- Promote designs that encourage slow-speed, low-volume roadways, thereby enhancing walkers' and bikers' safety.
- For ease of use, bicycle storage is ideally incorporated on the ground floor with direct roll-in access that is separate and distinct from automobile access. Push-button doors make roll-in access even more convenient for riders, especially during inclement conditions.
- Provide bicycle storage for staff as well as residents.
- Consider designing the building exterior and massing to encourage physical activity by maximizing variety, detail and continuity on the lower one-to-two floors of the building exterior; by providing multiple entries and maximum transparency; and by incorporating canopies and awnings into building façade.
- Consider using porous pavement for sidewalks and other paved surfaces to reduce stormwater runoff and the distribution of pollutants to streams, rivers and water bodies. Design sidewalks to distribute stormwater to open space for recharge and to prevent flooding.
- Make bicycle and pedestrian routes to parks and public spaces safe and visible.
- Conduct an assessment to determine most likely routes of pedestrian and bicycle use when laying out paved pathways / sidewalks from the project to the surrounding neighborhood. Build the pathways / sidewalks where there is visible evidence of pedestrian and bicycle use.
- To encourage pedestrian activity, minimize addition of mid-block vehicular curb cuts on streets with heavy foot traffic; construct curb extensions along sections of the sidewalk that tend to attract greater pedestrian congestion and that are close to pedestrian crossings.
- Dedicated pedestrian and bicycle paths are important even on dead-end streets.
- Design vehicular driveways and ramps to improve pedestrian safety and encourage walkability.
- Incorporate street furniture such as benches, trash receptacles and bicycle racks to create an active streetscape.

2: Site Improvements

- Install street features that have been shown to effectively calm traffic, including curb extensions, medians, roundabouts and raised speed reducers.

RESOURCES

- NYC Departments of City Planning, Health and Mental Hygiene, and Design and Construction. Active Design Supplement: Shaping the Sidewalk Experience, 2013. www.nyc.gov/html/dcp/pdf/sidewalk_experience/active_design.pdf
- Robert Wood Johnson Foundation, Active Living Research. <http://activelivingresearch.org/active-design-supplement-affordable-designs-affordable-housing>
- Task Force on Community Preventive Services, The Community Guide — What Works to Promote Health. <http://www.thecommunityguide.org/pa/environmental-policy/communitypolicies.html>
- Task Force on Community Preventive Services, The Community Guide — Street-Scale Urban Design Land Use Policies. <http://www.thecommunityguide.org/pa/environmental-policy/streetscale.html>

2.9 GREYFIELD, BROWNFIELD, OR ADAPTIVE REUSE SITE

Optional 5 points

REQUIREMENTS

Locate the project on a greyfield, brownfield, or adaptive reuse site.

Greyfields: locate the project on previously developed vacant or underutilized sites, such as parking lots and shopping centers.

Brownfields: locate the project on a site for which part or all is documented as contaminated by means of an ASTM E1903-97 Phase II Environmental Site Assessment or a local Voluntary Cleanup Program, or on a site defined as a brownfield by a local, state, or federal government agency. Remediate site contamination such that the controlling public authority approves the protective measures and/or cleanup as effective, safe, and appropriate for the future use of the site. A Brownfield is defined as real property where the expansion, redevelopment, or reuse may be complicated by the presence of a hazardous substance, pollutant, or contaminant including petroleum. These sites require a Phase II Environmental Site Assessment and a remediation plan.

Adaptive reuse site: An existing building that is being renovated to accommodate a new use, e.g., rehabilitating an old school for use as housing.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, provide a description and explanation that confirms the type of site.

RATIONALE

Use of brownfields, greyfields or adaptive reuse sites reduces pressure on undeveloped land. Reuse of existing structures reduces the need for new materials.

RESOURCES

- U.S. Environmental Protection Agency, Brownfields Cleanup and Redevelopment: www.epa.gov/brownfields/index.html
- National Vacant Properties Campaign: <http://www.communityprogress.net/>
This website provides information, resources, tools, and assistance to support vacant property revitalization efforts.

2.10 ACCESS TO FRESH, LOCAL FOODS

Optional 3 points

REQUIREMENTS

Choose one of the following options for a maximum of 3 points:

Option #1: Neighborhood Farms and Gardens **(3 points for choosing 1a or 1b)**

1a) Dedicate permanent and viable growing space and/or related facilities (such as greenhouses) within the project equal or greater in size to 25 square feet per dwelling unit of the project. Provide solar access, fencing, watering systems, garden bed enhancements (such as raised beds), secure storage space for tools, and pedestrian access for these spaces. Ensure that the spaces are owned and managed by an entity that includes occupants of the project in its decision making, such as a community group, homeowners' association, or public body.

Established community gardens outside the project boundary but within a 0.5-mile walk distance of the project's geographic center can satisfy this option if the garden otherwise meets all of the option requirements.

1b) Dedicate permanent and viable growing space and /or related facilities (such as greenhouses) within the project equal or greater in size to 25 square feet per dwelling unit of the project, and establish an agreement with a local farming operation to farm the land. Ensure in the agreement that at least 50% of the produce is made available for purchase by the project's residents. Provide solar access, fencing, watering systems, garden bed enhancements (such as raised beds), and secure storage space for tools.

Option #2: Community-Supported Agriculture **(3 points)**

Offer a specified location within the project boundaries for delivery of community-supported agriculture (CSA) program shares for residents, project staff, and surrounding community members, as appropriate. The farm(s) supplying the CSA shares must be within 150 miles of the project site. Shares must be delivered to the specified delivery point on a regular schedule at least twice a month for at least four months of the year.

Option #3: Proximity to Farmers Market **(3 points)**

Locate the project's geographic center within a 0.5-mile walk distance of an existing or planned farmers market that is open or will operate at least once a week for at least five months of the year. Farmers market vendors may sell only items grown within 150 miles of the project site OR market vendors consisting of only Washington state farmers, fishers, ranchers, foragers and small food businesses who sell directly to the public what they grow or produce. A planned farmers market must have firm commitments from farmers and vendors that the market will meet all of the above requirements and be in full operation by the time there is 50% occupancy of the project's dwelling units.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state which option the project will provide.
2. Attach a detailed plan of how the requirements will be met.
3. If selecting Options 1a or 1b, attach a site map identifying the growing space.

RATIONALE

Access to fresh produce offers healthy food options for residents. This measure also supports local economic development that increases the economic value and production of farmlands and community gardens.

RECOMMENDATIONS

- For projects pursuing Option 1a, consider bringing in an individual or group (e.g., master gardener(s) or a garden club) to work with the residents to establish the garden and maintain productivity.
- For projects pursuing Option 2 or 3, encourage the farms supplying the produce to accept food stamps.

RESOURCES

- Local Harvest: This website offers a search function to find farmers markets, family farms, and other sources of local, sustainably grown food in a given area:
www.localharvest.org/
- U.S. Department of Agriculture, National Agricultural Library, Food and Nutrition Information Center, Community Food Systems:
http://fnic.nal.usda.gov/nal_display/index.php?info_center=4&tax_level=2&tax_subject=276&topic_id=1344&placement_default=0

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

SITE IMPROVEMENTS

A Low-impact design and development principles minimize the site's environmental footprint and lower infrastructure costs associated with stormwater management.

3.1 ENVIRONMENTAL REMEDIATION

Mandatory

REQUIREMENTS

Conduct and provide a Phase I Environmental Site Assessment according to the *American Society for Testing and Materials (ASTM) E1527-13* standard and any additional assessments required to determine whether any hazardous materials are present on site.

- If hazardous substances are considered to be present, conduct and provide a Phase II Environmental Site Assessment.
- For all existing buildings, limited surveys for asbestos, lead-based paint and mold are required to be submitted with the application.
- For all vacant land, a limited wetland survey is required.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the conclusion of the ESA Phase 1 and that it was submitted with your application for funding. If you did not submit your ESA with your funding application, then attach it to the EPP.

3.2 EROSION & SEDIMENTATION CONTROL

Mandatory

REQUIREMENTS

Implement EPA's Best Management Practices (BMP) for erosion and sedimentation control during construction, referring to the EPA document, *Storm Water Management for Construction Activities* ([EPA 832-R-92-005](#)). Or comply with local erosion and sedimentation control standards if the local standards are more stringent than EPA.

Erosion control measures must include all of the following:

- Stockpile and protect disturbed topsoil from erosion (for reuse).
- Control the path and velocity of runoff with silt fencing or comparable measures.
- Protect onsite storm sewer inlets, streams and lakes with straw bales, silt fencing, silt sacks, rock filters or comparable measures.
- Provide swales to divert surface water from hillsides.
- If soil in a sloped area (i.e., 25 percent, or 4:1 slope) is disturbed during construction, use tiers, erosion blankets, compost blankets, filter socks and berms, or some comparable approach to keep soil stabilized.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state:
 - Which BMP or local controls will be incorporated into the construction and site development plans and contracts.
 - The actual erosion measures that will specifically be used on the site.

RATIONALE

Erosion and sedimentation control during site development keeps valuable top soils on site and reduces pollution, storm-water runoff and sediment runoff associated with construction activities into local waterways. Erosion and sedimentation control helps to avoid storm-water-related problems that can delay construction, cause environmental degradation (to creeks, streams and coastal waters) and damage public and private properties downstream. The goal of this criterion is no visible off-site discharge.

3.3A LANDSCAPING

Mandatory, if providing landscaping

REQUIREMENTS

Provide a landscape plan (including trees, shrubs, and groundcover) showing that 50% of the plantings be native and/or adaptive species. Where possible, locate newly planted trees to provide shade in the summer and allow for solar access in the winter.

All new plants within the property boundaries must meet the following criteria:

- Must be appropriate to the site's soils and microclimate
- If providing irrigation, meet the irrigation requirements outlined in ESDS 3.4
- Have an anticipated size at maturity that will not interfere with building areas, or require topping or heavy pruning to control height and growth
- Not be noxious weeds or weeds of concern

Areas specifically dedicated to food production are exempt from this requirement and not included as landscaped area.

Adaptive plant species Definition: A non-native plant species that performs similarly to a native species in a particular region, state, ecosystem, and habitat, and that 1) can survive temperature / weather extremes in the microclimate; 2) requires little irrigation or fertilization, once established; 3) is resistant to local pests and diseases; and 4) does not displace other plants, as invasive plants do.

Native plant species Definition: A plant species that occurs naturally in a particular region without direct or indirect human actions.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach a landscape plan showing native plantings and their relation to the building(s). The map must clearly show 50% or more of the landscaped area as native and/or adaptive species.

RATIONALE

Native and adaptive plants are well suited to the climate and provide excellent erosion, sediment, dust, and pollution control. Native and adaptive plants are more resistant to naturally occurring disease, insects, and low levels of nutrients, thereby reducing or eliminating the need for fertilizers, pesticides, or herbicides.

RECOMMENDATIONS

- Consult a local arborist and involve a landscape architect in the architectural design process to identify appropriate areas for landscaping including energy and water savings, and to ensure that landscaping includes appropriately sized trees or shrubs.
- Combine landscape plan with storm-water management to provide surface water filtration and aesthetic benefits.
- Non-native turf needs about 35 inches of water per year to thrive, whereas native turf needs much less water per year.
- In areas where water shortages are common, xeriscape (a landscaping method that uses drought-resistant plants to conserve resources, especially water) should be considered.
- If a project has exhausted all other options where the installation of grass is needed, select turf grass seed mixes that contain two or more species that have good drought tolerance. Drought tolerance should be confirmed by a qualified landscape professional or State authority, if possible. Species performance may be compared under the National Turfgrass Evaluation Program reports for various grass types:
<http://www.ntep.org/previous.htm>

RESOURCES

- Seattle Green Factor Tools- Tree List and Plant List:
- <http://www.seattle.gov/dpd/cityplanning/completeprojectslist/greenfactor/documents/>
- King County Weed Lists and Laws: Noxious Weed List, Non-Regulated Noxious Weed List, and Weeds of Concern List,
www.kingcounty.gov/environment/animalsAndPlants/noxious-weeds/laws
- Washington Native Plant list by county:
http://www.wnps.org/plant_lists/exploring_native_plants.html

3.3B LANDSCAPING

Optional 5 points

REQUIREMENTS

Provide a landscape plan (including trees, shrubs, and groundcover) showing that 100% of the plantings be native and/or adaptive species. Where possible, locate newly planted trees to provide shade in the summer and allow for solar access in the winter.

All new plants within the property boundaries must meet the following criteria:

- Must be appropriate to the site's soils and microclimate
- If providing irrigation, meet the irrigation requirements outlined in ESDS 3.4
- Have an anticipated size at maturity that will not interfere with building areas, or require topping or heavy pruning to control height and growth
- Not be noxious weeds or weeds of concern

Areas specifically dedicated to food production are exempt from this requirement and not included as landscaped area.

Adaptive plant species Definition: A non-native plant species that performs similarly to a native species in a particular region, state, ecosystem, and habitat, and that 1) can survive temperature / weather extremes in the microclimate; 2) requires little irrigation or fertilization, once established; 3) is resistant to local pests and diseases; and 4) does not displace other plants, as invasive plants do.

Native plant species Definition: A plant species that occurs naturally in a particular region without direct or indirect human actions.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach a landscape plan showing native plantings and their relation to the building(s). The map must clearly show 100% or more of the landscaped area as native and/or adaptive species.

RATIONALE-RECOMMENDATIONS-RESOURCES

See 3.3a

3.3C LANDSCAPING- SIGNIFICANT TREES

Optional up to 5 points

REQUIREMENTS

Preserve significant trees on the project site. A significant tree has all of the following qualities:

- a diameter at breast height (DBH) of nine inches or more
- adaptive
- healthy
- easy to maintain
- life expectancy of at least 10 years
- safe for residents, surrounding buildings and infrastructure: must have an anticipated size at maturity that will not interfere with building areas, or require topping or heavy pruning to control height and growth

Any combination of points below can be used from the options below, up to 5 points:

(1 point) For each tree with a diameter at breast height (DBH) of nine inches or more

(2 points) For each tree with a DBH of twelve inches or more

(3 points) For each tree with a DBH of eighteen inches or more

(4 points) For each tree with a DBH of twenty-four inches

NOTE: Do not build within the drip line or the branch overhang of the significant trees.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:
 - Identify the number of trees and DBH of each.
 - State that the project will not build within the drip line of the significant trees.
2. Attach the arborist report which evaluates each significant tree's life expectancy, health, future maintenance needs and safety.
3. Attach a brief explanation regarding the property maintenance plan for the significant trees, given the arborist report conclusions.
4. Attach a landscape plan showing existing significant trees, which trees are being preserved, and their relation to the building(s).

RATIONALE

Trees are valuable resources that provide economic, environmental and social benefits. Trees reduce the impact of stormwater runoff, improve air quality, moderate the effects of wind and temperatures, enhance the visual appearance of the community and help protect property values. Although trees can be removed and replaced with new plantings, it takes many years or decades for young trees to reach maturity and match the benefits of existing trees.

RECOMMENDATIONS

Consult a local arborist or landscape architect in the site design process to identify significant trees suitable for preservation which must have an anticipated size at maturity that will not interfere with building areas or require topping or heavy pruning to control height and growth. Ascertain the health and safety of the trees targeted for preservation, particularly if they are part of a tree stand where others are removed.

RESOURCES

- The National Tree Benefit Calculator estimates the benefits of significant trees on your site: <http://www.treebenefits.com/calculator/>
- OSU's BMP's for Tree Protection on Construction & Development Sites: http://www.dnr.wa.gov/Publications/rp_urban_treeprtctnguidbk.pdf

3.4 EFFICIENT IRRIGATION

Mandatory, if installing irrigation

REQUIREMENTS

Install an efficient irrigation system and water trees as outlined below.

Efficient Irrigation

An efficient irrigation system must include the following at a minimum:

- For all landscape planting beds and trees, use drip and/or bubbler irrigation system.
- For turf, separately zone turf based on watering needs. If using conventional rotors, multi-stream rotors, or high efficiency spray heads, the nozzles must have documented average distribution uniformity (DU) of at least 0.70.
- A zone manifold and/or timer/controller that can be programmed to control the frequency, time of day and duration of irrigation for each watering zone to minimize evaporative losses while maintaining healthy plants and obeying local regulations and water-use guidance.
- A moisture sensor controller or rain delay controller or weather-based irrigation controller designed to eliminate irrigation overwatering when plant needs are met by natural precipitation.

These irrigation requirements are mandatory only for permanent landscaping that requires regular irrigation.

Watering Trees

- Western Washington: watering tubes for trees are allowed for a period of two years.
- Eastern Washington: watering tubes for trees are allowed for a period of four years.
- Supplement watering may be allowed beyond the grace period if doing so will prevent the death of the affected tree(s).

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:
 - State that drip and/or bubbler irrigation system will be used for all landscape planting beds and trees.
 - State that turf and each type of bedding area will be separately zoned based on watering needs with a programmed zone manifold and/or timer/controller.
 - State that a controller designed to eliminate irrigation overwatering will be installed.

RATIONALE

Accurate delivery of water reduces evaporation and eliminates overspray. Proper scheduling eliminates fluctuations between wet and dry states that stress plants.

3: Location and Neighborhood Fabric

RECOMMENDATIONS

Use high-efficiency irrigation nozzles with average distribution uniformity (DU) of at least 0.70. This may include conventional rotors, multi-stream rotors, or high-efficiency spray heads, but the DU must be verified by manufacturer documentation or third-party tests.

RESOURCES

- U.S. Environmental Protection Agency, WaterSense: Efficiency Made Easy: <http://www.epa.gov/watersense/index.html> and Water-Efficient Landscaping: Preventing

3.5 SURFACE WATER MANAGEMENT

Optional up to 6 points

REQUIREMENTS

Implement a Comprehensive Stormwater Management Plan to retain rainfall. Use Table 1 to determine the required rainfall volume to retain on-site.

Comprehensive Stormwater Management Plan

1. Incorporate appropriate Low Impact Development (LID) Best Management Practices (BMPs) strategies:
 - bioretention,
 - permeable paving,
 - soil amendment,
 - evapo-transpiration,
 - infiltration
 - and/or rainwater harvesting and reuse (if your jurisdiction allows), as described in the [Stormwater Management Manuals for Eastern and Western Washington](#) and the [Technical Guidance Manual for LID in Puget Sound](#) or locally approved equivalent, whichever is more stringent.
2. Develop a season-specific maintenance plan that ensures continuous performance of the system, including clear indication of responsibility for implementing the maintenance plan.
3. For stormwater reuse systems not on a combined stormwater and sewer system, the total water reused for indoor use must not exceed 90% of the average annual rainfall.
4. Stormwater BMPs (except cisterns) must be designed to drain down within 72 hours.

Table 1.

Size Stormwater Management BMPs to retain on-site the following volumes in a 24 hour storm event:

Achievement Level	85th Percentile (2 Points)		90th Percentile (4 Points)		95th Percentile (6 Points)	
	Inches	Gals/1,000 sqft	Inches	Gals/1,000 sqft	Inches	Gals/1,000sqft
Aberdeen	0.26	160	0.34	210	0.47	290
Ellensburg	0.22	140	0.26	160	0.40	250
Longview	0.49	310	0.61	380	0.80	500
Omak	0.40	250	0.50	310	0.69	430
Pullman	0.34	210	0.42	260	0.56	350
Richland	0.19	120	0.24	150	0.32	200
Seattle	0.47	290	0.61	380	0.82	510
Spokane	0.29	180	0.37	230	0.50	310
Whidbey Island	0.26	160	0.34	210	0.47	290

Precipitation Data by location (based on most recent 20 year, 24 hour storm event data from NCDC/NOAA. Columns represent the 85th, 90th, and 95th percentile respectively)

Calculation Requirements:

Runoff volume to be retained is calculated by multiplying the total generating surface area of the project by the precipitation volume (gallons/1,000 sqft) for the appropriate rainfall event defined in Table 1. Use the location nearest your project, reflecting similar climate characteristics to the site, or follow the instructions in Appendix D to access 24 hr storm event data for your location.

- The total generating surface area of the project is the combined area (in square feet) of:
 - The project's development footprint,
 - Any other areas that have been graded, but not fully amended, so as to be effectively impervious, and
 - Any pollution-generating pervious surfaces, such as landscaping, that will receive treatments of fertilizers or pesticides.

Example: A project in Seattle, with the generating surface area of 10,000 square feet, is trying to achieve 6 ESDS points:

$$10,000/1000= 10 \times 510 \text{ gallons} = 5,100 \text{ gallons}$$

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the precipitation data location used, the appropriate rainfall event size, a site plan showing the total generating surfaces and calculated area for the project, and describe design features that will be implemented to meet the requirements, with an affidavit affirming that the design is sized to accommodate the target rainfall event - from the qualified design professional responsible for the design calculations.

RATIONALE

Reducing storm-water runoff through design and management techniques increases on-site filtration, prevents pollutants from entering waterways and reduces soil erosion. Water storage and nutrient collection processes reduce the need for irrigation and contribute to forming a healthier ecological community within the landscape.

RECOMMENDATIONS

- If a rainwater harvesting and storage strategy is considered in addition to infiltration, check with state and local governments to verify that capture and/or reuse of rainwater is permitted. If not, consider appealing local rules.
- Attempt to make use of innovative, low-impact techniques such as disconnected downspouts, permeable paving, swales, retention basins, rain gardens, sidewalk planters, xeriscaping, and nature-scaping, ecoroofs, rain barrels, and cisterns to convey, capture, infiltrate, and /or reuse stormwater.
- Strive to minimize impervious areas (surfaces that do not allow stormwater infiltration), including roofs, driveways, sidewalks, and streets, or use porous materials for such areas.

3: Location and Neighborhood Fabric

Water-permeable materials include pervious interlocking concrete paving blocks, concrete grid pavers, perforated brick pavers, and compacted gravel.

RESOURCES

- Precipitation Data by location (based on most recent 20 year, 24 hour storm event data) from [NCDC/NOAA](http://www.ncdc.noaa.gov). Columns represent the 85th, 90th, and 95th percentile respectively.
- National Oceanographic & Atmospheric Administration's National Climatic Data Center: <http://www.ncdc.noaa.gov/oa/mpp/digitalfiles.html>
- Puget Sound Partnership 2012 LID Technical Guidance Manual for Puget Sound: http://www.psp.wa.gov/downloads/LID/20121221_LIDmanual_FINAL_secure.pdf
- Department of Ecology, Stormwater Management & Design Manuals for Eastern and Western Washington: <http://www.ecy.wa.gov/programs/wq/stormwater/municipal/StrmwtrMan.html>
- U.S. Environmental Protection Agency, Low-Impact Development Design Strategies: An Integrated Design Approach: http://www.lowimpactdevelopment.org/pubs/LID_National_Manual.pdf

3.6 STORM DRAIN LABELS

Mandatory

REQUIREMENTS

Label all storm drains or storm inlets to clearly indicate where the drain or inlet leads.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state your commitment to label all storm drains and inlets.

RATIONALE

Provide a visual reminder that storm sewer inlets connect to area waterways and groundwater storages, and should not be used to dump garbage of any kind.

RECOMMENDATIONS

To provide a visual reminder that storm sewer inlets connect to area waterways and groundwater storages, use a plaque, tile, painted, or pre-cast message such as “No Dumping. Drains to [name of water source].”

RESOURCES

- Pollution Prevention Resource Center:
http://pprc.org/wp-content/uploads/2014/09/Stormwater-P2-Manual_BMP-Topic-3_Storm-Drains-and-Catch-Basins.pdf

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

WATER CONSERVATION

Water conservation translates into direct utility savings for residents and building owners and conserves a precious national resource.

4.1A WATER-CONSERVING FIXTURES

Mandatory

REQUIREMENTS

In new construction and when fixtures are replaced in rehabilitation, install WaterSense labeled toilets, showerheads and bathroom faucets, and water-conserving kitchen faucets in all units and all common space facilities with the following specifications:

- *Toilets* – 1.28 GPF (gallons per flush) or less. WaterSense labeled with MaP test performance at minimum 500g
- *Urinals*- 0.5 gpf or less, WaterSense labeled
- *Showerheads* – 2.0 GPM (gallons per minute) or less, WaterSense labeled
- *Bathroom faucets* – 1.5 GPM or less, WaterSense labeled
- *Kitchen faucets* – 2.0 GPM or less

In addition, comply with the following:

- For rehab projects, aerators may be used to meet faucet flow requirement, but they must be tamper-proof and “Pressure Compensating” to ensure consistent flow delivery across a wide range of supply pressures.
- Supply pressure may not exceed 60 PSI and should be controlled by pressure regulator if necessary. (Exempt: multifamily more than three floors).
- Compliance with ESDS 4.4 is recommended but not required.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state:
 - That the flow rates, WaterSense, and MaP performance for applicable fixtures that will be installed.
 - That a minimum of 15% of units will complete performance verification according to the requirements in ESDS 1.3a.

RATIONALE

Showers and faucets account for approximately 25 percent of indoor water use. Toilets account for approximately 30 percent of indoor water use. Saving water translates into utility savings, both by conserving water and reducing the energy required for water heating. A typical 3 person household using WaterSense faucets, showerheads and toilets, with electric hot water heating, will save about 5,100 gallons per and 400 KWh of electricity every year. That’s roughly equivalent to water used in 130 loads of laundry and to leaving a light bulb burning continuously for 10 months. (Sources: Code of Federal Regulations, March 18, 1998, Page 13307 & EPA WaterSense).

RECOMMENDATIONS

- Certain existing fixtures, such as bathroom faucets, can be retrofitted with an aerator to reduce water flow to the requisite level.
- For senior projects, consider using single-flush toilets that meet the criterion flow rates, rather than dual-flush toilets. Feedback from past projects suggests that senior populations may be unsure of the dual-flush technology, which may lead to their having difficulty in operating the toilets in an effective and appropriate way.
- Dual-flush toilets have an average flow rate calculated and provided by the manufacturer. However, if you are not able to locate this information on the packaging, use a 2:1 ratio for low-volume flush to high-volume flush to determine the average flow rate.

For example, with a dual-flush toilet that has a 0.8 low-volume flush and a 1.6 high-volume flush, the calculation to determine the average would be:

$$\frac{(0.8 \text{ gpf} \times 2) + (1.6 \text{ gpf} \times 1)}{3} = 1.067 \text{ gpf}$$

- For all single-family homes and all dwelling units in buildings three stories or fewer: The static service pressure must not exceed 60 pounds per square inch (psi) (414 kilopascal [kPa]). For units in multifamily buildings, the service pressure within each unit must not exceed 60 psi. Compliance for homes supplied by groundwater wells shall be achieved by use of a pressure tank. Compliance for single-family homes with publicly supplied water may be achieved by one of the following methods:
 - Use of a pressure-regulating valve (PRV) downstream of the point of connection. All fixture connections shall be downstream of the PRV.
 - Determination that the service pressure at the home is 60 psi or less at the time of inspection and documentation from the public water supplier that service pressure is unlikely to regularly exceed 60 psi at the home on a daily or seasonal basis.
- Piping for fire sprinkler systems is excluded from this requirement and should comply with state and local codes and regulations.

RESOURCES

- To search for toilets that meet the required MaP test performance: <http://www.map-testing.com/about/maximum-performance/map-search.html>
- Like Energy Star, the WaterSense label makes it easy for consumers to recognize products and programs that save water without sacrificing performance quality. Independent, third-party licensed certifying bodies certify that products meet EPA criteria for water efficiency and performance by following testing and certification protocols specific to each product category. Products that are certified to meet EPA specifications are allowed to bear the WaterSense label. http://www.epa.gov/watersense/about_us/watersense_label.html

4.1B ADVANCED WATER-CONSERVING FIXTURES

Optional up to 6 points, new construction must also achieve 4.4 to claim points for 4.1b

REQUIREMENTS

Install WaterSense labeled toilets, showerheads and bathroom faucets and water-conserving kitchen faucets in all units and all common space facilities with the following specifications:

- Toilets (2 points) – 1.1 GPF (gallons per flush) or less, or a toilet with dual flush, one of the options being less than 1 GPF, 500gWaterSense labeled
- Showerheads (2 points) – 1.75 GPM (gallons per minute) or less, WaterSense labeled
- Bathroom faucets (1 points) – 1 GPM or less, WaterSense labeled.
- Kitchen Faucets (1 points) -1.75 GPM or less
- For New constructions projects, you must comply with optional 4.4 to gain these optional points.

In addition, comply with the following:

- For rehab projects, aerators may be used to meet faucet flow requirement, but they must be tamper-proof and “Pressure Compensating” to ensure consistent flow delivery across a wide range of supply pressures.
- Supply pressure may not exceed 60 PSI and should be controlled by pressure regulator if necessary. (Exempt: multifamily more than three floors).
- Compliance with ESDS 4.4 is required.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state:
 - That the flow rates, WaterSense, and MaP performance for applicable fixtures that will be installed.
 - That a minimum of 15% of units will complete performance verification according to the requirements in ESDS 1.3a.
 - That the project will comply with ESDS 4.4.

RATIONALE

Water conservation translates into direct utility savings for residents and building owners and lowers infrastructure costs associated with stormwater management and water treatment facilities.

RECOMMENDATIONS

- High Efficiency Toilets (HETs) are toilets that use 1.3 GPF or less. These include dual flush toilets that are rated based on the average flush volume of the two settings. Both single and dual flush toilets are now available with flush volumes as low as 1 GPF. The

4: Water Conservation

WaterSense label will be on HETs that are certified by independent laboratory testing to meet rigorous criteria for both performance and efficiency.

- Certain existing fixtures, such as bathroom faucets, can be retrofitted with an aerator to reduce water flow to the requisite level.
- For senior projects, consider using single-flush toilets that meet the criterion flow rates, rather than dual-flush toilets. Feedback from past projects suggests that senior populations may be unsure of the dual-flush technology, which may lead to their having difficulty in operating the toilets in an effective and appropriate way.

4.2 WATER METERING

Optional new construction 2 points, Rehab 4 points

REQUIREMENTS

Meter or sub-meter each dwelling unit with a technology capable of tracking water use. Also separately meter outdoor water consumption (deduct meter). For rehab only, if each dwelling unit is not feasible, provide an optimal measuring proposal.

Single-Family buildings:

Install a whole-house water meter. Attached single-family homes may share a whole-building water meter if their irrigation is also commonly metered. Homes that use only well water and are not connected to a municipal water system are exempt from this measure.

Multifamily buildings:

Install a water meter or sub-meter for each of the project's dwelling units; OR
For multifamily projects with riser-fed systems, install a water meter or sub-meter for each of the project's risers rather than for each of the project's dwelling units.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach a description of how sub-meter data will be tracked, who will be responsible for monitoring it, and how the data will be used (direct billing or back-charging residents for water/sewer costs, providing consumption feedback for conservation assistance, leak detection and isolation, etc.)
2. For rehab only, if metering each dwelling unit is not feasible, attach an optimal measuring proposal.

RATIONALE

Individual metering or sub-metering of each unit allows building managers and residents to understand and better manage their water use. Monitoring individual units also enables property managers to more easily identify and manage potential issues such as leaks that might be occurring within a specific unit.

RECOMMENDATIONS

- As a first step, when designing the plumbing system for a multifamily building, consider supplying each unit with a single pipe source for the water to facilitate individual unit sub-metering. This will reduce costs associated with having to install multiple meters for several points of use attached to a single riser pipe.

4: Water Conservation

Second, choose equipment that is best suited for accurately measuring water use in each unit. Because water use within individual units will fluctuate between low and peak flows, depending on the unit's occupancy and the time of day, positive displacement meters are often the best option. Also, work with the meter manufacturer to select an appropriately sized sub-meter. It is critical to understand both the building's and the individual units' size, function, fixture types, usage occupancy and peak population in order to select an appropriately sized meter. These statistics determine the minimum and maximum flow rates and will assist in the selection of a properly sized water meter for each unit.

- Follow manufacturers' instructions closely so that proper installation can occur. Improper installation can lead to metering inaccuracies. In general, meters (including sub-meters for individual units) should be installed in an accessible location to allow for reading and repair. In addition, the meter location should be protected from potential damage. To ensure uniform flow entering and exiting the meter, the meter should be located where there is sufficient length of straight pipe above and below the meter. Also, install a strainer to prevent debris and sediment from entering the meter and causing reading inaccuracies.
- Several options exist for monitoring water use on a per-unit basis. Meters are typically owned by the water purveyor and represent separate accounts. In order to be separately metered, each unit must typically represent a wholly separate plumbing system attached to the main line. Sub-metering typically involves using smaller meters to monitor the different uses of water under a single account. Several alternative technologies are emerging that give property managers the ability to track water use on a per-unit basis without installing physical meters or sub-meters for each unit.

RESOURCES

- American Water Works Association Offers information and articles on sub-metering: <http://www.awwa.org/>
- California Apartment Association has articles on sub-metering: www.caanet.org
- California Urban Water Conservation Council has articles on submetering: <http://www.cuwcc.org/>
- WaterSense-labeled New Homes: http://www.epa.gov/watersense/new_homes/
- Alliance for Water Efficiency, 2010, "Submetering Introduction." <http://www.allianceforwaterefficiency.org/submetering.aspx>
- "Water-Meter Selection and Sizing," Smith, Timothy A. April 22, 2008. <http://www.park-usa.com/skins/park/homepage.aspx?elid=71&arl=108>

4.3 WATER REUSE

Optional up to 12 points: Up to 4 points for Option #1 and up to 8 point for Option #2

REQUIREMENTS

Install rainwater and greywater reuse strategies listed below. Choose Option #1 AND/OR #2.

Option #1 (up to 4 points):

1. Infrastructure Pre-plumbing Supply (2 points):

Install purple (reclaimed water) supply plumbing for cold water to laundry facilities, and design plumbing layout so these lines can be hooked up to the potable supply initially, but may be transferred to a non-potable supply in the future so that harvested rainwater or treated greywater may be supplied to these fixtures in the future without significant disturbance of building structure. For projects with common, rather than in-unit laundry, the purple pipe should serve all laundry rooms. For project with in-unit laundry, the purple pipe must serve at least 30% of the units.

2. Wastewater plumbing of grey water (2 points):

- Design wastewater plumbing to keep grey water from all central laundry facilities separate from all other wastewater. Grey water collector should pass through a location where it may be tapped in future for treatment and reuse (for irrigation or indoor non-potable supply). Grey and black water should only be combined immediately before exiting the building to the sanitary sewer.

---OR---

- Design wastewater plumbing to keep at least 30% of in-unit laundry facilities separate from all other wastewater. Grey water collector should pass through a location where it may be tapped in future for treatment and reuse (for irrigation or indoor non-potable supply). Grey and black water should only be combined immediately before exiting the building to the sanitary sewer.

Option #2 (up to 8 points): Harvest, treat, and reuse rainwater and/or greywater:

1. Harvest, treat, and reuse rainwater and/or greywater to meet a portion of the project's water needs. Determine the total water needs including all exterior and interior water use. Provide the defined percentage of the project's total water needs supplied by rainwater and /or greywater. Use the table below to determine the appropriate number of optional points:

Total water needs supplied by rainwater and/or greywater	Optional points awarded
5%	1 points
10%	2 points
20%	4 points
30%	6 points
40%	8 points

EVERGREEN PROJECT PLAN REQUIREMENTS

1. For Option #1: On the EPP form, state how the design will meet the requirement; how these details will be communicated to the plumbing contractor; and how they will be verified as compliant at construction.
2. For Option #2: State the percentage of the project's water needs that will be supplied by rainwater and/or greywater. Also, attach an explanation of how the project's total water need was determined and describe the design features (including cistern sizing calculation) that will be implemented to achieve the stated percentage.

RATIONALE

Rainwater and greywater reuse strategies reduce the need for municipal water supplies and sewage treatment. Water distribution in buildings tends to be embedded in structure; difficult or impossible to retrofit in a building designed to last 50 years or more. Installing the infrastructure for reusing water in the future is a solid investment in building longevity.

RECOMMENDATIONS

- An effective way to design for future use of salvaged water is to place non-potable end uses (such as toilets and clothes washers) on a separate plumbing trunk from potable uses (showers, all indoor faucets, etc.). Using purple pipe for this distribution will denote that this water is salvaged/non-potable – avoiding possible confusion between potable and non-potable lines, both current and future. This supply should pass through an area of the building where supply from a rainwater or greywater cistern can be installed and city water supply is also available for makeup. Accommodations will also be required for city water supply isolation and back-flow prevention, which will be required when the salvaged water source is installed.
- Rainwater can be harvested from impervious surfaces such as roofs and carried via gutters and downspouts to a storage tank or cistern where it can be treated or filtered for potable uses. Untreated rainwater may be used for non-potable uses.
- Greywater may be stored & treated for non-potable uses such as toilet flushing & irrigation.
- Rainwater and greywater systems are subject to state and local regulations and special requirements. In some jurisdictions, rainwater or greywater systems may not be allowed. Check with your local building code officials for requirements. If not, consider appealing local rules.
- Consider striving for beyond 20%. In some cases, employing rainwater and greywater harvesting, treatment, and reuse can provide for all of a project's water needs.

RESOURCES

- International Living Building Institute, Achieving Water Independence in Buildings: <https://ilbi.org/education/reports/oregon>. This downloadable publication explains water

4: Water Conservation

reuse systems and regulatory barriers, and provides information for those wishing to explore the possibilities of water reuse in buildings and to reform limiting regulation.

4.4 EFFICIENT PLUMBING LAYOUT & DESIGN

Optional 7 points

REQUIREMENTS

To minimize water loss from delivering hot water, the hot water delivery system shall store no more than 0.5 gallons of water in any piping/manifold between the hot water source (tank or recirculation trunk) and any hot water fixture. In addition:

- Hot water tanks must have heat traps installed on hot and cold lines (in-line or pipe bends) and 1" insulation on the first 5' or first penetration (whichever is shorter) for hot and cold lines.
- Recirculation system must have both temperature and demand controls, such that the return temperature of the recirculation loop does not drop below 100 degrees F, and a demand flow of more than 0.5 gallons per minute initiates the recirc pump until the return water temp reaches the design supply temp minus 5 degrees F.
- Recirc loop must be fully insulated with foam insulation of at least equal thickness to the nominal diameter of the pipe, but no more than 2" (or equivalent R-value if pipe is embedded in cavity insulation).
- 0.5 gallons of water represents the following maximum pipe runs from the hot water source (tank or recirculation loop) for different pipe materials and nominal sizes.

Type of Pipe	3/8"	1/2"	3/4"	1"
	Max Run (ft)	Max Run (ft)	Max Run (ft)	Max Run (ft)
K copper	75	45	22	12
L copper	60	40	20	12
M copper	60	40	18	11
CPVC	NA	50	24	15
PEX	95	50	26	16

- Plumber's scope must include language requiring compliance with the maximum pipe run requirements, based on actual run of pipe, which will be visually verified in the field.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state:
 - How the design will meet the requirement
 - How the details will be communicated to the plumbing contractor
 - How proper installation will be confirmed

RATIONALE

Efficiently designed hot water delivery systems reduce the amount of time it takes hot water to reach a fixture, saving both water and energy. Approximately 10–15% of the energy use associated with the hot water delivery system is wasted in distribution losses, and studies have shown that the average home wastes more than 3,650 gallons of water per year waiting for hot water to arrive at the point of use.

RECOMMENDATIONS

- Effective and efficient distribution of hot water requires a whole-system approach and can be challenging to many builders. Considering the hot water delivery system early in the design phase and carefully following a plumbing design can deliver superior homes and reduced installation costs.
- A hot water distribution system with less stored water in its piping will waste less water and energy. The length of piping between the water heater and each fixture, the pipe diameter and piping material can have a great cumulative impact on the efficiency of hot water delivery.
- Insulation of hot water pipes can improve the efficiency of a hot water distribution system. Insulation of hot water pipes reduces the rate of heat loss and can deliver water that is 2°F to 4°F hotter than uninsulated pipes can. Pipe sleeves made with polyethylene or neoprene foam with thicknesses of either ½ or ¾ inch are the most commonly used insulation. The pipe sleeve inside diameter should match the diameter of the pipe for a close fit. Securing insulation every one or two feet using tape, wire or cable tie will also help to fit insulation close to the pipe. Insulation should be used along the entire length of hot water pipes, including elbows and joints, but should be kept 6 inches away from the flue of gas water heaters. Insulation performs better with an R-value of R-3.0 or greater.
- Consider central core plumbing, and/or multiple stacked central core plumbing layout, locating the water heater very close to hot water fixtures.

RESOURCES

- EPA Hot Water Volume Tool: This editable tool allows project teams to design their plumbing system with a variety of materials to minimize waste in delivery.
http://epa.gov/watersense/excel/hw_volume_tool_v1.xlsm
- EPA WaterSense-labeled New Homes — Hot Water Delivery Systems.
www.epa.gov/watersense/docs/newhome_builder_resource_manual508.pdf
- EPA’s Guide for Efficient Hot Water Delivery Systems.
www.epa.gov/watersense/docs/hw_distribution_guide.pdf
- “Hot-Water Distribution Systems Part 1,” Plumbing Systems & Design, Gary Klein, Mar/Apr 2004.

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

ENERGY EFFICIENCY

Improvements in building energy performance result in utility cost savings from more efficient heating, cooling, hot water, lights and appliances, which improves residents' comfort, lowers operating costs, and provides environmental benefits.

5.1A BUILDING PERFORMANCE STANDARD- NEW CONSTRUCTION

Mandatory for new construction

REQUIREMENTS

Meet the minimum requirements of the most recent edition of the Washington State Energy Code and incorporate the following additional requirements:

Single Family Homes, duplexes, townhomes or multi-family buildings three stories or less

Obtain one additional credit from 2015 WSEC Table R406.2, Energy Credits. Or, use the 2015 WSEC section R405.3 Performance-based compliance to demonstrate an additional 7% reduction in energy use compared to code.

Multifamily buildings greater than three stories

Obtain one additional credits from 2015 WSEC Section C406—Additional efficiency package options. Or, use the 2015 WSEC section C407—Performance-based compliance to demonstrate and additional 4 % reduction in energy use compared to the code.

EVERGREEN PROJECT PLAN REQUIREMENTS

For Single Family Homes, duplexes, townhomes or multifamily buildings three stories or less:

1. On the EPP Form, state the additional credit chosen from the 2015 WSEC Table R406.2, Energy Credits.
2. OR Attach the 2015 WSEC section R405.3 Performance-based compliance cover sheet demonstrating an additional 7% reduction in energy use compared to code

Multifamily buildings greater than three stories

1. On the EPP Form, state the additional credit chosen from the 2015 WSEC C406—Additional efficiency package options.
2. OR, Attach the 2015 WSEC section C407.3—Performance-based compliance cover sheet to demonstrate and additional 4 % reduction in energy use compared to the code.

RATIONALE

This requirement will result in savings that contribute to improved home quality and homeowner comfort, and to lower energy demand and reduced greenhouse gas emissions.

RECOMMENDATIONS

Beginning with the 2015 WSEC, both the residential and commercial chapters of the energy code require applicants to select additional energy savings from a list of options. Beginning with this edition of ESDS, we are referencing the list of measures included in code to achieve additional savings.

To meet the minimum energy efficiency requirements for ESDS, each project shall select one additional option from the list. As an alternative, the applicant may use the energy simulation method included in the code to demonstrate additional energy efficiency.

The energy code options include a wide range of efficiency measures. This includes building insulation, windows, air leakage control, heat recovery ventilation, space and water heating equipment as well as renewable energy options. Using these options simplifies the adoption of additional energy efficiency as required by ESDS.

RESOURCES

Resources that support code compliance will also assist in meeting this ESDS requirement.

- For low rise residential, duplex and multifamily up to three stories, visit WSU Energy Program code support page: <http://www.energy.wsu.edu/BuildingEfficiency/EnergyCode.aspx>
- For multi-family greater than 3 stories, visit the Northwest Energy Efficiency Council web site: <http://neec.net/energy-codes>

5.1B BUILDING PERFORMANCE STANDARD- REHAB

Mandatory for all Rehab projects

REQUIREMENTS

Provide insulation and air sealing improvements as prescribed in **Appendix B**.

Three methods for addressing a successful energy efficiency strategy for rehabilitation are detailed in Appendix B. This includes a prescriptive list of measures, a method for calculating a simple 10-year payback, and a more complex savings-to-investment ratio (SIR) calculation. It is worth noting that all three methods tend to result in a similar if not identical list of energy efficiency measures. Unless there are special conditions in the existing building, it is likely that conducting a simple payback or SIR calculation will not be needed.

A typical set of improvements will include:

- Air sealing
- Wall, floor, and ceiling insulation
- Duct sealing

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the method chosen.
 - For prescriptive, attach all finished insulation levels and U values of windows and list ventilation, air sealing, and duct sealing.
 - For Simple Payback, attach the energy analysis on each of the mandatory prescriptive measures.
 - For Savings-To-Investment, attach the TREAT analysis and a list of the WX measures.

5.2A ADDITIONAL REDUCTION IN ENERGY USE- NEW CONSTRUCTION

Optional points for new construction: 5-25 points

REQUIREMENTS

Select additional efficiency measures to achieve greater energy savings. ESDS 5.1a requires each project to document additional energy savings compared to code using either the credit system or performance based compliance method. ESDS uses this same method to document additional energy efficiency credits as well. The code has a good range of options. This includes building envelop, HVAC, lighting and renewable energy systems. Adopting additional efficiency measures achieve greater savings.

The two tables below document ESDS points granted for additional reductions in energy:

Single family, duplex, townhome and multifamily up to 3 stories		
Table R406.2 Energy Credits (in addition to code requirements)	Using R405.3 Performance-based compliance (in addition to code requirements)	ESDS Points
0.5	-3%	ESDS Mandatory
1	-6%	ESDS Mandatory
1.5	-9%	5
2	-12%	10
2.5	-15%	15
3	-18%	20
3.5	-21%	25

Multifamily greater than 3 stories		
C406—Additional efficiency package options (in addition to code requirements)	C407 Performance-based compliance (in addition to code requirements)	ESDS Points
1	-3%	ESDS Mandatory
2	-6%	5
3	-9%	10
4	-12%	15
5	-15%	20
NA	-18%	25

EVERGREEN PROJECT PLAN REQUIREMENTS

1. For the prescriptive energy credits approach, attach documentation showing the energy credits used to meet code and the added energy credits to achieve additional energy savings.
2. For the performance based approach, use the analysis methodology required by code. Demonstrate that the proposed design will provide additional % reduction in energy use compared to code and ESDS 5a.

RATIONALE

For new construction, adding incremental improvements will improve energy efficiency while reducing utility and operating costs for residents and building owners. Energy conservation lessens smog, acid rain and greenhouse gas emissions.

5.2B ADDITIONAL REDUCTION IN ENERGY USE- REHAB

Optional 5 points for moderate and substantial rehab

REQUIREMENTS

Use the method in **Appendix B** for the simple 10-year payback except extend the payback period to at least 14 years.

- Include the energy improvement report done by the qualified engineer identifying energy efficiency improvements meeting the 14-year simple payback and that provide greater energy efficiency than the prescriptive measures listed in **Appendix B**.
- Specify those measures in the design and install those improvements.
- Facilitate verification during the construction process.

Note: All mandatory measures included in **5.1b** must be implemented. If new construction standards can be achieved, use the same calculation and documentation methods noted for new construction in **5.2a**.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the energy analysis identifying specific efficiency improvements meeting the 14-year simple payback that provide greater energy efficiency than the mandatory prescriptive measures. Note: If you choose this criterion, you cannot use ESDS 5.11, 5.12, 5.13.

5.3 SHADING FOR SOUTH FACING WINDOWS

Optional 4 points

REQUIREMENTS

For windows that face between 158 degrees and 202 degrees True (22 degrees either side of True South):

- 85% of glazing (by area) is shaded at 10am and 2pm, on June 21 (Pacific Standard Time) either by existing trees and adjacent structures, or by fixed shading devices attached to the building.

Project Type	Points
Stand-alone building	(4 points) Meet all guidelines
Projects w/ multiple buildings	(1 point) 25% of the homes meets all guidelines (2 points) 50% of the homes meet all guidelines (3 points) 75% of the homes meet all guidelines (4 points) 100% of the homes meet all guidelines

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach documentation that shading devices on the building will provide the described solar access and shading. Include an illustration demonstrating shading at the required date and times.

RATIONALE

Providing solar access to south facing windows can reduce the space heating loads of the building. But if they are not shaded during the most critical time periods, the solar gains can increase the cooling load. This is true regardless of window specifications or window area. This optional requirement provides a modest approach to solar control of buildings. More detailed analytical analysis can provide more robust and certain energy savings. To take credit for more robust passive solar designs, use the performance-based compliance method in ESDS sections 5.1a and 5.2a.

RECOMMENDATIONS

- Most 3d drafting programs will create a location and time based shading illustrations. This includes Google sketch-up, a free, easy to use, 3d drawing program. We recommend using these tools to create a shading illustration.
 - Sketchup: <http://www.sketchup.com/>
 - Autodesk shading instructions: <http://knowledge.autodesk.com/support/revit-products/learn-explore/caas/CloudHelp/cloudhelp/2016/ENU/Revit-Analyze/files/GUID-DC95789B-E7BA-4430-89B9-7B4C66F56684-htm.html>
- Calculation methods that provide both vertical and horizontal shading methods may be used. Several references on the development of shading models using calculation methods follow.
 - Solar Geometry, Robert A. Young, University of Utah. http://faculty.arch.utah.edu/young/TEACHING/ARCH4350F14/A4350F14_13_SolarGeometry.ppt

5.4 ENERGY STAR APPLIANCES

Mandatory for all projects providing appliances

REQUIREMENTS

If providing appliances, install ENERGY STAR-labeled clothes washers, dishwashers, and refrigerators.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state that all clothes washers, dishwashers & refrigerators will be Energy Star. Do not send in product literature or spec sheets with the EPP.

RATIONALE

In 1992, EPA introduced Energy Star, a voluntary labeling program designed to identify and promote energy-efficient products to reduce greenhouse gas emissions. Energy Star products must meet strict energy efficiency criteria set by EPA. These products reduce utility costs and greenhouse gas emissions.

5.5 CENTRAL LAUNDRY

Optional 3 points

REQUIREMENTS

Provide centralized laundry facilities. Do not install in-unit washers or dryers or hook-ups. If residential scale washers are provided in the centralized laundry facilities, they must be ENERGY STAR-labeled.

Exemption: Live-in resident manager units are exempt from this optional criterion.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state that the project will provide ENERGY STAR-labeled centralized laundry facilities and will not install in-unit washers or dryers or hook-ups. Facilitate on-site verification by the third party verifier.

RATIONALE

In-unit laundry washers use 3.3 times more water compared to centralized laundry. Energy usage of in-unit applications is close to 5 times higher compared to common area laundry rooms. (Source: 2002 Study: A National Study of Water and Energy Consumption in Multifamily Housing).

5.6 EFFICIENT LIGHTING

Mandatory

REQUIREMENTS

90% of lighting shall be fitted with LED lamps or luminaire.

Note: The 2015 WSEC requires 75% of all luminaire installed in housing to be high efficiency.

Note: Emergency exit lighting should be LED's or of similar efficiency.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state that 90% of lighting shall be fitted with LED luminaires or lamps. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Lighting accounts for between 5-10% of a home's energy use. LED lighting products have been developed for all applications and are very cost effective. Reduced energy use lowers utility costs and greenhouse gas emissions.

RESOURCES

To assure high visual and operational quality, select lighting products supported by utility programs. Utilities in Washington are relying on the qualification listing provided by the Lighting Design Lab. <https://www.lightingdesignlab.com/>

5.7A ELECTRICITY METER- NEW CONSTRUCTION

Mandatory for New Construction

REQUIREMENTS

Install an individual or a sub-metered electric meter for each individual unit.

Exceptions: Shelters, Single Room Occupancy & Designated Supportive Housing Dwelling units, Seasonal Farmworker.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On EPP form, state the commitment to install individual or a sub-metered electric meter for each individual unit.

RATIONALE

Providing information to residents on the cost and usage associated with the electricity consumption in their unit may reduce energy use.

RECOMMENDATIONS

Individual metering and /or sub-metering should be specified in the Integrative Design stage.

5.7B ELECTRICITY METER- REHAB

Optional 2 points for rehab projects

REQUIREMENTS

Install an individual or a sub-metered electric meter for each individual unit.

Exceptions: Shelters, Single Room Occupancy & Designated Supportive Housing Dwelling units, Seasonal Farmworker.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On EPP form, state the commitment to install individual or a sub-metered electric meter for each individual unit.

RATIONALE

Providing information to residents on the cost and usage associated with the electricity consumption in their unit may reduce energy use.

RECOMMENDATIONS

Individual metering and /or sub-metering should be specified in the Integrative Design stage.

5.8A RENEWABLE ENERGY

Optional up to 15 points for rehab projects

REQUIREMENTS

Install photovoltaic (PV) panels, wind turbines, or other electric-generating renewable energy source to provide a specified amount of energy generation.

ESDS points are awarded based on the system kWh of production per year / conditioned floor area. Very small systems are discouraged by the standard. All systems must provide at least 1200 kWh year production.

kWh/SF/Year	ESDS Points
0.14	1
0.28	2
0.42	3
0.56	4
0.7	5
0.84	6
0.98	7
1.12	8
1.26	9
1.4	10
1.54	11
1.68	12
1.82	13
1.96	14
2.1	15

Note: For New Construction, use ESDS 5.1a & 5.2a to document renewable energy systems

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the renewable energy source.
2. For solar electric systems, attach the design demonstrating this requirement using the National Renewable Energy Laboratory calculator PVWATTS. Documentation noting solar access shall be included on the plans.
3. For wind generation projects, attach designs documenting annual power generation based on the following factors: The wind turbine power curve; average annual wind speed at the site; frequency distribution of the wind speed at the site and height of the tower.

RATIONALE

Use of renewable energy reduces environmental impacts associated with utility energy production and use. These impacts include natural resource destruction, air pollution, greenhouse gas emissions and water pollution. Use of onsite renewable energy technologies, such as PV panels, can also result in energy cost savings.

RESOURCES

- National Renewable Energy Laboratory, P.V. WATTS
<http://www.nrel.gov/rredc/pvwatts/grid.html>
- National Renewable Energy Laboratory, Small Wind for Homeowners, Ranchers, and Small Businesses
http://www.windpoweringamerica.gov/small_wind.asp

5.8B PHOTOVOLTAIC/SOLAR HOT WATER READY

Optional 1 point

REQUIREMENTS

Site, design, engineer, and/or plumb the development to accommodate installation of photovoltaic (PV) or solar hot water system in the future.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, explain the plan including orientation, unobstructed exposure, conduit route and location of terminations.
2. Attach the design and engineering analysis that establishes the parameters of the installation that demonstrate the following:
 - Buildings are oriented to permit access to sunlight.
 - Architectural elements to optimize solar capture have been included in the roof design, including placement of HVAC and other equipment
 - Unobstructed roof areas where panels can be placed have been reserved
 - The roof has been engineered such that it will support the weight of the eventual PV installation. This includes the panel mounting system, as well as wind and snow loads as appropriate to the location
 - Conduit meeting code for PV will be run from the designated PV location to a central panel, as part of the general electrical work.
 - Space has been reserved, in an appropriate location, for the necessary PV system infrastructure (including inverters, disconnects, meters, etc.), as dictated by local code and utility requirements
 - No wire will be installed inside the conduit until the photovoltaic panels are installed.

RATIONALE

Generating and using renewable energy in a development is a hedge against rising costs for purchased energy. Further, it avoids the environmental impacts associated with conventional power generation: natural resource destruction, air and water pollution, and greenhouse gas production.

RECOMMENDATIONS

Building “PV Readiness” into a project reserves the opportunity to install a system later when resources become available.

5.8C SOLAR WATER HEATING

Optional up to 10 points for rehab projects

REQUIREMENTS

Provide domestic water heating using solar collectors. The system must meet the following requirements:

- The collectors or system must be rated and certified by the Solar Rating and Certification Corporation (SRCC). <http://www.solar-rating.org/> For listed systems the energy output shall be determined by the SRCC listing for the most appropriate Washington location, (currently Seattle, Spokane or Yakima) OR
- For built up systems, the energy output shall be determined by the ASHRAE methodology documented on the SRCC web site

Points: Projects will be awarded 1 point for every 5% of annual domestic hot water usage provided by solar collectors, up to 10 points:

1 point for 5%	6 points for 30%
2 points for 10%	7 points for 35%
3 points for 15%	8 points for 40%
4 points for 20%	9 points for 45%
5 points for 25%	10 points for 50%

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the plan for the size and type of solar water heating system including
 - the mounted orientation,
 - the annual performance,
 - how it supplies the annual percentage of domestic hot water,
 - how it was calculated,
 - and SRCC product information.

RATIONALE

Solar Hot Water systems can be a cost effective way to use the sun's energy to help meet domestic water needs.

RESOURCES

- SRCC ratings may be obtained from <http://www.solar-rating.org/index.html> For listed systems, go to the "Ratings" web page and input "system" and "Location" to obtain system output, system diagrams and certifications for the most appropriate Washington location.

<https://secure.solar-rating.org/Certification/Ratings/RatingsSummaryPage.aspx?type=2>

Welcome to the SRCC Rating Pages. Please select either collector or system below to continue.

Collector Or System:
System ▼

Number:

Request Type: Select Request Type ▼

Company: Select Company Name ▼

Backup Source: -Please Select- ▼

Name: Select Brand Name ▼

Unit: METRIC ▼

Location: WA - Yakima ▼

Annual Rating using hourly weather data for the chosen city:
 SEF_A = Solar Energy Factor ([more info](#))
 SF_A = Solar Fraction ([more info](#))
 Energy Savings = Estimated annual energy saved compared to a conventional water heater using the same type of backup

- Larger built up systems will require the development of an engineered design. Refer to the SRCC “commercial” page for methodology.

<http://www.solar-rating.org/commercial/index.html>

5.9 DOMESTIC WATER HEATING

Mandatory

REQUIREMENTS

Residential Water Heaters: Shall meet federal minimum standards in effect April 2015.

Commercial Water Heaters: Shall meet the minimum code requirements published in the 2015 WSEC.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the type of fuel, tank size, energy factor, and standby loss as applicable. Do not send in product literature or spec sheets with the EPP.

5.10 DOMESTIC WATER HEATING

Optional 2-5 points for rehab projects

REQUIREMENTS

Select a Residential Energy Star Water Heater.

In-Unit System	Efficiency	Points
Gas Storage	< 55 Gal. EF \geq 0.67 > 55 Gal. EF \geq 0.77	2
Whole-Home Gas Tankless	EF \geq 0.90	5
Electric Storage Water Heaters (Heat Pump)	< 55 Gal. EF \geq 2.0 > 55 Gal. EF \geq 2.2	5

Central System	Efficiency	Points
Gas Boiler or Water heater	90% AFUE or 0.90Et	5
Heat Pump (reverse cycle chiller)	COP 3 or greater	5

Note: For new construction of single family/duplex/townhomes, use ESDS 5.2a to demonstrate energy savings associated with superior performance domestic water heating.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state the type of fuel, type of equipment, and energy rating. Do not send in product literature or spec sheets with the EPP.

RECOMMENDATIONS

- Equipment that provides superior performance above the mandatory requirements is readily available.
- For individual housing units with gas/propane/oil, the on-demand water heaters are recommended.
- Large central water heating systems should choose condensing boiler equipment.
- For homes with only electric energy, heat pump water heaters are available.
Caution: heat pump water heaters should not be installed in the conditioned living space or in a confined space.

RESOURCES

Go to the Energy Star Web site and select from the list of certified products.
<https://www.energystar.gov/products/certified-products/>

5.11 PERFORMANCE TESTED BUILDING AIR SEALING

Optional 3 or 7 points for Rehab

REQUIREMENTS

In addition to the prescriptive air sealing measures (see Appendix B), conduct a blower door air sealing protocol that achieves the following performance objectives.

- For single family homes, the test will be conducted on the entire building.
- For multi-family buildings, the test will be conducted on individual dwelling units. At a minimum a sample of units shall be selected to represent both corner and central dwelling units on each floor. All tested units need to meet the minimum standard.

(3 points) Through performance testing, document that the unit air tightness level is less than 7 ACH 50.

(7 points) Through performance testing, document that the unit air tightness level is less than 5 ACH 50.

Testing

The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding the specified air changes per hour. Testing shall be conducted with a blower door at a pressure of 0.2 inches w.g. (50 Pascals). A written report of the results of the test shall be signed by the party conducting the test and be included in project documentation. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures;
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures;
3. Interior doors, if installed at the time of the test, shall be open, access hatches to conditioned crawl spaces and conditioned attics shall be open;
4. Exterior openings for continuous ventilation systems and heat recovery ventilators shall be closed and sealed;
5. Heating and cooling systems, if installed at the time of the test, shall be turned off; and
6. Supply and return registers, if installed at the time of the test, shall be fully open.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state the category of points chosen and provide performance testing documentation, calculations, and explanation as soon as available. State the estimated date the information will be submitted.

RATIONALE

This section provides credit for the verification of intent. The required prescriptive air sealing and duct sealing should have resulted in an air leakage rate of 7 ACH50 or less.

5 ACH50 is an air leakage rate similar to new construction. Additional points are granted for achieving this level of savings in a rehabilitation project.

RECOMMENDATIONS

For guidance on air leakage control and possible testing equipment, see the following links:

- A Do-it Yourself Guide to Energy Star® Home Sealing: http://www.energystar.gov/ia/partners/manuf_res/salestraining_res/HS_diy_guide.pdf
- Infiltec Test Equipment: <http://www.infiltec.com/inf-catb.htm>
- The Energy Conservatory Test Equipment: <http://www.energyconservatory.com/>

5.12 PERFORMANCE TESTED DUCT SEALING

Optional 10 points for Rehab

REQUIREMENTS

Conduct Performance Tested Duct Sealing:

- Test is to be conducted by an Energy Star, Climate Crafters, or equivalent independent third party organization Certified Technician or Inspector.
- Duct leakage shall not to exceed 0.10 CFM50 x floor area (in square feet) served by the system,

-OR-

It shall be reduced by 50% by comparing leakage to the outside before and after sealing.

- Based on the protocol for “Combustion Appliance Zone Pressure Testing” forced air system operation shall not depressurize a combustion appliance zone by more than 3 Pascals.
- When combustion appliances are located within a conditioned space, a UL listed carbon monoxide alarm must be installed unless the appliance has a type IV venting system.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state the commitment to test and provide the performance testing documentation, calculations, and explanation as soon as available. State the estimated date the information will be submitted.

RATIONALE

This section sets performance goals listed for duct sealing beyond the prescriptive requirements.

RECOMMENDATIONS

For guidance on duct sealing and possible testing equipment, see the following links:

- Thermal Energy Distribution: <http://ducts.lbl.gov/>
- Infiltec Test Equipment: <http://www.infiltec.com/inf-catb.htm>
- The Energy Conservatory Test Equipment: <http://www.energyconservatory.com/>

5.13 SPACE HEATING & COOLING EQUIPMENT REPLACEMENT

Optional 2, 5, or 7 points for Rehab

REQUIREMENTS

Install Space Heating and Cooling Equipment Replacement to the following standards.

Electric Resistance Heating, Baseboard or wall heaters (**7 points**): Add a ductless heat pump 1 ton or greater.

Electric Resistance Heating in a Forced Air Furnace (**7 points**): Upgrade electric resistance forced air furnace to Energy Star compliant furnace or heat pump.

Other Central Heating Equipment (**5 points**): During equipment replacement, choose Energy Star central heating equipment, including boilers, furnace or heat pumps.

Heat Pump Performance Testing (**2 points**):

- The air distribution system design and installation shall be such that air flow across the indoor coil is as specified in the heat pump manufacturer's literature, or is between 350 and 425 cubic feet per minute (CFM) per 12000 BTU/hr output at ARI rating conditions.
- Using a qualified contractor, test and verify the system meets the Performance Tested Comfort Systems (PCTS) requirements. See this web site for a list of qualified contractors: <http://www.ptcsnw.com/FindContractor.aspx>

Note: In order to claim these points, all ducts must be mechanically fastened, sealed with mastic, and insulated.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state the option chosen, how ducts will be fastened and sealed, and what insulation level will be installed. State that only Energy Star equipment will be used or provide the Heat Pump Performance Testing as soon as available. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Improving equipment efficiency at time of equipment replacement is very cost effective for all but a few applications. This section provides points for increasing the energy efficiency in existing housing using equipment upgrades.

RECOMMENDATIONS

- For combustion appliances, examine combustion venting needs before selecting

- equipment.
- For heat pumps, make sure the existing duct work has enough cross sectional area for the equipment.

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

MATERIALS

Purchasing green materials and recycling and reusing materials whenever possible can improve conditions for resident health, enhance project durability, and reduce waste and disposal costs.

6.1 Low/No VOC PAINTS & PRIMERS

Mandatory

REQUIREMENTS

All interior paints and primers must have volatile organic compound (VOC) levels, in grams per liter, less than or equal to the thresholds established by South Coast Air Quality Management District (SCAQMD) Rule 1113. Projects must follow the most recent revision available at time of product specification. For the latest rules: www.aqmd.gov/home/regulations/rules.

As of July 1, 2013, SCAQMD Rule 1113 thresholds are listed as:

Paint Type	Maximum VOC Limit
Coatings, Flats & Non-flats	50 g/L
Primer or Undercoat & Sealers	100 g/L
Opaque Floor coatings	50 g/L
Rust preventive coatings	100 g/L
Clear Wood Finishes	275 g/L

This table does not include colorant added at the point of Sale. If colorant is added at point of Sale, the VOC content of the colorant should not exceed 50 g/L for all paint types, except anti-corrosives at 150 g/L.

NOTE: These requirements do not apply to finishes that are factory applied or applied off site, except in modular construction

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that all interior paints and primers will meet the standard. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Interior paints and primers may release VOCs, particularly when wet. Exposure to individual VOCs and mixtures of VOCs can cause or aggravate health conditions, including allergies, asthma, and irritation of the eyes, nose, and airways; however, no health-based standards for indoor non-occupational exposure have been set.

RECOMMENDATIONS

- Allow a two week flush out period at turnover.

6.2 Low/No VOC ADHESIVES & SEALANTS

Mandatory

REQUIREMENTS

All adhesives & sealants (including caulks) must have volatile organic compound (VOC) levels, in grams per liter, less than or equal to the thresholds established by the South Coast Air Quality Management District Rule 1168. Projects must follow the most recent revision available at time of product specification. See: <http://www.aqmd.gov/home/regulations/rules> for latest rule.

NOTE: Exempt from this criteria are adhesives, caulks and sealants that are:

- used outside of the weather resistive barrier or
- used to seal the weather resistive barrier to itself or
- used to seal the weather resistive barrier to building openings

The weather resistive barrier includes the roof membrane.

As of January 7, 2005, SCAQMD Rule 1168 thresholds are listed as:

VOC LIMIT PRODUCT TYPE	(G / L)
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesives	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT And Asphalt Tile Adhesives	50
Drywall And Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single-Ply Roof Membrane Adhesives	250
Structural Wood Member Adhesive	140
Architectural Sealants, Including Caulk	250

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that all interior adhesives will comply with the most recent version of Rule 1168 of the South Coast Air Quality Management District. Do not send in product literature or spec sheets with the EPP.

RATIONALE

VOCs may pose health hazards to residents and workers. Use of low-VOC adhesives and sealants will reduce the concentration of such airborne chemicals.

RESOURCES

- U.S. Department of Energy, National Renewable Energy Laboratory, “Weatherize Your Home — Caulk and Weather Strip”: www.nrel.gov/docs/fy01osti/28039.pdf
- 2012 IECC Climate Zones Map: A detailed map that shows Climate Zones zoomed into each state and county as well as the basic 2012 IECC Building Code requirements for each Climate Zone (see the Appendix).

6.3 CONSTRUCTION WASTE MANAGEMENT

Up to 5 points

REQUIREMENTS

Reduce the amount of waste sent to the landfill. Choose one of the following methods.

Method #1- Measured by percentage

- Provide a waste plan that diverts 50% of the construction waste from the landfill. Provide receipts demonstrating compliance with the plan. (2 Points)
- Provide a waste plan that diverts 75% of the construction waste from the landfill. Provide receipts demonstrating compliance with the plan. (5 Points)

Method #2 – Material Specific (construction waste and demolition debris). Provide receipts demonstrating compliance. (up to 5 Points)

- Recycle all cardboard (1 Point)
- Recycle all wood (1 Point)
- Recycle all drywall (1 Point)
- Recycle all metals (1 Point)
- Recycle all concrete, brick, and asphalt (1 Point)
- Develop & implement a comprehensive advanced framing plan that minimizes all waste by design (5 Points)

Method #3- Minimizing Construction Waste (New Construction only). Provide receipts demonstrating compliance.

- Total Construction Waste to Landfill or Incinerator < 2.5 lbs / SF of building (2 Points)
- Total Construction Waste to Landfill or Incinerator < 1.5 lbs / SF of building (5 Points)

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:
 - State the method chosen.
 - State that the approved contractor submittal of the construction waste plan will be available on the job site detailing how reusable/recyclable materials are redirected from the landfill and where each material goes.
 - State that waste receipts will be available on the job site.

RATIONALE

The amount of job-site waste resulting from construction of the average U.S. home is 4 pounds per square foot of conditioned space, totaling about 8,000 pounds and taking up 50 cubic yards of landfill space. To the extent possible, waste should be avoided because 1) landfill space is rapidly diminishing, 2) incineration produces pollutants, and 3) waste of materials is in itself a

negative environmental impact. Source: National Association of Home Builders Research Center, 2001,

<http://www.toolbase.org/ToolbaseResources/level3.aspx?BucketID=5&CategoryID=26>

RESOURCES

- See the following for more information on advanced framing:
http://apps1.eere.energy.gov/buildings/publications/pdfs/building_america/26449.pdf

6.4 ENVIRONMENTALLY PREFERABLE MATERIALS

Up to 10 points

REQUIREMENTS

Use environmentally preferable materials and/or materials that are produced (extracted, harvested, manufactured and processed) within 500 miles of the construction site. Use the table below to determine the required specifications. Products that meet the EPP specification receive 0.5 point and/or 0.5 point if produced locally. Projects can receive a maximum of 10 points.

Assembly	Component (0.5 point per component)	Environmentally Preferable Materials (EPM) Specifications	Local production (0.5 point component)
Exterior wall	Framing/wall structure	Concrete wall structure: Use 20% fly ash or slag. Wood structure: FSC-certified or reclaimed or finger joint studs	Eligible
	Siding or masonry	Recycled content, reclaimed, or FSC-certified	Eligible
	Aggregate	Recycled content	Not Eligible
Flooring	Flooring-50% (0.5 point awarded for meeting the EPM specification for 50% of the floor area).	Linoleum, cork, bamboo, FSC-certified or reclaimed wood, sealed concrete, recycled-content flooring, or combination.	Eligible –projects will be awarded 0.5 point total if 50% or more of the floor area is produced locally.
	Flooring- 75% (1 point awarded for meeting the EPM specification for 75% of the floor area).		
	Flooring -100% (1.5 point awarded for meeting the EPM specification for 100% of the floor area).		
	Framing	FSC-certified or reclaimed	Eligible
Foundation	Aggregate	Recycled aggregate	Eligible
	Cement	Use 20% fly ash or slag	Eligible
Interior walls AND ceilings	Framing	FSC-certified or reclaimed	Eligible
	Gypsum board	N/A	Eligible
	Paints and coatings	Recycled paint that meets Green Seal standard GS-43	Not Eligible
Landscape	Decking or patio material	Recycled content, FSC-certified, or reclaimed	Eligible
Interior Finishes	Cabinets	Recycled content, FSC-certified, or reclaimed and composite materials must contain no added urea-formaldehyde resins	Eligible, hardware and fasteners excluded

6: Materials

	Counters (kitchens and bathrooms)	Recycled content, FSC-certified, or reclaimed AND composite materials must contain no added urea-formaldehyde resins	Eligible
	Doors(not including garage or insulated doors)	Recycled content FSC-certified or reclaimed	Eligible
	Trim	Recycled content, FSC-certified, or reclaimed AND composite materials must contain no added urea-formaldehyde resins	Eligible
Exterior Wall	Window framing	Recycled content, FSC-certified. Or reclaimed	Eligible
Roof	Framing	FSC-certified	Eligible
	Roofing	Recycled content	Eligible
Envelope	Insulation	Recycled content of 20% or more	Eligible
	Sheathing	Recycled content FSC-certified. Or reclaimed	Eligible

EVERGREEN PROJECT PLAN REQUIREMENTS

1. Attach the list of environmentally preferable materials that will be used and note the specification requirement and/or the local production requirement. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Use of building materials with recycled content reduces the negative environmental impact resulting from extraction and processing of virgin materials. Building materials that are extracted, harvested, processed, and manufactured locally to the project site minimize the energy embedded in their transportation and contribute to the local economy.

RESOURCES

- GreenSpec Directory, Building Green: <http://www.buildinggreen.com/>
The online GreenSpec® Directory lists product descriptions for more than 2,000 environmentally preferable products.

6.5A REDUCED HEAT-ISLAND EFFECT: ROOFING

Optional 2 points

REQUIREMENTS

Choose one of the following options:

- Option #1 (**2 points**) - Use an ENERGY STAR–certified roofing product for 100% of the roof area.
- Option #2 (**2 points**) - Install a “green” (vegetated) roof for at least 50 percent of the roof area.
- Option #3 (**2 points**) - Combinations of ENERGY STAR–certified roofing product and vegetated roof can be used, providing they collectively cover 75 percent of the roof area.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state which option is chosen.
2. Attach roof map showing all roofing areas with the type of roof specified. Clearly label and indicate on the map the areas specific to this criterion

RATIONALE

Urban heat islands disturb the atmosphere and cause energy waste by increasing loads on cooling systems. Heat islands create thermal gradient differences between developed and undeveloped areas. Using roof surfaces that do not retain heat reduces the heat island.

Energy Star Reflective Roofing may reduce energy use in the warmer regions of Washington State. Green Vegetated Roofing may also reduce energy use and provide desirable storm water retention.

RECOMMENDATIONS

Energy Star Reflective Roofing may or may not provide energy saving benefits in Washington. A reflective roof will reduce cooling cost, but may slightly increase heating cost in ceilings or attics with lower levels of insulation. To demonstrate that the application of an Energy Star roof provides energy savings and financial benefit, use the Roof Savings Calculator: <http://www.roofcalc.com/>

RESOURCES

- Resources and information on green roofs can be found at:
[Greenroofs 101](#)
[Scandinavian Green Roof Institute](#)
- Energy Star Roof Products:
http://www.energystar.gov/index.cfm?c=roof_prods.pr_roof_products
- Design green vegetated roofing in accordance with the following ASTM standards:
[E2396-05 Standard Test Method for Saturated Water Permeability of Granular Drainage Media \[Falling-Head Method\] for Green Roof Systems](#)
[E2397-05 Standard Practice for Determination of Dead Loads and Live Loads associated with Green Roof Systems](#)
[E2398-05 Standard Test Method for Water Capture and Media Retention of Geocomposite Drain Layers for Green Roof Systems](#)
[E2399-05 Standard Test Method for Maximum Media Density for Dead Load Analysis of Green Roof Systems](#)
[E2400-06 Standard Guide for Selection, Installation, and Maintenance of Plants for Green Roof Systems](#)

6.5B REDUCED HEAT-ISLAND EFFECT: PAVING

Optional 2 points, if providing paving

REQUIREMENTS

Use light-colored/high-albedo materials and/or an open-grid pavement, with a minimum Solar Reflective Index of 30 over at least 50 percent of the site's hardscaped area.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form:
 - State that light-colored/high-albedo materials and/or an open-grid pavement, with a minimum Solar Reflective Index of 30 over at least 50 percent of the site's hardscaped area will be used.
2. Attach a map of all paved areas showing the portion that will reduce the heat-island effect and the type of material.

RATIONALE

Urban heat islands have increased local air temperatures due to the absorption of solar energy by the built environment. They increase energy consumption by increasing loads on cooling systems. Heat islands create thermal gradient differences between developed and undeveloped areas. Use paving surfaces that do not retain heat and that reduce the heat island effect.

6.6 SOCIALLY SUSTAINABLE PRODUCTS

Optional up to 3 points

REQUIREMENTS

Choose building products from local manufactures (within 500 mile radius) that support a broader socially sustainable mission, outside of their environmental mission, including the safety and health of their own workers.

An example would be a product manufacturer who hires laborers with developmental disabilities. One point is given for each manufacturer of a product type and 90% (by cost) of that product is used in the project, up to 3 points.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that socially sustainable products that will be used. And that documentation will be provided to Commerce after construction bid.
2. Attach an explanation of each manufacturer, the product used in the project, and how they support a broader socially sustainable mission. Provide a website supporting your information or written documentation from the manufacturer with their contact information.

RATIONALE

Social sustainability is about creating and maintaining quality of life for all people. Like public affordable housing, the marketplace also plays a vital role in supporting socially sustainable communities. Human development and the achievement of human potential require a form of economic activity that is environmentally and socially sustainable in this and future generations. (Source: CPHA, 1992 Canadian Public Health Association).

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

**7 Healthy Living
Environment**

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

HEALTHY LIVING ENVIRONMENT

Reducing contaminants and optimizing ventilation improve indoor air quality and project durability, and universal design and active design measures promote physical mobility.

7.1 COMPOSITE WOOD PRODUCTS THAT EMIT LOW/NO FORMALDEHYDE

Mandatory

REQUIREMENTS

All composite wood products exposed to the interior (inside the weather resistive barrier), including particle board, plywood, OSB, MDF, cabinetry, and any other applicable wood product, must be certified as compliant with California 93120 Phase 2 (CARB Phase 2).

Or, if using a composite wood product that does not comply with California 93120 Phase 2 (CARB Phase 2), all exposed edges and sides must be sealed with low-VOC sealants, per Criterion 6.2.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that all particleboard, plywood, OSB, medium density fiberboard, cabinetry and any other applicable wood products will be compliant with CARB Phase 2. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Particleboard, interior grade plywood, MDF, and other composite wood products typically contain formaldehyde based glues. Formaldehyde is a volatile organic compound. Symptoms of exposure vary widely and can include watery eyes, nausea, coughing, chest tightness, wheezing, skin rashes, allergic reactions and burning sensations in the eyes, nose and throat. In a recent report, the World Health Organization (WHO) International Agency for Research on Cancer upgraded its evaluation of formaldehyde from a probable carcinogen to a known human carcinogen based on new evidence that formaldehyde causes nasopharyngeal cancer in humans. Avoiding products with added urea formaldehyde will reduce the quantity of harmful indoor air contaminants.

RECOMMENDATIONS

- Make this requirement part of the specifications for subcontractor submittals. Obtain the manufacturer's specifications to determine whether materials meet this requirement. Seek composite wood products compliant with California 93120 Phase 2. California 93120 is a regulation issued by the California Air Resources Board (CARB) limiting allowable formaldehyde emissions from composite wood products.
- Seek composite wood products with no added formaldehyde-based compounds in the contents. Seek composite wood products with CARB No Added Formaldehyde (NAF) certification.
- If feasible, specify formaldehyde-free hardwood, plywood, particleboard or medium-density fiberboard.

7.2A HEALTHY FLOORING MATERIALS

Mandatory if providing floor coverings

REQUIREMENTS

Prohibited Locations

Do not install carpets within three feet of entryways, or in laundry rooms, bathrooms, kitchens/kitchenettes, and utility rooms. Do not install carpet on slab on grade (see Exemption for New Construction).

Products

- Any hard surface flooring products used must be ceramic/porcelain tile, hardwood floors, linoleum, cork or other hard surface materials that meet the requirements of California's Section 01350 program or the NSF/ANSI 332 standard (including pre-finished hardwood flooring).
- Carpet may not be installed in the prohibited locations listed above. Any carpet products used in a permitted location must meet or exceed the Carpet and Rug Institute's Green Label or Green Label Plus certification for carpet, pad, and carpet adhesives.
- Reclaimed flooring is encouraged, and such flooring need not meet the Section 01350 or NSF/ANSI 332 standard requirement. Reclaimed wood flooring must be free of lead-based paint, and tiles should be free of asbestos.

Exemption for New Construction Only:

Where occupancy or other factors make it preferable to hard surface flooring, carpet tile may be installed on slab-on-grade floors with proper vapor barrier strategies installed (see [7.10 Vapor Barrier Strategies](#)). Carpet tile products must meet the certification requirements above. Tile should not be permanently glued to the slab so that individual tiles can be easily removed for spot cleaning or replacement. The carpet tile should be installed using either a releasable adhesive that meets the certification requirements above; or a releasable system for joining tiles together to create a single, floating sheet. Property Management unit turnover plans should also include appropriate directions for removing, cleaning, and replacing carpet tiles.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state what floor coverings will be used and where and that they will meet the requirements of this criteria. Do not send in product literature or spec sheets with the EPP.

RATIONALE

New carpets, padding, and adhesives release VOCs that may pose health hazards to residents and workers. Carpets also attract allergens such as dirt, pollen, mold spores, dust mites and other

microbes that may pose health hazards to individuals allergic to these substances. The Carpet and Rug Institute's program certifies that labeled carpets are low VOC.

When carpet is installed on older slab-on-grade floors, whose vapor barrier (if installed) is very likely to be significantly degraded in effectiveness, there is a significant risk that moisture will migrate up through the slab and be absorbed into the pad and carpet yarns. This may result in degradation of indoor air quality and negative impacts to occupant health.

RECOMMENDATIONS

- Resilient flooring that has passed the California Section 01350 program (FloorScore, CHPS) or NSF/ANSI 332 is compliant with this standard.
- More information on the Carpet and Rug Institute's Green Label program can be found on their website at www.carpet-rug.org.
- The EPA Energy Star with Indoor Air Package Specifications requires Green Label Plus carpet. The plus label is more stringent. The California Rug Institute maintains a list of manufacturers and products meeting the Green Label Plus standard. To view the lists go to: <http://www.carpet-rug.org/residential-customers/selecting-the-right-carpet-or-rug/green-label-plus-carpet-list.cfm>.
- Make Green Label Plus part of the specifications for sub-contractor submittals when using carpet.
- In wet areas, use smooth and resilient flooring that can tolerate moisture (e.g., ceramic tile, linoleum, etc.).

7.2B HEALTHY FLOORING MATERIALS

Optional 6 points

REQUIREMENTS

Use non-vinyl, non-carpet floor coverings throughout each building in the project. In addition, do not install flooring containing PVC or chlorine.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that no carpet flooring or flooring containing PVC or chlorine, will be used throughout each building.

RATIONALE

While certain health hazards are linked with the production of vinyl products, some alternative flooring materials that are natural and renewable have demonstrated low-VOC emissions and an environmentally friendly production. Avoid the use of carpet, which can serve as a sink for dust, allergens and other substances that may pose health hazards to susceptible residents.

RECOMMENDATIONS

- Use alternative flooring materials such as linoleum, laminate, ceramic tile, bamboo, cork, wood (especially salvaged wood) or rubber.
- For concrete floors and basements, leave the slab exposed and stained with low-VOC material rather than providing any floor treatments.

7.3A-7.5 GENERAL VENTILATION GUIDANCE

The most important measurement to manage is the airflow actually delivered at the unit. Installing a 50 CFM fan that, due to ducting runs, only delivers 30 CFM performance to the unit is not sufficient.

In certain otherwise-efficient configurations, EnergyStar products may not be available at the necessary scale. For instance, a commercial-grade rooftop fan may provide the most efficient ventilation for a building's bathrooms, but as EnergyStar is a residential program, no EnergyStar fan of sufficient size is available. The purpose of ESDS is to direct projects to the greatest sustainable efficiency, and NOT to unnecessarily limit the availability of products, so in such cases the EnergyStar requirement will have a very high likelihood of being waived.

7.3A EXHAUST FAN-BATHROOM

Mandatory for New Construction & Substantial Rehab

REQUIREMENTS

Install Energy Star-labeled bathroom fans that exhaust to the outdoors and are equipped with an automatic timer, motion sensor, humidistat sensor, or that operate continuously.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that Energy Star bathroom fans including how they will be controlled. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Properly sized and controlled exhaust fans in bathrooms reduce moisture condensation, lowering the potential for indoor mold growth that may yield odors and pose health hazards to residents. Energy Star-qualified fans use 65 percent less energy on average than standard models and move more air per unit of energy used with less noise. Timers and humidistat sensors help ensure that fans regularly remove moisture and provide increased ventilation.

RECOMMENDATIONS

For more information on bathroom fans, go to the Products section of the Energy Star homepage: www.energystar.gov.

7.3B EXHAUST FANS-BATHROOM

Optional 3 points for Moderate Rehab only

REQUIREMENTS

Install Energy Star-labeled bathroom fans that exhaust to the outdoors and are equipped with an automatic timer, motion sensor, humidistat sensor, or that operate continuously.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that Energy Star bathroom fans including how they will be controlled. Do not send in product literature or spec sheets with the EPP.

7.4A EXHAUST FANS-KITCHEN

Mandatory for New Construction

REQUIREMENTS

Install Energy Star labeled fans or range hoods that exhaust to the exterior. Recirculating range hoods are not an acceptable method for compliance with this Criterion. Kitchens cannot be vented by a whole-house fan.

Exemption: Microwaves with integrated range hoods do not need to be Energy Star certified. However, the exhaust fan must still vent to the exterior.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that Energy Star kitchen fans will be installed and vented to the outside. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Besides helping to reduce moisture, kitchen fans also help remove carbon dioxide and carbon monoxide over fuel-burning appliances and other air contaminants that may be byproducts of cooking. Energy Star-qualified fans use 65 percent less energy on average than standard models and move more air per unit of energy used with less noise.

RECOMMENDATIONS

- Energy Star products:
http://www.energystar.gov/index.cfm?c=products.pr_find_es_products
- If installing a microwave with integrated range hood, ask your vendor for the efficacy and sound level they are proposing. Matching Energy Star levels will help minimize energy consumption and complaints about hood noise. Energy Star range hoods meet the following: Max flow=500 cfm, Fan Efficacy ≥ 2.8 cfm/Watt, Sound level ≤ 2.0 sones.

7.4B EXHAUST FANS-KITCHEN

Optional 3 points for Rehab

REQUIREMENTS

Install Energy Star labeled power vented fans or range hoods that exhaust to the exterior.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that Energy Star kitchen fans will be installed and vented to the outdoors. Do not send in product literature or spec sheets with the EPP.

7.5 VENTILATION

Mandatory

REQUIREMENTS

Install a ventilation system for each dwelling unit that meets the Washington State Amendments to the International Mechanical Code Section 403. Ventilation system energy use shall meet the fan power and air flow limits in the Washington State Energy Code, Section R403 or C403.

Provide commissioning of the ventilation system. Test the airflow to individual housing units and verify that they meet the minimum standards, but do not exceed the design airflow by more than 20%. Verify performance using a flow hood, pressure pan, or similar method, for a reasonable sample of units (1.3A).

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form:

- State that whole-house ventilation will be installed according to section 403 of the 2015 WSEC.
- State the size of fan, how the size was determined, the location, and how it is controlled.
- State that the installer report of performance testing will be available on site for the Third Party Verifier to review.

RATIONALE

Optimal ventilation improves indoor air quality by providing fresh air to the living space on a regular basis. Since air sealing is part of the energy efficiency measures, adequate ventilation becomes essential to the health of the occupants.

RECOMMENDATIONS

In smaller units, a bathroom exhaust fan can double as the whole house fan if the fan is set to properly cycle on and off.

7.6 CLOTHES DRYER EXHAUST

Mandatory

REQUIREMENTS

Clothes dryers must be exhausted directly to the outdoors using rigid-type ductwork (from the connection point to the exterior exhaust), except for condensing and heat pump dryers, which must be plumbed to a drain. Do not vent to attic or crawl space.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that clothes dryers will be exhausted to the exterior.

RATIONALE

Outdoor venting of clothes dryers substantially reduces air moisture that can lead to mold growth.

RECOMMENDATIONS

- It is important to minimize the duct run to avoid build up of moisture and particles that can inhibit the flow of air through the duct. Rigid duct materials are preferred to help ensure clean ducts and to reduce the buildup of particles and moisture.
- International Residential Code:
M1502.1 General.
Clothes dryers shall be exhausted in accordance with the manufacturer's instructions.
M1502.2 Independent exhaust systems.
Dryer exhaust systems shall be independent of all other systems and shall convey the moisture to the outdoors.
Exception: This section shall not apply to *listed* and *labeled* condensing (ductless) clothes dryers.

7.7 COMBUSTION EQUIPMENT

Mandatory

REQUIREMENTS

If using fossil fuel fired water heaters, specify direct power vented or sealed combustion appliances when the heater is located in a conditioned space. Refer to requirements in 2015 WSEC.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that there will be direct power vented or combustion sealed fossil fuel fired water heaters when in the conditioned space. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Direct vent systems draw all the air needed directly from the outside so there is no risk of spilling combustion contaminants into the residence. Power vented equipment uses a fan or blower to create the pressure difference that causes air to flow from inside the house, through the combustion device out an approved chimney or vent system to the outdoors.

For all new construction in Washington since 1990, homes have been constructed to the air sealing level defined by the International Residential Code as unusually tight construction. In addition, projects complying with the energy efficiency requirements of this standard will achieve unusually tight construction.

7.8 MOLD PREVENTION: SURFACES

Mandatory

REQUIREMENTS

Use materials that have durable, cleanable surfaces throughout bathrooms, kitchens and laundry rooms. Materials installed in these rooms should not be prone to deterioration due to moisture intrusion or encourage the growth of mold. Do not use mold-propagating materials such as vinyl wallpaper and unsealed grout.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state durable, cleanable surfaces throughout bathrooms, kitchens and laundry rooms will be installed. Do not send in product literature or spec sheets with the EPP.

RATIONALE

The use of moisture-resistant materials in wet areas reduces moisture buildup, diminishing the potential for indoor mold growth that may yield odors and pose health hazards to residents.

7.9 MOLD PREVENTION: TUB & SHOWER ENCLOSURES

Mandatory

REQUIREMENTS

Behind tiled/grouted or multi-piece shower and tub enclosures:

Use moisture-resistant backing materials such as cement board, fiberglass faced gypsum board or equivalent behind tiled/grouted or multi-piece shower and tub enclosures.

Behind one piece fiberglass/plastic shower/tub enclosures:

Use paper-faced gypsum backer board that meets mold-resistant requirements per ASTM #D3273 with a score of at least 10, on all walls and ceiling facing the shower.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state which materials for tub and shower enclosures will be used. Do not send in product literature or spec sheets with the EPP.

RATIONALE

Projects pursuing Evergreen certification are expected to have a 40 to 50 year service life with minimal maintenance and replacement requirements. Wet rooms, particularly bathrooms, pose a significant challenge to this expectation. It is prudent to assume that any finish in a bathroom will eventually let water through to what's behind it. Using materials that do not degrade with time or the presence of moisture, and do not support mold growth, ensures that the underlying structure of these rooms remains intact when surface treatments degrade.

7.10 VAPOR BARRIER STRATEGIES

Mandatory for New Construction & Moderate/Substantial Rehab with foundation work

REQUIREMENTS

Beneath Concrete Slabs, Including Basements

- Provide vapor barriers under all slabs at conditioned spaces.
- Install a capillary break as follows:
 - Install a 4-inch layer of ½-inch diameter or greater clean aggregate
 - Immediately above the capillary break, install polyethylene sheeting with a minimum thickness of 6 mil, overlapped at least 6 inches at the seams to serve as a vapor retarder in direct contact with the slab above.

Beneath Crawl Spaces

- Install 8-mil minimum thickness cross-laminated polyethylene on the crawl floor, extended at least 12 inches up on piers and foundation walls, and with joints overlapping at least 12 inches. (The 8-mil polyethylene and the cross-lamination ensure longevity of the poly.)
- Line the likely “high-traffic” areas of the crawl space with foam board, so the polyethylene beneath will not be disturbed.

Exemption: Exceptions will be granted if recommended by the project’s Geotechnical Specialist.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state the vapor barrier strategies that will be used in the project.

RATIONALE

Water can migrate through concrete and most other masonry materials. Proper foundation drainage prevents water from saturated soils from being pushed by hydrostatic pressure through small cracks. Vapor barriers and waterproofing materials can greatly reduce the migration of moisture that can occur even in non-saturated soils.

RECOMMENDATIONS

- Ensure that trades’ work does not puncture the vapor barrier.
- For concrete slabs in dry climates, in addition to one of the two methods above the following are suggested to reduce slab curl and improve slab strength and hardness:
 - Maintain slab surface moisture during the curing process- called wet or moist curing- by regular wetting with a spray and/or application of wet burlap. For more information: http://www.cement.org/tech/cct_curing.asp

7: Healthy Living Environment

- Install a 2-inch deep sand bed over the vapor barrier before placing the concrete. However, this option does increase the risk of moisture collecting in the sand above the vapor barrier, to be released later as vapor through the slab.
- On interior below-grade walls, avoid using separate vapor barrier or a below-grade vertical insulation (such as polyethylene sheeting, vinyl wallpaper, or foil faced), which can trap moisture inside wall systems. Semi-vapor-permeable rigid insulation is not considered a vapor barrier.

7.11 RADON MITIGATION

Mandatory

REQUIREMENTS

New Construction

In high risk radon counties, provide radon mitigation as required by code. Radon Mitigation Systems are required for new construction in EPA Zone 1 counties. High risk EPA Zone 1 counties in Washington State are: Clark, Ferry, Okanogan, Pend Oreille, Skamania, Spokane, and Stevens Counties.

Washington State has adopted the International Residential Code APPENDIX F RADON CONTROL METHODS for single family and duplex construction.

Rehabilitation

In EPA Radon Zone 1 counties, conduct radon testing using the protocols described in the EPA publication: “Protocols for Radon and Radon Decay Product Measurements in Homes.” See http://www.epa.gov/radon/pdfs/homes_protocols.pdf.

When testing concludes that indoor radon levels in the home are 4 picocuries per liter (pCi/L) or higher, provide radon mitigation measures.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state whether the project is in a high risk radon county. If so, continue with the following:
 - For New Construction, on the EPP form state the list of radon mitigation measures that will be installed. Facilitate post testing and ensure documentation verification is reviewed by the third party verifier.
 - For Rehabilitation, on the EPP form state that radon testing using the EPA protocols will be done and state type and duration of test. If radon testing shows 4 pCi/L or higher, state here the radon mitigation measures that will be installed. Facilitate post testing and ensure documentation verification is reviewed by the third party verifier.

RATIONALE

Installation of radon-resistant features will reduce concentrations of radon, a cancer-causing soil gas that can leak into homes from the crawl space, cracks in the slab, or basement walls. EPA estimates that 20,000 individuals die of cancer every year due to excessive exposure to radon.

RECOMMENDATIONS

- Consult <http://www.epa.gov/radon/index.html> for information on the health effects, testing and mitigation strategies.
- The most commonly used test methods are: Activated Charcoal Adsorption for short-term monitoring (2-5 days) and Alpha Track Detection for long-term monitoring (3-12 months). Long term monitoring provides the most reliable results.
- Tests are best conducted during the winter months under closed house conditions. This is when the building is most likely to have higher radon levels.
- Radon mitigation strategies are provided in the EPA publication Radon Reduction Techniques for Existing Detached Houses: Technical Guidance (Third Edition) for Active Soil Depressurization Systems.

7.12 WATER DRAINAGE

Mandatory

REQUIREMENTS

- Provide drainage of water away from windows, walls, and the entire perimeter of foundations.
- In new construction, foundation walls should be carefully waterproofed on the exterior to avoid moisture migration and should not leach chemicals into the soil.
- If poured concrete walls are used, release agents used to free forms from concrete walls should not be comprised of used motor oil, diesel fuel or some other toxic material.
- Divert water drainage away from the building by directing gutters and downspouts to flow onto splash blocks or a proper drainage system. If possible, water should be diverted at least 12 feet from any building foundation and then allowed to infiltrate on site.
- Slope new and rebuilt walkways, stairs, patios and thresholds away from the buildings.
- Properly flash all roof penetrations.
- Where feasible, extend eaves 18 inches to 2 feet to keep water off walls and windows.
- Install pan flashing on windows and exterior doors. Apply window pan flashing over building paper at sill and corner patches.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that all water drainage measures listed in this criterion will be followed. If rehab, all water drainage measures listed which apply to the scope of work are required.

RATIONALE

Diverting water from the building prevents bulk water entry through foundations and into basements, which can contribute to moisture-related problems such as mold and the deterioration of wood and other building materials. Flashing helps direct water away from wall cavities to the drainage plane. Careful architectural detailing of the drainage system and diligent construction supervision ensure proper water drainage.

RECOMMENDATIONS

Best practices include a grade of 0.5 inch per foot, or approximately a 4 percent pitch. EPA recommends a 2 percent pitch (0.25 inch per foot) for hard surfaces such as patio slabs, walks and driveways.

Code References:

Storm Drainage: Provide storm drainage in compliance with the Uniform Plumbing Code Chapter 11, the International Residential Code Chapter 4, and local storm water regulations. This includes but is not limited to:

- All roofs, paved areas, yards, courts and courtyards shall be drained to a separate storm system, or to other place of disposal satisfactory to the Authority Having Jurisdiction.
- Subsoil drains shall be provided around the perimeter of buildings having basements, cellars, crawl spaces or floors below grade.
- Lots shall be graded to drain surface water away from foundation walls. The grade shall fall a minimum of 6 inches (152 mm) within the first 10 feet (3048 mm).
- Foundations: Provide foundation water proofing in compliance with IRC SECTION R406. Select environmentally friendly release agents & coating materials. This includes but is not limited to:
 - Foundation walls that retain earth and enclose interior spaces and floors below grade shall be damp proofed from the top of the footing to the finished grade.
 - If poured concrete walls are used, release agents used to free forms from concrete walls should not be comprised of used motor oil or some other toxic material.
- Water Resistive Barriers and Flashing: Provide Water Resistive Barriers and Flashing in compliance with the International Residential Code, Chapter 7 for wall covering and Chapter 9 for roof covering.

7.13A ENHANCED BUILDING ENVELOPE DESIGN

Mandatory for New Construction

REQUIREMENTS

Provide a building envelope design that prevents to the greatest degree possible the penetration of water and water vapor. The design must also make it possible to remove and replace windows without the replacement installation activity resulting in post-replacement compromise of the performance of the building envelope.

This must be achieved without compromising the requirements of [7.12 Water Drainage](#).

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form, state that the building envelope design will make it possible to remove and replace windows without compromising the performance of the building envelope.

RATIONALE

The building envelope should be designed in such a way that the physical and chemical properties of water and water vapor do not create structural or health issues during the useful life of the building.

A sometimes-overlooked aspect of envelope design is the need to plan for window replacement. Whether through breakage, early failure or simply wearing out (i.e. reaching the end of the design life), windows *will* need to be replaced at some point in the life of a building. This *should* be achievable without having to go through the additional cost of tearing out and then replacing the cladding, which in the meantime would expose the membranes to the exterior, *and* without the installation of the replacement window resulting in hammering holes through the Weather Resistive Barrier (“WRB”).

In the case of flanged windows, this requires thought to be given to the amount of trim to be installed around the opening. In the case of flangeless windows, the design of interior sills must be taken into account. In both cases, care must be taken to document for future replacement which windows may be installed and which are precluded by the design.

7.13B ENHANCED BUILDING ENVELOPE DESIGN

Optional up to 8 points for New Construction and up to 10 points for Substantial Rehabilitation

REQUIREMENTS

Utilize any of the following measures to enhance the building envelope design for durability.

Option #1 (2 points): Prepare a water and moisture inspection plan that provides, at a minimum, for documented independent periodic review of the building enclosure by the project architect or Building Envelope Consultant, during the course of construction to ascertain whether construction has been performed in substantial compliance with the building enclosure design documents.

Option#2 (3 points): Provide full-size mock ups of all envelope penetrations, reviewed by the architect or independent building envelope consultant, and made available for reference on the construction site throughout the construction period.

Option #3 (3 points): Provide water penetration resistance testing of a representative sample of windows and window assembly installations, conducted according to industry standards. The construction review and testing protocols shall be carried out by an independent testing laboratory or qualified building envelope consultant.

Substantial Rehab only-**Option #4 (2 points):** Provide a building envelope design that makes it possible to remove and replace windows without compromising the performance of the building envelope. This must be achieved without compromising the requirements of [7.12 Water Drainage](#).

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:

- State the option(s) chosen and how the objective will be achieved.
- State that inspection reports and photos of any mockups will be available on the job site.

RATIONALE

The building envelope should be designed in such a way that the physical and chemical properties of water and water vapor do not create structural or health issues during the useful life of the building.

RECOMMENDATIONS

The design should be appropriate for its location and climate, and consider the physical and financial operating conditions anticipated for the building. Consult architects and engineers who specialize in building envelope or include an independent building envelope inspector in the project team.

RESOURCES

- Lstiburek, Joseph. *Builder's Guide to Mixed-Humid Climate*. Bloomington MN: Energy and Environmental Building Association, 2005.
- Lstiburek, Joseph. *Water Management Guide*. Westford MA: Building Science Press, 2006. <http://www.buildingsciencepress.com/Water-Management-Guide-P9.aspx>

7.14 GARAGE ISOLATION

Mandatory

REQUIREMENTS

Install Carbon Monoxide Alarms as per the requirements of the [Washington State Carbon Monoxide Alarm Laws](#). In addition:

- Provide a continuous air barrier between the conditioned (living) space and any garage space to prevent the migration of any contaminants into the living space. Common walls and ceilings between attached garages and living spaces must be visually inspected to ensure that they are air-sealed before insulation is installed
- Do not install ductwork or air handling equipment in a garage.
- All connecting doors between living space and garage must be fixed with gaskets or otherwise made substantially airtight with weather stripping.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that there will be a continuous air tight barrier between the living space and an attached garage, how it will be achieved, and the number of placements of CO monitors.

RATIONALE

Carbon monoxide inhalation can be dangerous to human health. The air barrier and air sealing will help prevent carbon monoxide migration from the garage to the living space, and the CO alarm will help ensure that residents are alerted in the case of accidental accumulation of the gas.

RECOMMENDATIONS

ASHRAE 62.2 requires that the building envelope between the garage and occupied spaces be sealed to prevent air leakage. Refer to ASHRAE 62.2 for more information and to specify garage contaminant isolation measures. Homes meeting the Energy Star Northwest certification will meet the duct leakage test standard.

7.15 INTEGRATED PEST MANAGEMENT

Mandatory

REQUIREMENTS

Seal all wall, floor, and joint penetrations with low-VOC caulking or other appropriate non-toxic sealing methods to prevent pest entry. Provide rodent- and corrosion-proof screens (e.g., copper or stainless steel mesh or rigid metal cloth) for openings greater than ¼ inch.

Develop an integrated pest management (IPM) policy and, as part of that, develop resident guidance related to pesticide use, housekeeping, and prompt reporting of pest problems to be included in the Maintenance and Resident Manuals for cockroaches, rodents, and bedbugs.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that sealing of all penetrations will be done and include what materials will be used to prevent pest and rodent entry.

RATIONALE

Sealing of cracks and penetrations will minimize entry points for pests such as rodents and cockroaches. Avoiding unnecessary pesticides, improving resident housekeeping, and promptly responding to pest problems will reduce the chemicals needed to treat pests and will keep homes pest-free longer than a routine chemical treatment program.

RECOMMENDATIONS

- For guidance on low-VOC caulk, see ESDS 6.2.
- Integrated pest management work should be completed in conjunction with air sealing. Project teams should work with an air sealing contractor to ensure that IPM strategies are part of scope.

RESOURCES

- “How to Control Pests Safely: Getting Rid of Cockroaches and Mice,” New York City Department of Health and Mental Hygiene, under the header “Guide to Safe Pest Control in the Home”: <http://www.nyc.gov/html/doh/downloads/pdf/pest/pest-bro-healthy-home.pdf>
- The National Center for Healthy Housing, Integrated Pest Management in Affordable Housing: <http://www.healthyhomestraining.org/IPM/>
This webpage has resources dedicated to IPM in affordable housing, including model RFPs and contract language for greener pest control, case studies, and training.

7.16 LEAD-SAFE WORK PRACTICES

Mandatory

REQUIREMENTS

For properties built before 1978, use lead-safe work practices during renovation, remodeling, painting and demolition. The contractor performing the work must be Renovation, Repair and Painting certified at a minimum.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form:
 - State the year when the buildings were constructed.
 - For structures built before 1978, state that lead-safe work practices will be followed. Also state that the contractor performing the work must be Renovation, Repair and Painting certified at a minimum.

RATIONALE

Any activity that disturbs painted surfaces or building components in pre-1978 dwellings that contain lead-based paint may generate and spread lead dust and debris, increasing the risk of lead poisoning for exposed children and families.

RECOMMENDATIONS

Get a lead-based paint inspection or risk assessment if it is likely that the surfaces to be disturbed contain lead-based paint. Information about lead-safe work practices can be found at www.epa.gov/lead/pubs/traincert.htm and www.hud.gov/offices/lead/training/index.cfm.

7.17 SMOKE-FREE BUILDING

Mandatory

REQUIREMENTS

Implement and enforce a smoke-free building policy in unit leases. This policy includes all common and individual living areas, including decks and patios, and within 25 foot perimeter around the exterior of all residential buildings. The lease language must prohibit smoking in these locations and specify that it is a violation of the lease to smoke. The no-smoking restriction applies to all owners, tenants, guests, and servicepersons.

The use of e-cigarettes or related devices is not prohibited, but is strongly discouraged.

The smoking of medical marijuana is prohibited wherever smoking is prohibited. In addition, as smoking marijuana in public remains illegal, residents may not smoke medical marijuana in outdoor tobacco/e-cigarette smoking designated areas.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP state that:
 - A smoke-free policy in all common and individual living areas, including decks and patios, in unit leases and within 25 feet of building entries or ventilation intakes (including operable windows) will be implemented and enforced.
 - The lease language will prohibit smoking in these locations and that it is a violation of the lease to smoke.
 - A copy of the lease will be included in the on-site binder for the Third Party Verifier to review.

RATIONALE

Housing currently presents the biggest exposure to indoor secondhand smoke in Washington, and exposure is disproportionately experienced by vulnerable populations. Smoke-free housing policies effectively remove smoke from housing and are a major step to address the social inequities of tobacco use and secondhand smoke exposure. There is no safe level of exposure to secondhand smoke and air filtration and ventilation systems do not prevent smoke from moving between areas in a building. In addition to the negative health effects, smoking in housing significantly increases fire hazard and increases cleaning and maintenance costs. The leading cause of preventable fires is smoking-related fires.

RECOMMENDATIONS

- As confirmed by WA Department of Health, there is no evidence that medical marijuana must be smoked to treat or mitigate any specific disease; it can also be consumed in edible products, pills, tinctures, and topical applications.
- Service enriched housing should endeavor to offer tobacco cessation services as a part of their program.
- Properties should seek an insurance discount for projects with no-smoking policies.
- Project owners and property managers should inform residents that they are prohibited from smoking in the project.
- If necessary to implement policy, owners and managers may offer a designated outdoor smoking area. This area should include suitable receptacles for the disposal of cigarettes. Ensure that the receptacles are inside the project line and do not encroach into public space.

RESOURCES

- National Center for Healthy Housing, “Reasons to Explore Smoke-Free Housing Fact Sheet”:
http://www.nchh.org/Portals/0/Contents/NCHH_Green_Factsheet_Smokefree.pdf
- American Lung Association, Air Quality in the Home: www.lungusa.org
This site includes an entire section devoted to indoor air quality in the home. Choose “Air Quality” at the bottom of the screen and then click “Indoor Air Quality” and “Air Quality in the Home” to find numerous articles and educational pieces about maintaining a healthy indoor environment.
- Smokefreewashington.com (<http://www.smokefreewashington.com/apartments/>)
Includes steps to developing and implementing a smoke-free policy.
- U.S. Environmental Protection Agency, Indoor Air Quality Division: www.epa.gov/iaq
This site has numerous resources related to indoor air quality in homes, including reports and web links.

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living Environment

**8 Operations, Maintenance
& Resident Engagement**

Appendices

Glossary

OPERATION, MAINTENANCE & RESIDENT ENGAGEMENT

Educational materials and orientations help educate residents and staff on green features that were designed to deliver health, economic and environmental benefits, as well as their role in realizing those benefits in their own lives.

Engagement

8.1A BUILDING MAINTENANCE MANUAL & UNIT TURNOVER PLANMandatory

REQUIREMENTS

Develop a manual with thorough building operations & maintenance guidance and a complementary Unit Turnover Plan. In addition, provide a comprehensive walk-through and orientation for the maintenance and property manager(s) to review the Building Operations and Maintenance Manual and Unit Turnover Plan.

Building Maintenance Manual

The manual and plan should be developed over the course of the project design, development and construction stages and should include sections/chapters addressing the following topics:

1. Operations & maintenance guidance for all mechanical and electrical equipment and appliances (building level and dwelling unit level)
2. HVAC specifications, and operations & maintenance schedules
3. Operations, maintenance and replacement guidance for any other specialized systems (e.g., solar photovoltaics, solar water heating, ground source heating, microgrid) within the project
4. Location of mechanical, electrical, gas and water-system turnoffs
5. Lighting equipment specifications and replacement guidance
6. Landscaping and hardscaping specifications and maintenance plan, including any specific instructions for community gardens or growing spaces
7. Green cleaning product specifications and cleaning schedules
8. Pest control guidelines, referencing the Integrated Pest Management strategies developed in [Criterion 7.15](#)
9. Building accessibility for residents, including security and safety protocols, whether by leaving doors unlocked, by using a security device such as a card key, or by other measures
10. Maintenance of active recreation and play spaces (e.g., playgrounds, ground markings, exercise equipment) for adults, youth and children
11. Information on how energy and water information will be collected and reviewed to ensure that the project is meeting performance goals.

Unit Turnover Plan

The unit turnover plan describes the dwelling unit turnover process, including all materials that are frequently replaced at turnover and the process for educating the residents about proper use and maintenance of all building systems.

Engagement

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form:

- State that a copy of the Building Maintenance Manual and the Unit Turnover Plan will be submitted to Commerce before the project is completed
- State the estimated date of submittal.
- State the date the walk-through and orientation will be completed.

RATIONALE

Regular building maintenance using green methods helps minimize utility consumption and provides a healthy and durable living environment for residents.

RECOMMENDATIONS

Begin creating a thorough and well-developed O&M manual and plan well before construction completion. Work with designers, systems installers and operations staff to assemble critical information and schedules for best-practice operations and maintenance strategies.

Prior to, and while the project is under construction:

During the design process, keep a running list of how maintenance and landscaping teams and residents may need to be involved with the building in order to ensure that it will perform as intended. Once the project team has completed the integrative design process, amend templates of O&M documents with project-specific information for maintenance staff and residents. By working in this manner, the building O&M manual and plan will be informed by the development process and completed by the time the project is ready for occupancy.

- Identify the senior management position(s) with oversight responsibility for O&M and the job roles responsible for producing, managing and/or implementing the manual and plan.
- Ensure that the building performance goals/requirements that were established for the project during integrative design will be included in the O&M manual and plan.
- Create a knowledge-transfer plan to ensure that accurate as-built information is captured during construction, start-up and commissioning, and integrated into the O&M manual and plan (e.g., if possible, create a video of the commissioning agent or system installer showing key maintenance checks to use when training staff).
- Discuss your building O&M training plan to ensure that responsible staff will be up to speed on the operation of the building prior to turnover and occupancy.
- Develop a succession plan to ensure that important information is retained from departing staff and transferred to new staff. This could include an exit interview checklist, maintenance log review, etc.

As construction nears completion and into operations:

Finalize your building O&M manual and plan. Clearly identify key operations and maintenance activities, assign those activities to a person/job role and establish a schedule to verify that

Engagement

maintenance is performed.

To enhance your O&M manual and plan, include:

- Account information on your energy and water performance tracking software. Identify who will monitor this account and at what interval, and what procedures will take place if irregularities are discovered.
- HVAC maintenance plans. Develop a maintenance schedule for HVAC systems, and include assignments of key tasks to specific job roles. Create a system to track when/what maintenance tasks were completed.
- Information on lighting equipment, including specs for replacement bulbs and a maintenance strategy for when to replace inaccessible fixtures.
- Location of mechanical, electrical, gas and water-system turnoffs.
- Irrigation system maintenance plans. Develop a periodic visual inspection of functions (since irrigation systems are often scheduled to operate when O&M staff are off duty).
- Landscaping and hardscapes (paved surfaces) review protocols. Develop an inspection schedule of landscaping and paving, and assign key tasks to specific job roles.
- Green cleaning products and cleaning schedules. Specify products, vendors, schedule and assignments of key tasks to specific job roles. Create a system to track when actions are completed.
- A written Integrated Pest Management policy (see [Criterion 7.15](#)) aimed at preventing pests and addressing conditions conducive to pests. Repair and maintain structures and grounds to minimize pest-related conditions. Develop resident guidelines related to pesticide use, housekeeping and prompt reporting of pest problems, such as cockroaches, rodents and bed bugs. Ensure that anyone applying pesticides is licensed and working under a scope that includes IPM provisions.
- If the project is utilizing recycled water (greywater), design and institute a policy that requires biodegradable soaps, cleaners and other products if they are going to be flushed down the drains.
- Video-record installers of mechanical systems explaining best practices for regular maintenance and strategies to address common system problems. Use this video as part of your maintenance staff training.
- Provide maintenance staff with local information for handling hazardous waste, including where to recycle fluorescent and compact fluorescent lighting (CFLs).

RESOURCES

- Enterprise Green Communities, Building Maintenance Manual Templates in Information Resources: www.enterprisecommunity.com/resources/ResourceDetails?ID=63995.doc
- San Francisco Department of the Environment, “Pest Prevention by Design: Authoritative guidelines for designing pests out of structures”: www.ipminstitute.org/school_ipm_2015/Pest_Prevention_by_Design.pdf

Engagement

- For language on residential IPM policy, the University of Minnesota offers the following resource: www.entomology.umn.edu/cues/em/index.html
- National Center for Healthy Housing, “Healthy Homes Maintenance Checklist”: www.nchh.org/Portals/0/Contents/Maintenance_Checklist2009.pdf
- Stewards of Affordable Housing for the Future (SAHF), Multifamily Energy and Water Management Toolkit: This toolkit (including checklists, worksheets and resources) helps improve energy and water management, reduce costs and spending, and minimize environmental impacts over the long-term, while helping to preserve affordable properties. www.sahfnet.org/energytoolkit.html
- Federal Energy Management Program (FEMP) Operations & Maintenance Best Practices: A Guide to Achieving Operational Efficiency: <https://www1.eere.energy.gov/femp/pdfs/OandM.pdf>
- ENERGY STAR Maintenance Checklist: www.energystar.gov/index.cfm?c=heat_cool.pr_maintenance
- ASHRAE Guideline 1.4P: 2014 — Published Guideline Procedures for Preparing Facility Systems Manuals provides procedures for producing a Systems Manual as a resource for training, operations, maintenance and upgrading of facilities. www.eepformance.org/uploads/8/6/5/0/8650231/systemsmanualsgdl1_4-201x_chair_approved.pdf

Engagement

8.1B O&M INSTRUCTIONS FOR MAINTENANCE STAFFOptional 7 points

REQUIREMENTS

Develop Building Operations and Maintenance instructions that will be permanently affixed to the building according to the following requirements:

- *Location:* The instructions for each system should be located where maintenance staff will be handling the relevant equipment. For example, the irrigation instructions will be located on the wall next to the irrigation controls.
- *Instructions:*
 - Each set of instructions should be written simply and concisely ensuring that maintenance staff with varied levels of experience will be able to understand them. Consider providing instructions in additional languages, if needed.
 - The instructions will include (1) operations guidance, (2) maintenance schedule, (3) replacement schedule, and (4) any applicable performance goals.
- *Walk-Through:* Provide a comprehensive walk-through and orientation for the maintenance and property manager(s) to review the Building Operations and Maintenance Guidance.

The instructions should be developed over the course of the project design, development and construction stages and should include the following topics:

1. All mechanical and electrical equipment and appliances
2. HVAC
3. Lighting equipment
4. Landscaping & hardscaping, including community gardens/growing spaces
5. Green cleaning products
6. Pest control
7. Building accessibility for residents including security and safety protocols whether by leaving doors unlocked, by using a security device such as a card key, or by other measures (signage)
8. Active recreation and play spaces (e.g. playgrounds, ground markings, exercise equipment) for adults, youth, and children
9. Preventative maintenance schedules (i.e. duct cleaning, dryer duct cleaning, filter replacement, systems maintenance, etc.)
10. Any other systems within the project, including renewable energy systems if applicable.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP form:
 - State that the Building Operations and Maintenance instructions that will be permanently affixed to the building

Engagement

- State that the requirements regarding the location, instructions and walk-through will be followed.

RATIONALE

Instructions permanently affixed to the building will allow maintenance staff the ability to review them in their relevant locations, rather than rely solely on the building maintenance manual that will be housed in an office.

Engagement

8.2 EMERGENCY MANAGEMENT PLAN

Mandatory for multifamily

REQUIREMENTS

Provide a plan on emergency operations targeted toward operations and maintenance staff and other building-level personnel. The Plan should address response and recovery to various types of emergencies, leading with those that have the greatest probability of negatively affecting the project. In addition, provide a comprehensive orientation for the maintenance staff and other building-level personnel to review the project's emergency plan.

Emergency Plan Details

The Plan should provide guidance as to how to sustain the delivery of adequate housing throughout an emergency and cover a range of topics including but not limited to:

1. Emergency Planning Education: how to prepare buildings, the site, and residents for the on-set of a emergency situation.
2. Detail how to help residents plan for a potential emergency in which any of the following services may be disrupted: fire, water, energy, and vertical access. The details should also include how often residents will be educated on these topics.
3. How to evacuate and shelter in place
4. Communication plans for staff to staff and staff to resident
5. Contact information for public utility, service providers, and local jurisdiction emergency management organizations
6. Infrastructure and building "shutdown" procedures
7. Procedure for inspecting buildings and site following an emergency to ensure resident and staff safety
8. Re-housing of residents following an emergency situation
9. Proximity to shelters and other resources

This information should be readily available to all building residents, staff and visitors.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form:
 - State that the Emergency Management Manual will be submitted to Commerce before the project is completed and the estimated date of submittal.

RATIONALE

In the event of an emergency, time is of the essence. Creating and socializing a plan for building managers and residents before an emergency occurs increases the likelihood that disturbances

Engagement

due to the emergency (whether it be flooding, earthquake, power outages or other disturbances) can be appropriately mitigated.

Through resilience planning, a resident community will be better suited to maintain livable conditions in the event of natural disasters, loss of power or other interruptions in normally available services.

RECOMMENDATIONS

- Emergency Management Plans should be reviewed and updated annually (at a minimum) in both digital and hard-copy formats, and located in a well-marked location.
- Reviewing and updating all Emergency Management Plans should be built into the job description and performance requirements of staff members.
- Consider having staff trained in first aid, cardiopulmonary resuscitation (CPR), and the use of automated external defibrillators (AEDs), and include information about these resources within your Emergency Management Plan.

RESOURCES

- Enterprise Disaster Response Staffing Plan: www.enterprisecommunity.org/resources
- Ready is a public service campaign designed to educate and empower Americans to prepare for and respond to emergencies, including natural and man-made disasters. The goal of the campaign is to get the public involved and ultimately to increase the level of basic preparedness across the nation. www.ready.gov/ or www.ready.gov/business/implementation/emergency
- Federal Emergency Management Agency (FEMA) - Plan, Prepare & Mitigate a Disaster: www.fema.gov/safer-stronger-protected-homes-communities • American Red Cross: www.redcross.org
- Seattle Office of Emergency Management provides many valuable resources, They can be accessed online at: www.seattle.gov/emergency/publications
- Urban Green, Building Resiliency Task Force Report, Ch. 4: Better Planning, June 2013. <http://urbangreencouncil.org/content/projects/building-resiliency-task-force>
- Preparedness publications on the WA Emergency Management Division website: <http://mil.wa.gov/other-links/publications>.

Engagement

8.3 RESIDENT MANUAL & ORIENTATIONMandatory

REQUIREMENTS

Provide a guide for homeowners and renters that explains the intent, benefits, use and maintenance of green building features. In addition, provide a comprehensive walk-through and orientation for residents to review the details of the manual.

Resident Manual Details

The Guide should include any of the relevant information:

- a routine maintenance plan
- location of transit stops and other neighborhood amenities
- operations and maintenance guidance for all appliances and special plumbing fixtures
- HVAC operation
- cautions or appropriate maintenance on renewable energy systems
- location of water-system turnoffs
- lighting equipment
- interior finish materials, including paints, caulks, and flooring
- paving materials and landscaping
- pest control and Non-toxic measures in pest control
- special health considerations if greywater is used indoors (e.g., do not drink from the toilet in emergency situations)
- encouraging additional green activities such as recycling, gardening, use of healthy cleaning products, purchase of green power, energy savings potential in plug loads any other systems that are part of the home

Resident Orientation Details

The records should include the date of the orientation, who in each household received the orientation, and who on the management team gave the orientation. Orientations are given initial lease-up and updated when there is turnover. Housing Trust Fund staff will monitor these records during site visits.

NOTE: Although not required, rather than a paper manual, consider creating videos for residents. Videos covering the Resident Manual would help free up staff time.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state:
 - That the Resident Manual will be submitted to Commerce before the project is completed; include an estimated date of submittal.
 - How the orientations will be completed with new tenants and the plan for

Engagement

orientation at turnover.

- That a record of the orientation will be submitted to Commerce after project development is completed and at least 90% occupied. The record should include the date of the orientation, who in each household received the orientation, and who on the management team gave the orientation; include an estimated date of submittal.

RATIONALE

Education on the operations and maintenance of the home will allow residents to fully realize the environmental, health, and economic benefits that green housing offers. This resource will familiarize residents with the green features and methods used in their new home and additional activities they could initiate to realize the home's benefits.

RECOMMENDATIONS

- During the design process, keep a running list of how maintenance and landscaping teams and residents may need to be involved with the building in order to ensure that its lifespan is maximized and that it will perform as intended. Once the project team has completed the integrative process (see Criterion 1.1), amend templates of the Operations and Maintenance documents with project-specific information for maintenance and residents. By working in this manner, Operations and Maintenance documents will be informed by the development process and completed at the same time the project is ready for occupancy.
- Provide residents with local information for handling household hazardous waste, including CFLs and LEDs.
- Consider including ENERGY STAR "Best Practices" information in the Resident Manual. See the following websites:
 - For washers and dryers:
http://www.energystar.gov/index.cfm?c=clotheswash.clothes_washers_performance_tips
 - For refrigerators:
http://www.energystar.gov/index.cfm?c=refrig.pr_best_practices_refrigerators
 - For dishwashers: http://www.energystar.gov/index.cfm?c=dishwash.pr_best_practices
- For additional best practices on ENERGY STAR products:
http://www.energystar.gov/index.cfm?c=products.pr_find_es_products
Select a product type, click on "Buying Guidance," and scroll down to the bottom of the page to select "Best Practices" products.

RESOURCES

There are two templates that can be used to help create your Resident Manual:

- On Green Communities Website: "Template for Healthy Home Guide for Residents"

Engagement

<http://www.greencommunitiesonline.org/tools/resources/>

- On Commerce's website: "Example Resident's Manual"

<http://www.commerce.wa.gov/Programs/housing/TrustFund/Pages/PropertyManagementResources.aspx>

Engagement

8.4 PROJECT DATA COLLECTIONOptional up to 8 points

REQUIREMENTS

Collect and monitor post occupancy project performance data on energy, water, and, where possible, healthy living environments for at least 5 years. Produce a “Post Occupancy Evaluation” report detailing the first 10 months of operations, and provide a copy of this report to Commerce. Provide Commerce also with access to utility monitoring data. The number of points claimable under Criterion 8.4 is determined by the method and level of data collection.

Post Occupancy Data collection:

Utility monitoring data will be examined by Commerce on the same cycle as the Annual Report.

Option #1: Collect and monitor whole building use (i.e., aggregate numbers, not broken down by resident); this includes all owner paid and tenant paid utilities. **(3 points)**

Option #2: For sub-metered projects, property owner /developer must agree to collect utility release forms from the required number of residents to track actual utility data of a sample of homes. The following table identifies the number of residents for which the property owner /developer must collect and track utility data, as based on the project size in total number of units. **(5 points)**

Project Size	Number of Units to report
0-24 units	8
25-49 units	10
50-74	12
75+	15

Option #3: As for Option #2, but for 100% of units’ residential use data. **(8 points)**

The Post Occupancy Evaluation

Coordinate with the Owner’s development and property management staff to design and develop a Post Occupancy Evaluation form that is specifically adapted to the project. Use monitoring data and information gathered via this form, as well as information gathered via a POE walk-through;

Engagement

collect resident and property management surveys; and produce a final report to the project owner and development team. To optimize the utility of the report, occupancy rates during the evaluation window should be included in the report.

The POE final report shall include an executive summary of the following categories:

- **Durability** of material and finishes
- **Analyses of the Original Intent vs. Actual** (e.g. 'physical traces' or anomalies in the design of major building systems and features)
- **Functionality Observation from Interviews and Surveys** (a sample number of tenants (residential and/or commercial), the Owner's Property Management, Facilities Management staff regarding unit layout, interior finishes, private & common area indoor & outdoor spaces, overall appearance of the building, etc.).
- **Lessons Learned** (e.g. water intrusion issues with cast-in-place concrete planter boxes built adjacent to exterior cladding, clogged exterior duct vent filled with dryer lint, excessive efflorescence on exterior masonry walls, etc.)

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form,
 - Provide an estimated date for completion of the Post Occupancy Evaluation
 - State which data collection option was chosen,
 - Specify how access to usage information will be provided to Commerce.

RATIONALE

The POE has two goals: (1) The Owner needs a structured feedback process to document what worked and didn't so the lessons learned can be incorporated into the next similar project; (2) Catch any warranty items or issues before the one year warranty expires.

A data collection and monitoring system helps project owners, on-site staff, and residents to understand project performance issues. Once an issue is identified, appropriate actions can be taken to maximize cost savings and health benefits associated with green building features.

Engagement

RECOMMENDATIONS

- For tax credit properties, projects selecting option #3 may receive a utility allowance adjustment by following the WSHFC Tax Credit Compliance Manual Appendix O: <http://wshfc.org/managers/ManualTaxCreditIndex.htm#O>
- Multifamily building data can be tracked and analyzed using EPA's free Portfolio Manager tool.
- Provide Commerce with access to the performance data annually for a five-year period through the Utility Release Form and /or the EPA's Portfolio Manager account information to help populate its database intended to collect national information on green affordable housing.
- Ensure that the training for residents and building maintenance staff includes information on how to effectively use the data collection, monitoring, and reporting system.
- Property owners have indicated that the best time to collect tenant release forms is during tenant lease-up.

RESOURCES

- Environmental Protection Agency, Portfolio Manager Overview: www.energystar.gov/index.cfm?c=evaluate_performance.bus_portfoliomanager
The Portfolio Manager Overview is an interactive energy management tool that allows the project team to track and assess energy and water consumption across its entire portfolio of buildings in a secure online environment.
- Private, fee-based, benchmarking and utility tracking tools are available. Among others, these include: WegoWise: www.wegowise.com; Energy Score Cards: www.energyscorecards.com; eGauge: www.egauge.net

Engagement

8.5 EDUCATIONAL SIGNAGE

Mandatory

REQUIREMENTS

Post current, durable and permanent educational signage throughout the building and/or provide educational material to communicate the green efforts of the project to the community, residents and building operators.

EVERGREEN PROJECT PLAN REQUIREMENTS

1. On the EPP Form, state that educational signage and/or educational material will be provided onsite.

RATIONALE

Educating residents, building operators and the community about the benefits of green buildings can help motivate others to make change. People take care of beautiful buildings; understanding how a building operates instills pride and ownership which maximizes the building maintenance and performance.

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendices

Glossary

APPENDIX

APPENDIX A: RESERVED

APPENDIX B

Energy Efficiency for Rehabilitation of Existing Housing

A list of prescriptive weatherization methods has been adopted as the primary method for meeting the Evergreen Sustainable Development Criteria for energy efficiency during building rehabilitation. Two analysis methods are also available as an alternative to the prescriptive method. This includes a simple 10 year payback calculation, or a savings to investment ratio. The prescriptive options have been adopted principally from the Regional Technical Forum, Site Built Housing Weatherization Specifications, October 1, 2003. This is the list of measures developed by the Northwest Power Planning Council and Bonneville Power Administration. The list of measures has been developed over 20 years with input from weatherization agencies and sponsor utilities. The list of measures has remained fairly consistent over time. In most cases, when the opportunity presents itself, it is cost effective to provide air sealing and insulation measures to housing in the Pacific NW Region.

There are special conditions in some buildings that make it more difficult than usual to install the prescriptive options detailed here. For these cases, the applicant may wish to propose an alternative to the prescriptive requirements. To propose an alternative list of measures, the applicant may provide either a simple payback analysis or a savings to investment ratio, as detailed below.

In all cases minimum code requirements must be met. Specific to energy efficiency, the requirements of Washington State Energy Code Section 101.3 apply to existing buildings.

1. Prescriptive Option - Mandatory Measures

For each project, complete the following mandatory weatherization measures.

Existing Building Air Sealing and Ventilation:

- Mechanical Ventilation (Mandatory): Provide a whole house mechanical ventilation system in compliance with the applicable Washington State Mechanical Code, Chapter 4, or the applicable edition of ASHRAE Standard 62.2.
- Prescriptive Air Sealing (Mandatory): All accessible exterior joints around windows and door frames, openings between walls and foundation, between walls and roof and wall panels; openings at penetrations of utility services through walls, floors and roofs; and all other openings in the building envelope for all occupancies and all other openings in between units in R-1 and R-2 occupancies shall be sealed, caulked, gasketed or weather-stripped to prevent air leakage. All exterior doors or doors serving as access to an enclosed unheated area shall be weather-stripped to prevent leakage around their perimeter when in a closed position.

Attic Spaces: (Mandatory)

- All penetrations in the ceiling shall be sealed to prevent air leakage from the interior space to the attic space.
- Attic ceilings with less than R-20 existing insulation shall be insulated to a minimum of R-38 or the highest R-value approaching R-38 which is practical.
- Uninsulated knee walls shall be insulated to R-21, or the highest R-value approaching R-21 which is practical.
- Attic access doors which are adjacent to Conditioned Spaces shall be insulated to at least R-30 for horizontal openings and to at least R-13 for vertical openings and weather-stripped.
- If water pipes are located in the attic space, water pipe insulation shall be included with ceiling insulation.

?

Single Rafter Vaults: (Mandatory)

- When vaulted roof cavities are exposed during renovation, the cavity shall be insulated to R-38 or highest R-value approaching R-38 which is practical. Code required roof cavity ventilation shall be taken into account when determining the maximum depth of insulation installed in the rafter space.

Floors over vented crawl space, or other unconditioned spaces. (Mandatory)

- All penetrations in the floor system shall be sealed to prevent air leakage from the crawl space to the interior space.
- Floors over unconditioned space shall be insulated to a minimum of R-30, or to the maximum level needed to fill the joist cavities.
- Any crawlspace access door adjacent to a Conditioned Space shall be insulated to at least R-30 for horizontal openings and to at least R-13 for vertical openings and shall be weather-stripped with appropriate materials.
- Uninsulated walls separating the crawlspace from Conditioned Space shall be insulated to a minimum of R-21 or the highest R-value which fills the cavity.
- If water pipes are located in the crawlspace, water pipe insulation shall be included with underfloor insulation.

Above and Below Grade Walls (Mandatory)

- Insulation shall be installed in wall cavities that have less than 1" of existing insulation.
 - Walls shall be insulated to minimum R-13 in 2x4 walls and R-21 in 2x6 walls or the highest R-value practical for the wall cavity space.
- When exterior wall cladding is replaced or installed over existing siding and windows are replaced, R-5 minimum exterior foam sheathing shall be installed.

Window Replacement: (Mandatory)

- When windows are replaced, all replacement windows must meet a minimum thermal heat transmission of U-0.30. An area weighted U-factor calculation may be used to demonstrate compliance.
- For homes with exhaust only ventilation systems, outdoor air inlets meeting the requirements of the Washington Ventilation and Indoor Air Quality Code shall be installed in new window frames.

Skylight Replacement: (Mandatory)

- When skylights are replaced, all skylights must meet a minimum thermal heat transmission of U-0.40.

Ductwork located in unconditioned and semi-conditioned spaces, including crawl spaces, attics and garage.

- All existing ductwork shall be inspected. Damaged ducts are to be repaired or replaced with new ductwork. All joints are to be inspected to assure they are mechanically fastened as required by the mechanical code. All duct joints and seams shall be sealed with mastic. All existing ducts shall be insulated to R-8 (2 ½ ") if the existing insulation is less than R-4 (1/1/2") insulation.

2. Simple Payback Method Option – (Mandatory)

As an alternative to the prescriptive building envelope measures, implement all building envelope measures that are demonstrated to provide a 10 year simple payback or less.

- Identify an engineer or energy auditor to conduct an energy analysis of the existing building condition and identify cost-effective energy improvements by preparing an energy improvement report.
- The report analyzes the current and projected energy performance of the building using energy simulation software.
- Analyze all of the mandatory prescriptive measures listed above.
- First costs are determined using actual bids for the project, or information from a similar project. First costs include only the contractor bid price. First costs do not include financing, overhead or profit.
- Cost of energy is calculated using local utility rates. If the local utility uses a block rate structure, the lowest block rate should not be used to calculate space conditioning energy cost. Use the second and third block rates.
- Simple payback is calculated as: first cost of the measure / first year energy cost savings.

3. Savings to Investment Ratio Option – (Mandatory)

Using TREAT Weatherization Evaluation Software, or an equivalent software, analyze all of the mandatory prescriptive measures listed above. Implement all measures that are demonstrated to provide a savings to investment ratio greater than 1.

For 5.2b: Simple Payback Method – Additional Points (5points)

Specify and install measures that provide greater energy efficiency than the prescriptive measures listed above as demonstrated by a 14-year simple payback calculation described above.

Notes: This Appendix was developed by Chuck Murray, Energy Policy Specialist, Department of Commerce, 360.725.3113, Chuck.Murray@commerce.wa.gov.

The prescriptive standards included here were adopted from the 5th Northwest Power Plan, with some modification. Since the 1980's, the Northwest Power Planning Council has developed a set of weatherization measures for regional adoption. They are analyzed for three regional climate zones. Zones 1 and 2 are in Washington State. The standards were developed using a detailed cost effectiveness calculation. They evaluate the life cycle cost to the building occupant, as well as impacts of savings on the regional rate payers.

Prior to making this recommendation, several additional sources were checked to confirm that measures, measure savings and cost figures were reasonable.

To confirm that the list of measures was not out of the ordinary:

- The weatherization specifications developed by Oak Ridge National Laboratory was consulted. This document was in agreement with the list of the applications. The R- values varied to some degree. ORNL staff contacted noted they are currently updating the R-values to reflect recent changes in fuel cost.
- The weatherization specifications developed by the Commerce weatherization program was consulted. Table 5.1 Draft Matrix of Weatherization Measures. This document also includes a similar set of measures, with somewhat different R-values. Commerce staff noted this table has not been updated to reflect the recent changes in fuel price.

To confirm that the cost in the Power Plan were not out of the ordinary, 2006 RS Means was consulted. There is some variation in the cost. Some cost are higher, some lower. But there were no cases where the cost differences were substantial.

Appendix

For insulation, the changes have been small. The level of insulation recommended for rehabilitation work has remained fairly constant since the early 1990's. The opportunities to make changes in existing structures have not changed over time. The physical limitations on access and space in attic crawl or wall systems have not changed. This document has included two variations from the Power Plan.

- All references to R-11 insulation have been changed to R-13.
- All references to R-19 for walls have been changed to R-21.
- In response to changes in fuel cost, the insulation measures are the same for all equipment and fuel types.

There are several mandatory measures that are only required as part of other work. This is because they are only cost effective when incorporated with the work noted. This includes:

- Window Replacement – U-factor: Window replacement is very expensive. It is not cost effective to replace windows simply for energy savings. But when windows are replaced, it is cost effective to purchase the most energy efficiency products available. The state energy code would require a U-35 window. The mandatory requirement for window replacement for this document is U-.30.
- Window Replacement – ventilation ports: The Washington State Ventilation and Indoor Air Quality Code requires outdoor air inlets as part of code compliance. For exhaust only ventilation systems, this is typically accomplished by providing small ports in the frame. This is a reasonable requirement for projects using this ventilation strategy when the windows are replaced.
- Foam Sheathing- Adding foam sheathing is cost effective when exterior cladding is being replaced or installed over existing siding. In addition, it is important to integrate the foam sheathing with the flashing details, especially with the windows. As a result, foam sheathing is only required when both the windows are being replaced and the cladding is replaced or new cladding is installed over existing siding.

Prescriptive air sealing measures have been included. This is simply a “find the hole, seal the hole” approach. For additional points, performance testing has been included.

In all cases, when air sealing work is conducted, a minimum standard for whole house ventilation needs to be included. Because there are very few people that can accurately assess the need for mechanical ventilation, it is mandatory in all cases. Also, it is likely that it will cost less to simply implement a ventilation strategy, than to analyze it.

Duct sealing and improved duct insulation was introduced during the early 1990's. The Power Plan would require the performance testing as noted in the optional measures. The prescriptive section was written to simply bring the existing ducts up to current energy code requirements. Use the Performance Tested Comfort Systems methodology, or an equivalent to take additional credit for air sealing. This method is required on all new Energy Star homes with duct systems.

Additional credit is assigned to performance testing for heat pump systems. Heat pumps need to have adequate air flow across the heating/cooling coil to achieve the rated performance.

Appendix

Performance Tested Comfort Systems methodology has been developed to meet this challenge. It is required on all new Energy Star homes with heat pumps.

Equipment upgrades during time of replacement are only included in the optional criteria. For most rehabilitation projects providing the most efficient replacement equipment would be cost effective. It is highly recommended. There are conditions where the cost of replacing existing venting systems or ductwork to accommodate contemporary systems is too costly to provide reasonable recovery.

Measure Name	Savings (kwh/yr)	Phys Life (yrs)	Capital Cost (\$2000)	Deemed
Single Family R0 to R19 Attic Insulation - Heating Zone 1	1.83	45.00	0.86	X
Single Family R0 to R19 Attic Insulation - Heating Zone 2	2.41	45.00	0.86	X
Single Family R19 to R38 Attic Insulation - Heating Zone 1	0.66	45.00	0.33	X
Single Family R19 to R38 Attic Insulation - Heating Zone 2	0.87	45.00	0.33	X
Single Family R0 to R19 Floor Insulation - Heating Zone 1	2.04	45.00	0.80	X
Single Family R0 to R19 Floor Insulation - Heating Zone 2	2.68	45.00	0.80	X
Single Family R19 to R30 Floor Insulation - Heating Zone 1	0.38	45.00	0.15	X
Single Family R19 to R30 Floor Insulation - Heating Zone 2	0.50	45.00	0.15	X
Single Family R0 to R11 Wall Insulation - Heating Zone 1	1.90	45.00	0.81	X
Single Family R0 to R11 Wall Insulation - Heating Zone 2	2.49	45.00	0.81	X
Single Family Infiltration Control - Heating Zone 1	0.24	20.00	0.16	X
Single Family Infiltration Control - Heating Zone 2	0.32	20.00	0.16	X
Single Family Energy Star Prime Window Replacement - Heating Zone 1	10.04	45.00	16.01	
Single Family Energy Star Prime Window Replacement - Heating Zone 2	13.17	45.00	16.01	
	2.49		1.19	

Measure Name	Savings (kwh/yr)	Phys Life (yrs)	Capital Cost (\$2000)	Deemed
Multifamily - R0 - R19 Attic insulation - Heating Zone 1	2.23	45.00	0.86	X
Multifamily - R0 - R19 Attic insulation - Heating Zone 2	3.26	45.00	0.86	X
Multifamily - R19 - R38 Attic insulation - Heating Zone 1	0.46	45.00	0.33	X
Multifamily - R19 - R38 Attic insulation - Heating Zone 2	0.66	45.00	0.33	X
Multifamily - Wall Insulation - Heating Zone 1	1.31	45.00	0.81	X
Multifamily - Wall Insulation - Heating Zone 2	1.91	45.00	0.81	X
Multifamily - R0 - R19 Floor insulation - Heating Zone 1	1.41	45.00	0.80	X
Multifamily - R0 - R19 Floor insulation - Heating Zone 2	2.05	45.00	0.80	X
Multifamily - R19 - R30 Floor insulation - Heating Zone 1	0.26	45.00	0.15	X
Multifamily - R19 - R30 Floor insulation - Heating Zone 2	0.38	45.00	0.15	X
Multifamily - Energy Star Prime Window Replacement - Heating Zone 1	9.58	45.00	16.01	
Multifamily - Energy Star Prime Window Replacement - Heating Zone 2	13.97	45.00	16.01	

APPENDIX C

Housing Trust Fund Handbook Section 207: Evergreen Sustainable Development Standard

207.1. Evergreen Sustainable Development Standard

The Evergreen Sustainable Development Standard (ESDS) is a building performance standard required of all affordable housing projects or programs receiving capital funds from the Housing Trust Fund after July 1, 2008.

The ESDS was developed in compliance with [RCW 39.35D.080](#) and contains 80 criteria safeguarding health and safety, increasing durability and sustainable living, preserving the environment, and increasing energy efficiency.

The ESDS [webpage](#) provides the latest edition of the ESDS Criteria, along with related forms, documents, and supporting information.

207.2. Evergreen Application Checklist

When applying to the Housing Trust Fund, project sponsors are required to submit an Evergreen Application Checklist. This form is submitted with the Stage 2 Application and is located within the Excel-format portions of the applications for both Multifamily and Homeownership. Project sponsors must also submit a total development budget and construction cost estimate that includes the sustainable features identified in their completed Evergreen Application Checklist.

The threshold point requirements on the Evergreen Application Checklist must be met for a project to receive full consideration during its application review.

If a project contains both rehab and new construction elements, it must comply with all the mandatory requirements. A separate Evergreen Application Checklist must be submitted for each element and the appropriate threshold number of points must be met for each.

Farmworker housing projects for seasonal occupancy-only have different criteria and threshold requirements, which are available upon request.

207.3. Evergreen Project Plan

Once the project receives an allocation of HTF funds, the project sponsor will submit the Evergreen Project Plan (EPP). The EPP consists of the following:

1. The EPP form, available on the ESDS [website](#).
2. Required attachments for each criterion. Each attachment should clearly indicate at the top of the page the applicable criterion. Attachments should show how the EPP meets requirements.

The specific EPP instructions within each criterion of the ESDS are noted like this:

Required Documentation for the Evergreen Project Plan

It is essential that these instructions are followed in order to produce an acceptable EPP. The third party verifier (3PV) will verify on site the measures outlined in the EPP. All mandatory criteria that apply to a given project must be included in the plans and specs, implementation, and construction.

HTF funds will not be disbursed until the EPP has been approved by Commerce. If at some point during development the project is found to be out of compliance with the ESDS, funds may be withheld by Commerce until the issue is resolved.

207.4. Evergreen Coordinator

The project sponsor must designate an Evergreen Coordinator (EC) as their agent regarding the implementation of the ESDS.

The EC will have the following responsibilities:

- Understand the specifications for all of the ESDS measures in the project.
- Prepare the Evergreen Application Checklist for the project sponsor to submit with their Stage 2 Application.
- Prepare the EPP for Commerce approval.
- Prepare and maintain the Evergreen Binder, ensuring that it is up-to-date with the appropriate technical submittals and available to the third party verifier (3PV) on the job site at all times.
- Communicate progress, coordinate site visits, and facilitate verification and quality control with the 3PV.
- Communicate with Commerce regarding EPP implementation during development.
- Oversee the development process to make sure that the ESDS features are implemented and correctly installed, and troubleshoot any ESDS problems with the general contractor or sub-contractors.

207.5. Third Party Verifier

Commerce uses a third party verifier (3PV) to conduct on-site inspections in a consistent, fair, and transparent manner. The goal is to verify the correct implementation of ESDS features without delaying construction. ESDS on-site inspections should be scheduled to coincide with draw inspections.

The responsibilities of the 3PV are:

- Initially review the project plans, specifications, and construction cost estimate to verify that the features and details in the EPP are included.
- Track the application and installation of the features and details of the Evergreen Project Plan during construction. Verify through direct observation that all measures are implemented and that the quality of the installation meets specifications. Additional documentation may be requested by the third party verifier from the Evergreen Coordinator as needed.
- Alert and inform Commerce about any emerging issues.
- Provide limited technical assistance to the EC while on site.
- Determine whether or not each individual ESDS feature in the EPP is installed appropriately and submit the results of these observations to Commerce during and after construction.

207.6. Evergreen Binder

The Evergreen Binder contains the documents necessary for the 3PV to complete their on-site review of the ESDS elements of the project. The Evergreen Binder is required to be on the job site, as well as complete and up-to-date throughout construction. The Evergreen Binder consists of the Contracts Document Table, the EPP and any necessary attachments. The Contracts Document Table and the instructions for the Evergreen Binder are located in an excel spreadsheet on the ESDS [webpage](#).

207.7. Steps in the Evergreen Development Process

Below is an outline of the step-by-step process required by the ESDS:

1. **Evergreen Application Checklist:** Project sponsor submits the Evergreen Application Checklist with the Stage 2 application and ensures that the ESDS features are included in the construction cost estimate and the outline plans and specs.
2. **HTF Application Review:** HTF review team evaluates the Evergreen Application Checklist to determine whether it passes the ESDS threshold requirements. If there are questions or concerns, the Evergreen Coordinator must resolve the issues. If Commerce does not receive needed information within Commerce's required timeframe, the project will be dropped from further consideration in that funding round.
3. **HTF awards:** When a project receives HTF funding, the EC prepares the complete Evergreen Project Plan.
4. **EPP Approval:** The EPP is sent to the HTF Project Manager assigned to the project. If there are questions or concerns, the EC must resolve the issues. The project sponsor will agree to a date by which all additional information will be submitted. **The HTF Contract Manager must approve the EPP prior to disbursement of any HTF funds.**
5. **Coordination with the Third Party Verifier:** The HTF Project Manager sends the approved EPP to the 3PV. The project sponsor sends the following to the 3PV:
 - a. plans and specifications
 - b. development budget
 - c. construction cost estimate
 - d. all other relevant construction documentation
6. **3PV Initial Oversight:** The 3PV compares all documents to confirm that the features listed in the EPP are reflected appropriately. If there are questions or concerns, the 3PV notifies Commerce and contacts the EC to resolve the issues.
7. **Evergreen Binder:** The EC assembles the Evergreen Binder in accordance with [Section 207.6](#) of this handbook.
8. **Voucher Requests:** Once the HTF contract is executed and any outstanding conditions have been met, the project sponsor can draw down funds using the current voucher reimbursement system. The EC coordinates and assists the 3PV with site visits to inspect ESDS features. The EC will contact the 3PV to schedule an on-site inspection to verify the installation and implementation of ESDS features. If a problem surfaces during development regarding agreed upon ESDS features, Commerce may withhold payment of voucher requests until the issue is resolved.
9. **Project Completion:** At the end of development, the 3PV evaluates all the site visits and documentation reviewed and makes a final recommendation to Commerce regarding whether or not the project meets the ESDS requirements. ESDS 8.1, 8.2, 8.3 and 8.4 are verified by the HTF Project Manager, not the 3PV. The HTF Project Manager may withhold payment of voucher requests until these documents are received. Once it is determined that all measures of the EPP have been met, Commerce will send a letter to the project sponsor confirming that the project has been built in compliance with the ESDS.

207.8. ESDS Waivers

The HTF's Evergreen Program Manager may consider ESDS waivers for specific ESDS Criteria to accommodate the variation in projects. To be considered for an ESDS waiver, the project sponsor must demonstrate that:

- the criterion creates an excessive hardship or is inadvisable for a specific project, AND
- an alternative path is identified and will be implemented that meets the intent of the criteria.

Project sponsors must submit ESDS waiver requests via email to the HTF Contract Manager. The HTF project manager will forward the request to the HTF Evergreen Program Manager for review.

207.9. Compliance

Should a completed project fail to meet threshold requirements, including verification of mandatory ESDS criteria, the project sponsor will be responsible for bringing the project up to the standard or implementing alternatives accepted and approved by Commerce. Failure to meet ESDS requirements at project completion may affect consideration of future funding requests.

The project sponsor is responsible for ensuring that the project is operated according to the Management Plan and the Owner's Manual. HTF field monitors will visit the project periodically while the HTF contract is in effect and assess whether or not the project is being managed according to these approved documents.

Introduction

1 Integrative Process

2 Location &
Neighborhood Fabric

3 Site Improvements

4 Water Conservation

5 Energy Efficiency

6 Materials

7 Healthy Living
Environment

8 Operations, Maintenance
& Resident Engagement

Appendix

Glossary

GLOSSARY

GLOSSARY

Adaptive plant species: A non-native plant species that performs similarly to a native species in a particular region, state, ecosystem, and habitat, and that 1) can survive temperature / weather extremes in the microclimate; 2) requires little irrigation or fertilization, once established; 3) is resistant to local pests and diseases; and 4) does not displace other plants, as invasives do.

Adaptive reuse site: An existing building that is being renovated to accommodate a new use, e.g., rehabilitating an old school for use as housing.

Air barrier: Air barriers are systems of materials designed and constructed to control airflow between a conditioned space and an unconditioned space. The air barrier system is the primary air enclosure boundary that separates indoor (conditioned) air and outdoor (unconditioned) air. In multi-unit/townhouse/apartment construction, the air barrier system also separates the conditioned air from any given unit and adjacent units.

www.buildingscience.com/documents/digests/bsd-104-understanding-air-barriers

Anti-Corrosive Coating: A coating formulated and recommended for use in preventing the corrosion of metal substrates.

ASHRAE (American Society of Heating, Refrigerating and Air-Conditioning Engineers) Standard 62.2-2010: Establishes minimum requirements for ventilation and acceptable indoor air quality in low-rise residential building. <http://www.ashrae.org/technology/page/548>

ASHRAE Standard 90.1-2007: Provides the minimum requirements for energy-efficient design of most buildings, except low-rise residential buildings. It offers, in detail, the minimum energy-efficient requirements for design and construction of new buildings and their systems, new portions of buildings and their systems, and new systems and equipment in existing buildings, as well as criteria for determining compliance with these requirements.

Berm: A sloped wall or embankment, typically constructed of earth, hay bales, or timber framing, used to prevent inflow or outflow of material into or out of an area. http://www.epa.gov/OUST/pubs/tum_appx.pdf

Building Performance Institute (BPI): A national standards development and credentialing organization for residential energy-efficiency retrofit work that provides training through a network of affiliate organizations, individual certifications, company accreditations, & quality assurance programs.

Brownfields: real property where the expansion, redevelopment, or reuse may be complicated by the presence of a hazardous substance, pollutant, or contaminant including petroleum. These sites require a Phase II Environmental Site Assessment and a remediation plan.

CFM (cubic feet per minute): A standard unit of measurement for airflow that indicates how many cubic feet of air are passing through a fixed point per minute.

Charrette: A focused and collaborative brainstorming session held at the beginning of a project to

bring people from different disciplines and backgrounds together to explore design options for a particular area or site. All stakeholders are encouraged to exchange ideas and information beyond their areas of expertise so as to allow truly integrative design solutions to take form.

Common area: An area available for use by more than one person, including rental or sales offices, entrances, hallways, shared leisure rooms, resident services areas, and laundry rooms.

CSA (Community-Supported Agriculture): A community of individuals who pledge support to a farm operation so that the farmland becomes the community's farm, with the growers and consumers providing mutual support and sharing the risks and benefits of food production. Typically, members of the farm or garden pledge in advance to cover the anticipated costs of the farm operation and the farmer's salary. In return, they receive shares in the farm's bounty throughout the growing season. Members also share in the risks of farming, including poor harvests due to unfavorable weather or pests. <http://www.nal.usda.gov/afsic/pubs/csa/csadef.shtml>

Compost blanket: A layer of loosely applied compost or composted material that is placed on the soil in disturbed areas to control erosion and retain sediment resulting from sheet-flow runoff. http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm?action=factsheet_results&view=specific&bmp=118&minmeasure=4

CO (carbon monoxide): A colorless, odorless, and tasteless gas that greatly affects indoor air quality. Because it is impossible to see, taste, or smell the toxic fumes, CO can kill you before you are aware it is in your home. At lower levels of exposure, CO causes mild effects that are often mistaken for the flu. These symptoms include headaches, dizziness, disorientation, nausea, and fatigue.

Critical habitat: is an area that the U.S. Fish and Wildlife Service or a state or tribal authority designates as occupied by a threatened or endangered species, or essential to the conservation of a threatened or endangered species. See, for example, Endangered Species Act, 16 U.S.C. 1523(5).

Critical slope area: is an area within a tract of land that has a greater than 15 percent change in elevation or an erodability factor of greater than 0.4 as determined by the Natural Resources Conservation Service of the USDA.

Dial-a-ride program: A privately or publicly operated program that provides an on-demand ride service, requiring passengers to call ahead to reserve a ride. These programs usually provide connections between different transportation systems and/or employment centers.

DU (distribution uniformity): A measure of the evenness of irrigation water coverage over a defined area. www.epa.gov/WaterSense/docs/home_finalspec508.pdf

ECM (electronically commutated motor): Also known as brushless DC motors, ECMs are synchronous motors that are powered by a DC electric source via an integrated

inverter/switching power supply that produces an AC electric signal. Used, for example, in HVAC equipment that uses electricity efficiently, particularly at lower speeds.

Emissivity: A unitless measure, describing the relative ability of a surface to emit heat through radiation, ranging from 0.00 (minimum radiation of heat) to 1.00 (maximum radiation of heat). Generally, more reflective materials have a lower emissivity.

Employer vanpool: A program in which 5 to 15 people (over the age of 16) ride together to and from work. The vanpool may be public or private, but must carry all passengers more than half the distance to work to qualify. Vanpools may be employer-operated, sponsored by transit agencies, or administered by third-party operators.

ENERGY STAR: A voluntary labeling program designed to identify and promote energy-efficient products to reduce greenhouse gas emissions. Introduced by the EPA in 1992, ENERGY STAR also offers an accepted national standard for certifying new residential construction projects. www.energystar.gov

Engineered wood products: Wood building materials manufactured by gluing particles, fibers or veneers to increase strength. For the purposes of Criterion 6.5 Certified, Salvaged and Engineered Wood Products, Green Communities considers prefabricated and precut wood products as “engineered wood products.” www.astm.org/SNEWS/JUNE_2003/yeh_jun03.html

Entryway: Threshold separating the indoor space from the outdoor space.

Environmental site assessment: An investigation of the site’s conditions often performed before acquisition of a property to satisfy the due-diligence requirements of a property transaction.

EPP: Abbreviation for Evergreen Project Plan.

Erosion blankets: Porous fabrics used for a variety of purposes, including separators, reinforcement, filtration and drainage, and erosion control. <http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm?action=browse&Rbutton=detail&mp=45&minmeasure=4>

Evergreen Application Checklist: When applicants apply for funding from the Housing Trust Fund, they are required to submit the Evergreen Checklist. This form lists all of the mandatory criteria required of the project and the optional criteria chosen for the project.

Evergreen Coordinator: The individual chosen by the project sponsor who is responsible for the implementation of the Evergreen Sustainable Development Standard. See [Chapter 2, Section 207.4 of the Housing Trust Fund Handbook](#) for specific requirements of the Evergreen Project Plan.

Evergreen Project Plan: The document submitted to the Housing Trust Fund outlining how a project specifically intends to meet the ESDS. It includes the Evergreen Project Plan form, and any necessary attachments, completed by the Evergreen Coordinator. See [Chapter 2, Section 207.3 of the Housing Trust Fund Handbook](#) for specific requirements of the Evergreen Project Plan.

ESDS: Abbreviation for Evergreen Sustainable Development Standard.

Filter sock: A mesh tube filled with composted material that is placed perpendicular to sheet-flow runoff to control erosion and retain sediment in disturbed areas.

<http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Formaldehyde: A chemical used widely by industry to manufacture building materials and numerous household products. Formaldehyde is also a byproduct of combustion and certain other natural processes, and thus may be present in substantial concentrations both indoors and outdoors. Health effects include eye, nose and throat irritation; wheezing and coughing; fatigue; skin rash; and severe allergic reactions. High levels of exposure may cause some types of cancer. www.epa.gov/iaq/formaldehyde.html

Greenfield: A previously undeveloped parcel of land.

Greyfields: previously developed vacant or underutilized sites, such as parking lots and shopping centers.

Green roof: A planted roof that reduces storm water runoff.

www.epa.gov/heatisland/mitigation/greenroofs.htm

Greywater: Wastewater produced from baths and showers, clothes washers, and lavatories. Greywater gets its name from its cloudy appearance and from its status as being neither fresh (as in potable water) nor heavily contaminated (as in black-water from toilet waste).

www.epa.gov/watersense/outdoor/rainwater_reuse.html

HERS Index (Home Energy Rating System Index): A scoring system established by the Residential Energy Services Network (RESNET) in which a home built to the specifications of the HERS Reference Home (based on the 2006 International Energy Conservation Code) scores a HERS Index of 100, while a net zero energy home scores a HERS Index of 0. The lower a home's HERS Index, the more energy-efficient it is in comparison to the HERS Reference Home. Each 1-point decrease in the HERS Index corresponds to a 1% reduction in energy consumption compared to the HERS Reference Home; thus a home with a HERS Index of 85 is 15% more energy-efficient than the HERS Reference Home, and a home with a HERS Index of 80 is 20% more energy-efficient.

Home Energy Rating: An analysis of a home's construction plans and onsite inspections. Based on the home's plans, the Home Energy Rater uses an energy-efficiency software package to perform an energy analysis of the home's design. This analysis yields a projected, pre-construction HERS Index. Upon completion of the plan review, the rater will work with the builder to identify the energy-efficiency improvements needed to ensure that the house will meet ENERGY STAR performance guidelines. The rater then conducts on-site inspections, typically including a blower door test (to test the leakiness of the house) and a duct test (to test the leakiness of the ducts). Results of these tests, along with inputs derived from the plan review, are used to generate the HERS Index score for the home.

HTF: abbreviation for Housing Trust Fund

IECC (International Energy Conservation Code): A model building energy code created by the International Code Council to set a minimum standard for energy efficiency; updated on a three-year schedule. www.iccsafe.org/

Intermittent rate: Ventilation that stops and starts at regular intervals (i.e., the opposite of continuous ventilation).

Local production: materials that are produced within 500 miles of the project site.

LED (light-emitting diode): Energy-efficient lights that produce less initial heat per lumen, consume less energy, and last longer than conventional incandescent and fluorescent lights.

Low-impact development: A strategy of site design where the goal is to restore the natural, pre-developed ability of an urban site to absorb stormwater. <http://water.epa.gov/polwaste/green/>

Maintained solar reflectance: A measure of a material's ability to maintain its initially rated solar reflectance. Products are tested over a period of three years.

Manual D: Manual prepared by the Air Conditioning Contractors of America (ACCA) on residential duct sizing. www.acca.org/technical-manual/manual-d/

Manual J: Manual prepared by ACCA on residential load calculations.
<http://www.acca.org/store/product.php?pid=172>

Manual S: Manual prepared by ACCA on residential equipment selection.
<http://www.acca.org/store/product.php?pid=154>

Moderate rehabilitation: a project whose scope of work comprises a work area less than 50% of the Gross Area of the affected building(s).

Native plant species: A plant species that occurs naturally in a particular region without direct or indirect human actions. http://web4.audubon.org/bird/at_home/PlantNativeSpecies.html

Naturescaping: A method of landscaping that reduces water use, energy consumption, and chemical needs by using climate-appropriate plants and maintenance techniques.

Non-buildable land: Land that is not economically feasible to be developed, such as easements, utility fall zones, unsuitable soil, steep grades, water features, wetlands, or natural preserves.

Noxious weeds: non-native plants that, once established, are highly destructive, competitive and difficult to control. They have economic and ecological impacts and are very difficult to manage once they get established. Some are toxic or a public health threat to humans and animals; others destroy native and beneficial plant communities.

Open space: Undeveloped land that is permanently set aside for public use. Open space may be used as community open space or preserved as green space, and includes parcels in conservation easement or land trust, park or recreation areas, and community gardens.

Phase I Site Assessment: is an investigation and a report regarding a specific site to satisfy the due-diligence requirements of an acquisition. The site assessment identifies existing or potential environmental contamination liabilities addressing both the underlying land and any physical improvements.

Phase II Environmental Site Assessment: is an investigation that collects original samples of soil, groundwater, or building materials to analyze for quantitative values of various contaminants and includes a report of the results.

Phase III Environmental Site Assessment: an investigation regarding the remediation of a contaminated site including a report that documents the steps in the cleanup and the monitoring of residual hazardous substances.

Permeable paving: A porous cover system that encourages groundwater recharge and infiltration. <http://www.epa.gov/oaintrnt/stormwater/pavers.htm> and http://www.epa.gov/greeningepa/stormwater/best_practices.htm

Phenol-formaldehyde: A resin used in the manufacture of composite wood products primarily for outdoor use, including softwood plywood and flake or oriented strand board. Composite wood products that contain phenol-formaldehyde generally emit formaldehyde at lower rates than those containing urea formaldehyde resin. <http://www.epa.gov/iag/formalde.html>

Photocell: A light-sensitive device that detects ambient light and controls exterior fixtures accordingly.

Photovoltaics: Composite materials that convert sunlight directly into electrical power.

Post-consumer waste: Materials or finished products that have served their intended use and so have been diverted or recovered from waste destined for disposal.

Post-industrial waste (also called pre-consumer waste): Materials generated in manufacturing and converting processes such as manufacturing scrap and trimmings and cuttings.

Project Sponsor: The sponsoring organization who submits the HTF application and who will contract with Commerce to complete the project. Also called the “Applicant.”

Public-private regional transportation: Private company offering public transit services through a public funding stream, based on a regular schedule and permanent stops.

Radon: A colorless, odorless, and tasteless gas that greatly affects indoor air quality. According to the EPA, radon exposure is the second leading cause of lung cancer in the United States.

Resilience: The capacity to adapt to changing conditions and to maintain or regain functionality and vitality in the face of stress or disturbance. Relative to climate change, resilience involves adaptation to the wide range of regional and localized impacts that are expected with a warming planet: more intense storms, greater precipitation, coastal and valley flooding, longer and more severe droughts in some areas, wildfires, melting permafrost, warmer temperatures, and power outages. www.resilientdesign.org/.

Resilient flooring: Flooring products in which the wearing surface is non-textile, including but not limited to rubber, polymeric, and linoleum.

<http://webstore.ansi.org/RecordDetail.aspx?sku=NSF%2FANSI+332-2010>

RESNET (Residential Energy Services Network): A national, nonprofit corporation that certifies raters to evaluate building energy performance using HERS. www.resnet.us

Retention basin: A shallow impoundment, sometimes referred to as a “wet detention pond,” designed to capture and retain stormwater runoff during storm events.

http://water.epa.gov/scitech/wastetech/upload/2002_06_28_mtb_wetdtnpn.pdf

Road section: The cross-section through a street, with particular attention paid to the width of the street and its hydrology. Carefully planned road sections can decrease the amount of impervious surfaces and can improve the overall stormwater management for the project site. More information can be found in the document *Low-Impact Development Design Strategies: An Integrated Design Approach*, found at <http://water.epa.gov/polwaste/green/>

Rock filter: A permanent or temporary stone structure installed to serve as a sediment-filtering device in drainage ways. Allows a pool to form in an excavated or natural depression, where sediment can settle. The pool is then dewatered through the gravel rock dam.

<http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Rural:

For the purposes of ESDS, a rural area or community is defined as follows:

- a) Counties with a population of less than 90,000, except for cities within these counties with a population greater than 25, 000.
- b) Counties with a population greater than 90,000 but less than 390,000 when more than an aggregated 25% of that county’s population resides in one metropolitan area. In this case, the county except such metropolitan area would be considered rural; for Example, Yakima County except the City of Yakima.

Silt fencing: A temporary fabric barrier surrounding a site to control stormwater runoff.

<http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Silt sacks: Tube-shaped erosion-control devices.

<http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Slab: One type of foundation, with many variations (monolithic slabs, floating slabs, rat slabs, in conjunction with a basement, etc.), that may be above, at or below grade. Wood frame crawl foundations are an alternative to slabs.

Solar hot water system: Captures, converts, and transfers heat from direct and indirect sunlight to heat an auxiliary water tank and provide hot water for a building’s occupants.

Solar reflectance (or albedo): A measure of a material's ability to reflect sunlight (including the visible, infrared, and ultraviolet wavelengths) on a scale of 0 to 1. A solar reflectance value of 0.0 indicates that the surface absorbs all solar radiation, and a 1.0 solar reflectance value represents total reflectivity.

Solar south: A measurement of the sun's true position based on its path across the sky. It is different from magnetic south, which is taken from a compass reading. Methods for calculating solar south include the solar noon method or a compass using a magnetic declination chart to correct for magnetic declination.

Straw bale: A bound block of straw and organic material used to control stormwater runoff. <http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Substantial Rehab: A project that includes the replacement and/or improvement of at least two major systems of the building, including its envelope. Major building systems include roof structures, wall or floor structures, foundations, plumbing, heating and air conditioning, and electrical systems. The building envelope is defined as the air barrier and thermal barrier separating exterior from interior space.

Swales: Shallow grass-covered hydraulic conveyance channels that help to slow runoff and facilitate infiltration. www.epa.gov/greeningepa/stormwater/best_practices.htm

T8 fixture: A fixture made up of a tubular fluorescent bulb and an electronic ballast, both operating with a higher efficacy than traditional tubular fluorescent design technology, such as the T12 bulb and magnetic ballast.

Third Party Verifier: The individual(s) hired by the Department of Commerce who are responsible for conducting on-site inspections to verify compliance with the Evergreen Sustainable Development Standard. See [Chapter 2, Section 207.5 of the Housing Trust Fund Handbook](#) for specific requirements of the Third Party Verifier.

Tiers: Earthen embankments that reduce erosion by slowing, collecting, and redistributing surface runoff to stable outlets that increase the distance of overland runoff flow. <http://water.epa.gov/polwaste/npdes/swbmp/Construction-Site-Stormwater-Run-Off-Control.cfm>

Transit ride: A scheduled stop along a defined route of one form of public transportation (bus, rail, or ferry).

Universal design: The design of products and environments to be usable by all people, to the greatest extent possible, without the need for adaptation or specialized design. The principles of universal design are as follows: 1) equitable use, 2) flexibility in use, 3) simple and intuitive use, 4) perceptible information, 5) tolerance for error, 6) low physical effort, and 7) size and space for approach and use. <http://www.ncsu.edu/www/ncsu/design/sod5/cud/>

Urea-formaldehyde: A toxic resin created from formaldehyde that causes similar side effects.

Composite wood products made for indoor use, such as particleboard, hardwood plywood paneling, and medium-density fiberboard, often contain this resin. www.epa.gov/iaq/formaldehyde.html

Urban: For the purposes of ESDS, an urban area or community is defined as any municipality with a population greater than 25,000, and which does not fall into the definitions of rural.

Vehicle share program: A private system in which a company or a group of individuals share vehicles on a reservation basis and pay for the use on the basis of time or mileage. Programs that qualify under Criterion 2.15 must have an established formal agreement among participants.

Ventilation: The process of supplying outdoor air to, or removing indoor air from, a dwelling by natural or mechanical means. Such air may or may not have been conditioned.

VOCs (Volatile Organic Compounds): A large group of carbon-based chemicals that easily evaporate at room temperature. www.epa.gov/iaq/voc.html

Waiver Request: Recognizing a need for some flexibility given the variation in projects, waivers for specific ESDS Criteria may be considered. The project sponsor must demonstrate that the criterion creates an excessive hardship or is inadvisable for a specific project, AND that an alternative path is identified and will be implemented that meets the intent of the criteria. [Housing Trust Fund Handbook Chapter 2 section 207.8](#)

Walk distance: The distance a pedestrian must travel between origins and destinations without obstruction, in a safe and comfortable environment on a continuous network of sidewalks, all-weather-surface footpaths, crosswalks, or equivalent pedestrian facilities. Any crossing of a street with speeds at or greater than 30 miles per hour requires controlled crossing (e.g., a stop sign or stop light).

Watershed: The area of land where all of the water that is under it or drains off of it goes into the same place. <http://water.epa.gov/type/watersheds/whatis.cfm>

Xeriscaping: A method of landscaping aimed at reducing or eliminating excess water from irrigation by using drought-tolerant plants.

3PV: Abbreviation for Third Party Verifier
