

# Seattle Public Utilities Post-Earthquake Water System Performance Goals

Water System Advisory Committee  
November 18, 2015


# Presentation Outline

- Background
  - Performance of Water Systems in Past Earthquakes
  - Previous SPU Seismic Mitigation Activities
  - SPU Water System Seismic Study
- Post-Earthquake Water System Performance Goals
  - Purpose
  - Examples From Other Utilities
- SPU Post Earthquake Water System Goals
  - Development Process
  - Draft Goals



# Loma Prieta (San Francisco) - 1989

- M6.9 (epicenter 60 miles south/southeast of San Francisco)
- Approximately 1000 watermain breaks
- Water system damage mostly in areas of poor soils
  - Water outage durations usually less than a few days
  - Fire suppression water was an issue in Marina District




# Northridge - 1994



- M6.7 (previously unknown fault)
- Over 1000 watermain breaks
- Over 100 fires
- Water system damage mostly in areas of poor soils
- Outage durations over 8 to 13 plus days

# Kobe (Hyogo-Ken Nanbu) – 1995 (M6.9)

- Over 1700 Pipe Breaks Just in Kobe
- 109 Kobe Fire Ignitions Immediately After Earthquake (Another 88 in Surrounding Cities)
- 60 Days Plus for Restoration of Service




“Substantial” Restoration  
(March 18)



# 2011 Christchurch Earthquake (M6.2)



- 1645 Watermain Breaks (February 2011 Earthquake) in Christchurch
- Limited Number of Fire Ignitions
- 45 Days Plus for Restoration of Service

Timeline of Events after 22nd February Earthquake




# Tohoku (East Japan) – 2011 (M9.0)

- Water Systems of Over 180 Municipalities Affected
- 345 Fire Ignitions
- 45 Days Plus for Substantial Restoration of Service



# Pacific Northwest Earthquake Sources

(Washington State Department of Natural Resources and USGS)




Source	Max. Size	Recurrence
● Subduction zone	M 9+	200–600 years
● Deep Juan de Fuca plate	M 7+	30–50 years
● Crustal faults	M 7+	Hundreds of years?

\*figure modified from USGS Cascadia earthquake graphics at <http://geomaps.wr.usgs.gov/pacnw/pacnweq/index.html>




# Previous Earthquake Vulnerability Assessments

- Cygna Study of Water System Facility Vulnerability (1990)
- System Response to Pipeline Breaks
  - Kennedy/Jenks/Cilton 1990
  - Water Research Foundation 2009
- Miscellaneous Individual Facility Assessments




# SPU Earthquake Hazards – 1990 and 2015



# Estimated/Preliminary SPU Water System Performance to M6.5 to M7.5 Seattle Fault Event

- Performance Likely Similar to Kobe and Christchurch
- Cedar and Tolt Transmission Systems
  - Loss of at Least Cedar System
  - 3 to 7 Days for Partial (50%?) Restoration
  - One to Two Months For Substantial Restoration
- Distribution (Direct Service) System
  - Loss of Pressure Throughout System Possible Within 8 to 12 Hours After Earthquake
  - Water Service Restoration
    - 50% ± After 14 Days
    - 45 to 60 Days to Reach Nearly 100% Restoration

# Customer Service Restoration Expectations Following a Major Earthquake



# SPU Water System Seismic Study

## - Project Goals

- **Establish post-earthquake water system performance goals**
- Preliminary critical facility seismic vulnerability assessments
  - Defined earthquake scenarios
  - ASCE/SEI 7-10 (Code Assessment)
- Overall post-earthquake water system performance
- Develop planning level mitigation measures, cost estimates and timeframe to meet service level goals
- Define seismic design standards for water transmission and distribution pipelines



# Post-Earthquake Water System Performance Goals

- Define water availability and water service restoration time after an earthquake
- Purposes
  - Establish acceptable water system post-earthquake performance
  - Define seismic program objectives
  - Provide others with expected system performance so they know what to expect and prepare for

# SFPUC Performance Goals

- “The basic “Level of Service” criterion shall be to deliver winter day demand (WDD) of 215 million gallons per day (MGD) (February 2030 demand) within 24 hours after a major earthquake.
- Deliver WDD to at least 70% of SFPUC wholesale customers’ turnouts within each of the three customer groups (Santa Clara/Alameda/South San Mateo County, Northern San Mateo County, and City of San Francisco).
- Achieve a 90% confidence level of meeting the above goal, given the occurrence of a major earthquake.

# EBMUD Performance Goals

Table A-2. Water System Service Goals - Probable Earthquake (EBMUD)

Service Category	Probable Earthquake
General	1 Minimal secondary damage and risk to the public
	2 Limit extensive damage to system facilities
	3 All water introduced into the distribution system minimally disinfected
	4 All water introduced into the distribution system fully treated
Fire Service	5 Sufficient portable pumps and hose to provide limited fire service in all areas
	6 All areas have minimal fire service (one reliable pumping plant and reservoir)
	7 High risk areas have improved fire service (all facilities reliable, minimum fire reserves)
	8 Normal service to all hydrants within 20 days
Hospitals and Disaster Centers	9 Minimum service to affected area within 1 day (water available via distribution system near each facility)
	10 Impaired service to affected area within 3 days (water available via distribution system to each facility, possibly at reduced pressures)
Domestic Users	11 Potable water via distribution system or truck within 1 day
	12 Impaired service to affected area within 3 days (water available via distribution system to each domestic user, possibly at reduced pressures)
Commercial, Industrial and Other Users	13 Impaired service to affected area within 3 days (water available via distribution system to each commercial or industrial user, possibly at reduced pressures)

Table A-3. Water System Service Goals - Maximum Earthquake (EBMUD)

Service Category	Maximum Earthquake
General	1 Minimal secondary damage and risk to the public
	2 Limit extensive damage to system facilities
	3 All water introduced into the distribution system minimally disinfected
	4 All water introduced into the distribution system fully treated
Fire Service	5 Sufficient portable pumps and hose to provide limited fire service in all areas
	6 All areas have minimal fire service (one reliable pumping plant and reservoir)
	7 High risk areas have improved fire service (all facilities reliable, minimum fire reserves)
	8 Normal service to all hydrants within 100 days
Hospitals and Disaster Centers	9 Minimum service via distribution system or truck within 3 days
	10 Minimum service within 10 days (water available via distribution system near each facility)
	11 Impaired service within 30 days (water available via distribution system to each facility, possibly at reduced pressures)
Domestic Users	12 Potable water at central locations for pickup within 3 days
	13 Minimum service to 70% of customers within 10 days
Commercial, Industrial and Other Users	14 Potable water at central locations for pickup within 1 week
	15 Minimum service to 70% of customers within 10 days
	16 Impaired service to 90% of customers within 30 days (water available via distribution system to 90% of commercial or industrial users, possibly at reduced pressures)

# Oregon Resiliency Plan Performance Goals

TARGET STATES OF RECOVERY: WATER & WASTEWATER SECTOR (VALLEY)											
	Event occurs	0-24 hours	1-3 days	3-7 days	1-2 weeks	2 weeks-1 month	1-3 months	3-6 months	6 months-1 year	1-3 years	3+ years
Domestic Water Supply											
Potable water available at supply source (WTP, wells, impoundment)		R	Y		G			X			
Main transmission facilities, pipes, pump stations, and reservoirs (backbone) operational		G					X				
Water supply to critical facilities available		Y	G				X				
Water for fire suppression—at key supply points		G		X							
Water for fire suppression—at fire hydrants				R	Y	G			X		
Water available at community distribution centers/points			Y	G	X						
Distribution system operational			R	Y	G				X		

## TARGET TIMEFRAME FOR RECOVERY:

*Desired time to restore component to 80-90% operational*

*Desired time to restore component to 50-60% operational*

*Desired time to restore component to 20-30% operational*

*Current state (90% operational)*

G
Y
R
X

# Performance Goal Development

## – Stakeholder Input


- Public/Direct Service Customers
  - Survey/Choice Experiment (Willingness to Pay)
  - Water System Advisory Committee
- Wholesale Customers (Operating Board)
- City Leadership
  - Fire Department
  - SPU
  - Emergency Executive Board
- SPU Water LOB Staff



# Performance Goal Development

## – Seismic Study Findings

- Consultant Recommendations
- Cost Considerations



# Milestones/Target Dates

- Consultant and Stakeholder Review
  - May 1, 2015 through October 31, 2016
- Development of Mitigation Options/Costs to Meet Performance Goals
  - June 1, 2016 through July 31, 2016
- Modification of Performance Goals to be Consistent with Seismic Study Findings
  - July 1, 2016 through September 30, 2016
- Final Performance Goals
  - November 1, 2016

# Emergency Executive Board Input

- Review Performance Goals
- Provide Input and Reaction to Bill Heubach ([Bill.Heubach@Seattle.Gov](mailto:Bill.Heubach@Seattle.Gov), 684-0623) with Questions, Comments and Suggestions by December 31, 2015
- SPU Report Back to Emergency Executive Board
  - Spring/Summer 2016: Performance Goals for Earthquake Mitigation Development
  - Summer/Fall 2016: Cost to Achieve Performance Goals

**DRAFT (November 2015) Post-Earthquake Water System Level of Service Goals - 2035**  
**Surface Fault or Cascadia Subduction Event**

		<b>Immediately After</b>	<b>24 Hours</b>	<b>3 Days</b>	<b>7 Days</b>	<b>14 Days</b>	<b>1 Month</b>
<b>Water Supply at Wholesale Meters</b>	Minimum Water Volume	Winter Demand	Winter demand	Winter demand	Winter Demand	Winter Demand	Normal
	Water Quality	Non Potable	Non Potable	Non Potable	Non Potable	Potable	Potable
	Water Availability	50% of Meters	50% of Meters	50% of Meters	75% of Meters	100% of Meters	100% of Meters
<b>Fire Suppression Water – Designated Supply Points (e.g., reservoirs and tanks)</b>	Minimum Water Volume	300,000 gallons per location	150,000 gallons per location	Full storage capacity	Full storage capacity		
	Water Availability	90% of Supply Points	75% of Supply Points	75% of Supply Points	100% of Supply Points		
<b>Water Supply at Hydrants and Retail Meters</b>	Water Quality	Non Potable	Non Potable	Non Potable	Non Potable	Non Potable	Potable
	Water Availability	50%	50%	60%	75%	90%	100%
<b>Water Supply for Critical Retail Customers (e.g., hospitals)</b>	Water Quality	Non Potable	Non Potable	Non Potable	Non Potable	Non Potable	Potable
	Water Availability	50% of critical customers	50% of critical customers	100% of critical customers	100% of critical customers	100% of critical customers	100% of critical customers
<b>Water Supply at Retail Customer Emergency Supply Points</b>	Water Quality	Potable	Potable	Potable			
	Water Availability	0%	50%	100%			

**DRAFT (November 2015) Post-Earthquake Water System Level of Service Goals - 2065**  
**Surface Fault or Cascadia Subduction Event**

		<b>Immediately After</b>	<b>24 Hours</b>	<b>3 Days</b>	<b>7 Days</b>	<b>14 Days</b>	<b>1 Month</b>
<b>Water Supply at Wholesale Meters</b>	Minimum Water Volume	Winter demand	Winter demand	Winter demand	Winter demand	Normal	
	Water Quality	Non Potable	Non Potable	Non Potable	Potable	Potable	
	Water Availability	50% of Meters	75% of Meters	100% of Meters	100% of Meters	100% of Meters	
<b>Fire Suppression Water – Designated Supply Points (e.g., reservoirs and tanks)</b>	Minimum Water Volume	300,000 gallons	150,000	Full storage capacity			
	Water Availability	90% of Supply Points	90% of Supply Points	100% of Supply Points			
<b>Water Supply at Hydrants and Retail Meters</b>	Water Quality	Non Potable	Non Potable	Non Potable	Potable	Potable	
	Water Availability	67%	67%	75%	90%	100%	
<b>Water Supply for Critical Retail Customers (e.g., hospitals)</b>	Water Quality	Non Potable	Non Potable	Non Potable	Potable		
	Water Availability	90% of critical customers	90% of critical customers	100% of critical customers	100% of critical customers		
<b>Water Supply at Retail Customer Emergency Supply Points</b>	Water Quality	Potable	Potable				
	Water Availability	90%	100%				



# Performance Goal Comparison

## - Water Supply at Wholesale Meters

[illegible]

# Performance Goal Comparison – Supply Points

[illegible][illegible]

# Performance Goal Comparison – Retail Meters

### Water Supply at Hydrants and Retail Meters

[illegible]

### Water Supply for Critical Retail Customers (e.g., hospitals)

[illegible]

QUESTIONS?

COMMENTS?

SUGGESTIONS?