

•

FINAL REPORT

TRANSMISSION RIGHTS-OF-WAY VEGETATION MANAGEMENT PLAN

Prepared For

SEATTLE CITY LIGHT

PROJECT MONITOR MARY BOLDT

Prepared By

COMPLIANCE SERVICES INTERNATIONAL DAMES & MOORE, INC. and DON SHIMONO ASSOCIATES

> PROJECT MANAGER DIANA Z. DUKE

February, 1990

. .

•

This copy of the Transmission Rights of Way Vegetation Management Plan includes the Aesthetic Impact Evaluation and related appendixes for submittal to the Federal Energy Regulatory Commission (FERC). Section 2.0, Herbicide Use Evaluation and Section 4.0, Survey of Rare Plant Species, with related appendixes, have been omitted from this version. The latter section was submitted to the FERC as a separately bound report on October 30, 1989.

April 27, 1990

. . .

'n

•

EXECUTIVE SUMMARY

In December of 1983, Seattle City Light (SCL) adopted policy and procedures for maintenance of the utility's transmission rights-of-way (ROW). Policy objectives highlight a concern for continual worker safety and uninterrupted transmission of power along the network system. The proper management of vegetation within and bordering the ROW corridors is, therefore, of primary importance. With regard to vegetation management, the Department's policy supported the aggressive investigation, evaluation and, where feasible, implementation of an integrated vegetation management approach along ROW corridors.

In response to its own Departmental goals and with a sensitivity to the multiple-uses inherent with the administration of the public lands within the Ross Lake National Recreation Area (NRA), SCL contracted a study to evaluate opportunities to enhance their Integrated Vegetation Management Program along the 20-mile segment of the Skagit line that transects the NRA. Vegetation management issues that are correlated with herbicide use, aesthetic impacts, and identification of threatened, endangered and sensitive plant species were targeted for evaluation.

SCL currently uses the herbicide dicamba (Banvel) to treat the noxious weed, tansy ragwort, and to control regrowth of cut broadleaf stumps. A comprehensive technical review of this compound and a similar review of appropriate herbicide alternatives has shown that a number of other compounds may have properties which are of use in the Department's Vegetation Management Program. Five compounds (glyphosate, imazapyr, sulfometuron, tebuthiuron and triclopyr) were included with dicamba in the data review process. A data matrix summarizing the toxicological, chemical and environmental fate properties of the compounds has been constructed. The data profile of all compounds is sufficient for making comparative use selections based on (1) the control need and (2) the environmental conditions of the surrounding areas. Comparative costs are also presented for equivalent hypothetical use situations.

The North Cascades Highway (SR20) is the primary transportation corridor that provides access to the numerous locations suitable for scenic viewing and recreation offered by the NRA. The Skagit Hydroelectric Power Project's 230 kV transmission system alignment runs parallel to much of this highway in the NRA.

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE i

. . .

·

An inventory was conducted of the Skagit transmission towers, lines and ROW corridor visible from the North Cascades Highway. Site reconnaissance and consultation with SCL personnel resulted in the identification of seven areas (Aesthetic Target Areas) in the project area that were recommended for visual impact reduction. The Aesthetic Target Areas are located along SR20 and within the Ross Lake National Recreation Area between Bacon Creek and Ross Dam. A range of vegetative management scenarios to mitigate the visual impacts of the seven Aesthetic Target Areas are proposed in the form of Vegetation Mitigation Management Prescriptions.

Field surveys were conducted to investigate the potential occurrence of threatened, endangered and sensitive species along the entire Skagit ROW corridor in the NRA. A list was developed of rare species that could potentially occur in the study area. Field searches were not limited to locating new populations of previously reported rare plants. Rather, a floristic survey was perfomed, where each species observed was identified to a taxonomic level that would allow a determination of its rarity. Results of the survey indicate that no rare plant populations occur in the study area. New populations of state or federally listed or candidate rare plants were not found during the field surveys. No modifications are required in vegetation management practices with regard for the protection to rare plant species.

•

.

. .

TABLE OF CONTENTS

ļ

,

EXECUTIVE SUMMARY	. i
1.0 PROJECT INTRODUCTION	1-1
1.1 PROJECT STUDY AREA	1-1
2.0 HERBICIDE USE EVALUATION	2-1
2.1 OPTIONS AVAILABLE FOR CHEMICAL WEED CONTROL	2-1
2.1.1 Application Alternatives	2-1
2 1 2 Explanation of Pesticide Terminology	2-2
2.1.2 Explanation of resticide leminology 2.1.3 Herbicide Compounds Available for Pights-Of-Way Uses	2-3
2 1 A Servering Criteria for Final Compounds	2-3
2.1.4 Screening criteria for rinar compounds	26
	2-0
2.1.5 Options of Hignest Interest	2-9
2.2 OVERVIEW OF COMPOUNDS AND RESEARCH	2-12
2.2.1 General Compound Characteristics	2-12
2.2.1 Search Strategy	$\frac{-12}{2-12}$
2.2.1 Detron berutegy :	2 12
2.2.5 Data Reporting	2-13
2.3 HERBICIDE DATA MATRIX	2-16
2.3.1 Identification	2 - 17
2 3 2 Chemical Data	2 ± 7 2 ± 17
	2^{-1}
	2-19
$2.3.4 \text{TOXICITY} \dots \dots \dots \dots \dots \dots \dots \dots \dots $	2-22
2.3.5 Wildlife and Aquatic Organisms	2-25
2.4 HERBICIDE USE	2-50
2.4.1 Specific Target Vegetation	2-50
2 A 2 Herbicide Choice	2_51
$2.4.2 \text{Merbicide Choice} \dots \dots \dots \dots \dots \dots \dots \dots \dots $	2-51 2-51
2.4.3 Dicamba vs. Other Herbicides	2-53
2.5 HERBICIDE COSTS	2-54
3.0 AESTHETIC IMPACT EVALUATION	3-1
3.1 INTRODUCTION	3-1

·

. . .

	3.2	EVALUATION APPROACH	•	•	•	•	3-3
		3.2.1 Data Collection and Review	•	•	•	•	3-3
		Consultation	•	•	•	•	3-3
		3.2.3 Visual Impact Determination	•	٠	•	•	3-4
	3.3	AESTHETIC TARGET AREAS (ATA)	•	•	•	•	3-5
	3.4	DEVELOPMENT OF VISUAL IMPACT MITIGATION RECOMMENDATIONS	•	•	•	•	3-20
	3.5	VEGETATION MITIGATION PRESCRIPTIONS	•	•	٠	•	3-20
		3.5.1 Prescription Goals and Objectives 3.5.2 Aesthetic Target Area Prescription Play	ns	•	•	•	3-20 3-30
	3.6	PROGRAM IMPLEMENTATION BY SEATTLE CITY LIGHT	•	•	•	•	3-38
4.0	SURVI	EY OF RARE PLANT SPECIES	•	•	•	•	4-1
	4.1	INTRODUCTION	•	•	•	•	4-1.
	4.2	STUDY AREA	•	•	•	•	4-2
	4.3	METHODS	•	•	-	•	4-2
		4.3.1 Identification of Rare Plant Species					
		Potential Occurrence	•	•		•	4-2
		4.3.2 Field Surveys	•	•	٠	•	4-5
	4.4	RESULTS	•		•	•	- 4-6
	4.5	DISCUSSION	•	•	•	•	4-6
		4.5.1 Effects of Transmission Line Operation and Rights-Of-Way Maintenau	nce	•	•	•	4-6
		4.5.2 Management Recommendations	•	•	•	٠	4-6

REFERENCES

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE iv

LIST OF FIGURES

FIGURE NO.	<u>. TITLE</u>	P	AG	<u>e no.</u>
1-1	Project Vicinity Map	٠	•	1-3
1-2	Project Transmission Corridor	•	•	1-4
3-1	Aesthetic Target Areas	•	•	3-6
3-2	Type-A T-Line Corridor Profile Planting	•	-	3-24
3-3	Type-B Corridor Edge Planting	.•	. •	3-25
3-4	Type-C Wide Corridor Planting	•	•	3-26
3-5	Type-D Roadside Planting	•	•	3-27
3-6	Type-E T-Line Crossing Planting	•	•	3-28
3-7	Type-F Perpendicular Exposed Corridor Planting .	•	•	3-29
3-8	Bacon creek Target Area 1	•	•	3-31
3-9	Pinkies Target Area 2	•	•	3-32
3-10	Thornton Creek Target Area 3	•	•	3-33
3-11	Goodell Creek Target Area 4	•		3-34
3-12	Gorge Dam Viewpoint Target Area 5	•	٠	3-35
3-13	Diablo "Y" Target Area 6	•	•	3-36
3-14	Diablo Overlook Target Area 7	•	•	3-37
3-15	Projected Vegetation Maintenance Program	•	•	3-39

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT,

· <u>-</u> ' _

LIST OF TABLES

TITLE FIGURE NO. Compounds Commonly used for Right-Of-Way Weed 2 - 1Control in Washington 2 - 4Comprehensive List of Compounds Registered For 2 - 2Non-Cropland Weed Control 2-5 State Restricted Use Pesticides For Use By 2 - 3Certified Applicators Only 2-7 Compounds Most Commonly Used In Western 2 - 4Washington Noxious Weed Control Programs . . . 2-8 Compounds of Interest for Right-Of-Way 2-5 Maintenance 2-10 Ranges for Activity Values - Herbicides 2-6 2-7 Dialog Information Services - Databases 2-15 2-8A through 2-8F 2 - 92 - 10USEPA Toxicity Classification of Products Reviewed . 2-48 2 - 112 - 123-1 Seattle City Light T-Line vegetation Management Aesthetic Target Area Visual Impact Determination . 3-8 3 - 2Habitats of Potential Species 4-3 4-1

PAGE NO.

•

LIST OF APPENDICES

- Appendix A Pacific Northwest Weed Control Manual
- Appendix B Specimen Labels for Compounds of Interest Banvel (Diamba) Roundup (Glyphosate) Arsenal (Imazapyr) Oust (Sulfometuron Methyl) Spike (Tebuthiuron) GarlonTM 3A (Triclopyr)
- Appendix C U. S. EPA Data Requirements for Registration of Pesticides for Terrestrial Non-food, Aquatic Non-Food, and Forestry Use
- Appendix D Herbicide Use Evaluation Bibliography
- Appendix E U. S. EPA Glossary of Environmental Terms
- Appendix F Washington Park Wilderness Act of 1988 (Public Law 100-668)
- Appendix G Proximity to Overhead Power Lines (WAC 296-24-960)
- Appendix H Safety Standards for Electrical Construction Code (WAC 296-44-21230)
- Appendix I Seattle City Light Transmission Row Plant Species Inventory
- Appendix J Washington Natural Heritage Program Letters Reporting Plant Populations in North Cascades National Park and Whatcom and Skagit Counties

. .

-

. .

·

. .

·

.



·

. .

·

z.

1.0 PROJECT INTRODUCTION

1.1 PROJECT STUDY AREA

The Ross Lake National Recreation Area (NRA) is one of four major and contiguous park units that comprise the North Cascades National Park Service Complex, an area which is noted for its natural scenic beauty and multitude of recreational attractions. The NRA divides the neighboring North Cascades National Park into its north and south units. Lake Chelan National Recreation Area is the third park unit of the complex. It is located at the southern boundary of the North Cascades National Park - South Unit. The configuration of the NRA follows the Skagit River drainage from the north at the Canadian/United States border southward and then continues in a general southwest direction. Lands within the Ross Lake National Recreation Area are administered by the National Park Service (NPS).

The project study area (Figure 1-1, Project Vicinity Map) is defined as the Seattle City Light (SCL) Skagit transmission line rights-of-way (ROW) corridors located in the NRA. The eastern boundary of the project study area is located at Ross Dam which is approximately 1,200 feet (ft) above mean sea level. The western boundary of the NRA is located at the confluence of the Bacon Creek tributary to the Skagit River (approximately 800 ft above mean sea level). The north and south boundaries of the project study area correspond with the ROW boundaries.

Of the 190 miles of ROW developed and maintained by SCL in northwestern Washington, approximately 20 linear miles of the utility's Skagit line transects the NRA. Figure 1-2, Project Transmission Line, overlays the 230 kV Skagit transmission line alignment on a project area base map. As depicted by this figure, the transmission corridor generally parallels both the North Cascades Highway and the Skagit River corridor. The Skagit transmission system consists of two lines. The line designated as the B line is situated to the north of and runs a parallel course to the southern D line. As shown in Figure 1-2, on a number of occasions, segments of the parallel lines split and temporarily run separate courses. The ROW width varies from 75 ft for wood-pole lines to 150 ft for each of the two steel lattice tower lines B and D.

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 1-1

.

.

.

The North Cascades Highway (SR20) was built by the state to provide recreation access to the North Cascades and Ross Lake. Additionally, it provides access to the three Seattle City Light hydroelectric power generation facilities located on the Skagit River. It presently provides one of the more popular scenic transportation routes across the Cascade Mountains.







•

•

3.0 AESTHETIC IMPACT EVALUATION

3.1 INTRODUCTION

SCL Departmental Policy and Procedure (DPP) goals for the maintenance of the utility's transmission rights-of-way were adopted in 1983 (DPP 500 P I-506). The policy goals included the development of an integrated vegetation management approach that would be reviewed annually and used as a guide by SCL to maintain the integrity of the utility's transmission network system and associated ROW. This policy further states objectives to maintain the ROW in cooperation with governmental agencies having jurisdiction over neighboring lands and to encourage multiple uses of the ROW for public benefit, as long as those uses do not compromise the maintenance or repair of the line.

More recent attention to multiple-use issues which affect portions of SCL's transmission and ROW network occurred with the passage of the Washington Park Wilderness Act of 1988 (Public Law 100-668) and with SCL's submittal of a relicensing application to the Federal Energy Regulatory Commission (FERC) for the Skagit Hydroelectric Power Generation Project (Project No. 553-005-Washington). As discussed in paragraphs that follow, vegetation management activities in the project study area must comply with restrictions set forth in the Washington Park Wilderness Act since the study area is located within the Ross Lake NRA.

The Washington Park Wilderness Act designated wilderness area within the North Cascades National Park Complex as well as within two other national parks in the state of Washington. A 20-mile segment of the SCL Skagit transmission line and ROW corridor traverses public lands within the NRA. These public lands are administered by the NPS. The manner in which the ROW vegetation is maintained along this segment of the corridor is of interest to the NPS, as they are responsible for the management of NRA lands in accordance with the objectives of the aforementioned wilderness act. With specific reference to the NRA, the Washington Park Wilderness Act allows the removal and disposal of trees within power line rights-of-way as is necessary to protect transmission lines, towers and equipment, provided that, to the extent possible, such activity is required to be conducted in a manner to protect scenic viewsheds. Appendix F provides a copy of the

. . . . **...**, . .

Washington Park Wilderness Act. The following is an excerpt from Section 205., Renewable Natural Resource Use in Recreation Areas, concerning the removal and disposal of trees within power line rights-of-way:

"Within the Ross Lake National Recreation Area the removal and disposal of trees within power line rights-of-way are authorized as necessary to protect transmssion lines, towers, and equipment;": <u>Provided</u>, That to the extent practicable, such removal and disposal of trees shall be conducted in such a manner as to protect scenic viewsheds.".

Following review of Seattle City Light's relicensing application, FERC requested additional information concerning aesthetic impacts of the Skagit Project. In a letter to SCL concerning a review of the relicensing application (October 31, 1988), FERC noted both the high scenic quality and recreational use of the NRA/Skagit Project lands and the public's heightened awareness of the altered natural landscapes, as well as their increasing concern for visual quality. As a result, FERC is requesting a more detailed analysis of the aesthetic impact issue.

In response to these developments, SCL has conducted an aesthetic impact evaluation of the 20-mile 230 kV Skagit transmission line and ROW located in the Ross Lake National Recreation Area. The evaluation presented here supplements a comprehensive aesthetic impact evaluation prepared for the Skagit Hydroelectric Power Project, conducted under separate contract.

The scope of this task is to:

- conduct an evaluation of the visibility of the transmission structure and ROW from the North Cascades Highway (SR20) within the NRA and identify areas that should be targeted for visual impact reduction (Aesthetic Target Areas);
- document the extent of visibility, character and magnitude of visual impact for the Aesthetic Target Area ROW segments; and
- evaluate and recommend viable vegetative management techniques (mitigation prescriptions) for minimizing the visual impacts of the transmission structures and corridor.

.

.

. . .

. .

.

.
The results of this evaluation will be reviewed by SCL. The utility will then decide which of the recommended mitigation prescriptions will be incorporated in the utility's Integrated Vegetation Management Program for the Skagit transmission line and ROW corridor that is located between the Sauk River crossing and the line's northern terminus at Ross Dam.

3.2 EVALUATION APPROACH

3.2.1 Data Collection and Review

Initial activities focused on a review of the available data concerning the project segment of the Skagit transmission corridor. Data sources include:

- Seattle City Light Departmental Policy and Procedure for transmission ROW maintenance (DPP 500- P I-506),
- supplemental information requests from FERC (FERC 1988),
- the Washington Park Wilderness Act of 1988 (Public Law 100-668),
- prior data inventories (Envirosphere 1985) conducted as part of SCL's Integrated Vegetation Management Program.
- maps, aerial photographs, aerial video documentation, and plan and profile engineering design and detail drawings for the project transmission ROW (refer to References).

3.2.2 Seattle City Light and Interagency Consultation

Operational and Safety Constraints

SCL staff responsible for vegetation maintenance along the project ROW were consulted to obtain a familiarity with the vegetation management techniques that are currently being implemented to guard visual resources of the neighboring lands. Additional information was obtained concerning SCL's operational and safety constraints that are integral to the successful and uninterrupted distribution of power via the Skagit line.

.

.

•

One of the key objectives is to manage the vegetation in the ROW corridor to prevent vegetation from contacting the power lines, thus preventing transmission failure, fire hazards and potential safety hazards to SCL maintenance personnel. Additionally, unimpaired access is important for quick response to repair transmission failure or control the spread of fires. Other aspects that affect worker safety and the transmission system's integrity include line sag and sway, tree size and age, and soil type, slope and stability. Costs associated with an inability to quickly respond to such adverse scenarios are substantial (Newby Consequently, it is necessary for SCL maintenance crews 1989). to routinely manage vegetation to control height and clear vegetation within and along the ROW margins. The proximity of vegetation to overhead power lines is dictated, in part, by the Washington General Safety and Health Standards (WAC 296-24-960) and Safety Standards for Electrical Construction Code (WAC 296-44-21230) presented in Appendix G and H, respectively.

Interagency Consultation

Early in the project's development an agency consultation meeting was held with the NPS, SCL and the consulting contractor project staff. The meeting provided an opportunity to review NPS issues of concern regarding the management of the public lands adjacent to the transmission ROW. The objectives and approach to determining the key aesthetic impacts of the transmission line corridor to viewers enroute along SR20 and the development of mitigation recommendations was presented. No issues, in addition to those targeted by the objectives of this contract subtask, were presented by the NPS.

Additional presentation of this contract workscope was made to members of the Forest Service (FS), the North Cascades Conservation Council (NCCC), and the consulting team contracted to prepare supplemental documentation to support FERC's relicense of the Skagit Hydroelectric Power Project.

3.2.3 Visual Impact Determination

In addition to a review of the database of materials made available from SCL, a site reconnaissance of the project area was conducted. The entire length of SR20 in the project study area was traveled to identify areas where the transmission line towers and ROW had a high level of visibility to travelers along the highway. A number of areas which had a history of concern were pointed out by SCL staff. Additional areas of concern were included as a result of the survey of the project study area.

•

•

3.3 AESTHETIC TARGET AREAS (ATA)

Reconnaissance of the project study area and consultation with key SCL personnel resulted in the identification of seven areas (Aesthetic Target Areas) that are recommended for visual impact reduction.

The selection of ATAs was based upon the visibility of the transmission line features and its likely adverse impact to viewers traveling SR20. Of primary concern is the visual compatibility of the transmission features in the areas observed. The varying level of contrast of the visual characteristics of the transmission line and corridor (i.e. form, line, color, texture) with those of the surrounding natural landscape elements will impact the viewer. The extent of impact can be determined from an evaluation of the following:

- <u>Viewer Exposure</u> the visibility of the transmission corridor to travelers enroute or located at key viewpoint locations along SR20. The significance of the viewer's exposure is affected by:
 - the viewing distance zones (i.e. views of the project features experienced from foreground, middleground and background distances [USDA 1974]),
 - the duration of the viewing activity (affected by whether views are experienced while moving or stationary),
 - the portion of the transmission line features and ROW exposed to viewers at key viewpoint locations (i.e. lines, towers, ROW cleared vegetation), and
 - the visual magnitude or the extent of the visibility of the transmission features and ROW corridor.
- <u>Viewer Sensitivity</u> based upon the numbers of viewers, the visual characteristics of the natural environment, and the viewer's probable expectations.

Figure 3-1 locates the seven areas on the project base map. Following an upstream progression from the western project boundary near Bacon Creek, the Aesthetic Target Areas named in the figure are:

- 1) Bacon Creek
- 2) Pinkie's
- 3) Thornton Creek
- 4) Goodell Creek

- 5) Gorge Dam Viewpoint
- 6) Diablo "Y"
- 7) Diablo Overlook

ł

.



The ATAs are somewhat evenly distributed along the highway between the Bacon Creek tributary and the eastern end of the project study area at Ross Dam. At each of the areas a location was selected for stationary viewing. Stationary viewing activities increase the significance of the visual impact experience due to the extended period of time over which the viewer is exposed. Consequently, the associated evaluation of impact represents a worst-case scenario. As much as possible, the viewing site was selected based upon a location which was reasonably safe and likely to attract a recreationist to pull off the highway to rest or to participate in some level of recreational activity (i.e. hiking, fishing, temporary rest/picnicking, scenic Boundaries of the ATAs correspond to the farthest viewing). steel lattice transmission towers that are visible in either direction along the transmission ROW corridor from the stationary viewpoint. Views of the transmission corridor, when traveling east and westbound along SR20 through each of the ATAs, were recorded.

The degree to which viewers are impacted by the visibility of the transmission towers, lines and cleared ROW is highly variable among the seven ATAs. Together these areas represent an overview that could be presented to a viewer traveling along or through a significant part of the ROW. Table 3-1, Aesthetic Target Area Visual Impact Determination, presents the aesthetic impact parameters (i.e. viewer exposure, viewer sensitivity) which were evaluated to determine the significance of the visual impacts of the transmission corridor from each of the ATA sites. Table 3-1 is preceded by a definition of terms and the impact rating scores assigned to the visual parameters evaluated in the table. Aesthetic impact evaluation tasks undertaken under this contract support the FERC supplemental information request which discusses, in some detail, numbers of recreationists/viewers that experience the visual resources of the project study area.

Based on the relative impact significance rating scores in Table 3-1, the ATAs were prioritized from highest to lowest as follows: Goodell Creek; Bacon Creek; Diablo Overlook; Thornton Creek; Gorge Dam Viewpoint; and Diablo "Y" and Pinkie's (both ranked sixth).

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 3-7

·

•

.

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

DEFINITION OF TERMS AND IMPACT RATINGS

PARAMETER OF CONCERN	IMPACT RATINGS	DEFINITION
VISIBILITY OF T-LINE FEAT	URES	These are the structural components of the trans- mission corridor.
Transmission Tower	1 - 3	At any one site, tower visibility is rated as 1 . (minimum), 2 (moderate) or 3 (maximum).
Transmission Lines	1 - 3	At any one site, visibility of lines between towers are rated 1 (minimum), 2 (moderate) or 3 (maximum).
T-Line ROW Clearing	1 - 3	At any one site, maintenance clearing zones, depending upon their visual impact, are rated 1 (minimum), 2 (moderate) or 3 (maximum).
OBSERVER POSITION/VIEWING	ANGLE	Note: Not all viewing angles are achieved at each site; applicable angles are ranked when they are appropriate viewing angles for the site.
Infer ior	1	An inferior view (below the target viewed) is considered of least impact, and is assigned a ranking of 1.
Normal	2	An average normal line of sight with respect to the target viewed is considered of moderate im- pact, and is assigned a ranking of 2.
Super ior	3	A superior view (above the target viewed) is considered of maximum impact, and is assigned a ranking of 3.
Perpendicular	1	A view which is perpendicular to the viewed object or target is considered of minimum viewer impact and is assigned a ranking of 1.

.

. •

DEFINITION OF TERMS AND IMPACT RATINGS (continued)

PARAMETER OF CONCERN	IMPACT RATINGS	DEFINITION
Lineer	2	A view along the length of the viewed object or target is considered of moderate impact and is assigned a ranking of 2.
VIEWING DISTANCE ZONE		Most viewpoint locations will have only one zone, that is the target viewed will be in the fore- ground, background, or middleground of the view- er's scope of vision.
Background	1	A viewed object at background distances (5 miles plus) is considered of minimal impact and is rated as 1.
Middleground	2	A viewed object at middle ground distances (3-5 miles) is considered of moderate impact and is rated 2.
Foreground	3	A viewed object in the foreground (X - X mile) is considered to have maximum impact and is rated 3.
VIEWING OPPORTUNITY TYPE		The frequency of use and the accessibility of an area will determine the ranking for these catego- ries. The opportunity type, viewer category and view duration are interdependent and require some subjective interpretation of the viewing potential and duration.
Primary Iravel Route	3	A maximum ranking is given to primary travel routes since the frequency of viewer contact is highest at these areas.
Informal Turnout	2	A moderate ranking is given to pull-off sites, as movement through these areas is usually associated with specific purposes (to let faster traffic pass, etc.) and views may be secondary.
Formal Turnout	3	Campgrounds, scenic view turnouts, and in some cases trailheads are areas in which viewers have a specific interest in their visual surroundings. These areas are, therefore, rated with a maximum score of 3.

·

• · · ·

DEFINITION OF TERMS AND IMPACT RATINGS (continued)

PARAMETER OF CONCERN	IMPACT RATINGS	DEFINITION
Non-ROW Changes	1	Structural modifications such as the proposed NPS visitor center have their own impact on surround- ing viewsheds and thus interrelate indirectly with the T-Line needs. These areas are given a rating of minimum impact (1).
VIEWER CATEGORY		People passing through the areas evaluated have specific activities or goals for their movement. Depending upon their likely intent and presence, viewer categories are given a ranking of 1 to 3 as described below.
Pleasure driver	1	A pleasure driver is likely to pass through an area rather quickly and make observations while moving, without stopping to concentrate on any particular view. Therefore, this viewer opportu- nity for activity is rated as minimum for visual impact purposes.
Recreationist	2 - 3	Visitors who come specifically to use the area under review will be moderately to maximally impacted by T-Line views, depending upon their activity and use areas. Multiple use areas (i.e. hiking, boating and picnicking) will be scored for each activity.
Scenic Viewing	3	Areas where scenic viewing is likely to be a high interest are given a maximum rank of 3.
VIEW DURATION	¥	Not all durations will apply to a given site; those which do apply are given an appropriate score as described below.
Traveling	1	A viewer moving through the area and not typically stopping is rated with a minimum score of 1.
Still Viewing	2	A viewer provided with an opportunity to stop briefly will be more cognizant of the surrounding areas and thus is moderately impacted and rated as 2.

· ·

.

DEFINITION OF TERMS AND IMPACT RATINGS (continued)

PA OF	RAMETER CONCERN	IMPACT RATINGS	DEFINITION
	Extended Viewing	3	Extended views are likely in scenic view areas, resort and camping areas, and similar use situa- tions. This type of viewing is assigned a maximum rating of 3.

Compiling Scores: Once the parameters of an area under evaluation are determined, and scores are assigned, a subtotal for each category is derived by adding the scores. A total for the area is added to achieve a score for the viewpoint location. Scores can then be used to rank the location itself, with the highest scores having the highest priority.

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 3-11

, , • . .

TABLE 3-1 SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 1: BACON CREEK					Page 1 of 8
	VIEWER EXPO	SURE		IMPACT SI	GNIFICANCE
VIEWSHED DESCRIPTION					
		1 ~ 3 (mi)	n - max)	SUBTOTAL	TOTAL
<u> </u>	Visibility of T-Line Feature	es'			
VIEWPOINT LOCATION	* transmission towers	3			
	* T-Lines	3			
SR20;(M.P. 111)	* ROW clearing	3			
Skagit River: R.M. 83.00			SUBTOTAL	9	
	Observer Position / Viewing	Angle			
	<pre>inferior (1)</pre>	1	Westwar	d	
	* normal (2)	2	at Site	Look ing	
	* superior (3)		eastwar	d	
	* perpendicular (1)				
	* linear (2)	2			
			SUBTOTAL	5	
VIEWSHED CHARACTERISTICS	Viewing Distance Zone				
	* background (1)				
	* middleground (2)				
Transmission lines B & D cross	<pre>* foreground (3)</pre>	3			
SR2D west of Bacon Creek target	•		SUBTOTAL	3	· 17
area and again east of Bacon					
Creek Campground access road.					
	VIEWER SENSITIVI	LTY			
classed vogeteties within POV			<u> </u>		
dominate views of and through	VIEWING POTENTIAL / DORATION	IMPACT RA	TING		
the target area					
	* Primary travel emits	7			
		· J			
		2			
-	Bacon Creek Camporound	7			
	(Vest of project bound	ev)			
		.,,	SURTITAL	R	
	Viewer Category		JODICIAL	v	
	* Pleasure driver	1			
	* Recreationist	•			
	- picknicking/	3			
	temporary rest				
	- fishing	3			
	- informal hiking	2			
	(no establ. trails)	_			
			SUBTOTAL	9	
	 View Duration 			-	
	<pre>* traveling (1)</pre>	1			
	* still viewing (2)	2			
	* extended viewing (3)				
	_		SUBTOTAL	9	26
			TOTAL		
			TUTAL		45

. . . . , . -. .

.

· · · · · ·

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT

AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 2: PINKIES

Page 2 of 8

	VIEWER EXPOS	SURE	IMPACT SIG	NIFICANCE
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT RATING 1 - 3 (min - max)	SUBTOTAL	TOTAL
	Visibility of T-line Feature	3		
VIEWPOINT LOCATION	•	D-Line D		
	<pre>- LFANSBISSION LOWERS - Tallana</pre>	2	-	
SK20;(M.P. 114.4)	" l-times	2		•
Skagit kiver; K.M. 0/.75	··· KUW GLOAFING	I		
		SUBTOTAL	5	
	Observer Position / Viewing	Angle		
	f inferior (1)	1		
	# normal (2)	I		
VIEUSHED CHAPACTERISTICS	infinite (2)			
TENSILD CHARACTERISTICS	* perpendicular (1)	1		
	* Linear (2)	ł	2	
The transmission ROW paraliels SR20			-	
to the north. Line D is adjacent to	Viewing Distance Zone			
the highway and line 8 is situated				
up slope and above the highway along	* background (1)	1		
a steep embankment.	* middleground (2)			
	* foreground (3)			
Sporadic views of Line D, its towers	-	SUBTOTAL	1	8
and ROW cleared of vegetation are				
partially screened by the rugged	VIEWER SENSITIVI			
terrain and vegetation. Line 8 would	· · · · · · · · · · · · · · · · · · ·			
be visible from a stationary position	VIEWING POTENTIAL / DURATION	IMPACT RATING		
ing on \$R20.	Opportunity Type			<u> </u>
•	* Primary travel route	3		
	* Informal turnout	2		
		SUBTOTAL	5	
	Viewer Category			
	* Pleasure driver	1		
	* Recreationist			
	 picknicking/ 	3		
	temporary rest			
	- fishing	3	-	<u>.</u> .
	- informal hiking	2		_
	(no establ. trails)		_	
		SUBTOTAL	9	
	View Duration			
	- traveling (1)	1 3		
	- STILL VIEWING (2)	۷		
	extended Alewing (3)	SURTOTAL	र	17
		JUDIUIAL	3	17
		TOTAL		25

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 3-13

.

· · ·

·

. .

.

.

-

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 3: THORNTON CREEK				F	age 3 of	
	VIEWER EXPO	SURE		IMPACT SIGNIFICANCE		
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT R 1 - 3 (mi	ATING n - max)	SUBTOTAL	TOTAL	
VIEWPOINT LOCATION	Visibility of T-line Festure	83				
SR20;(M.P. 117)	transmission towers	3				
Skagit River: R.M. 90	* T-Lines	3				
	* ROW clearing	3				
	Observer Position / Viewing	Angle	SUBTOTAL	9		
		viðro.				
VIEWSHED CHARACTERISTICS	* inferior (1)					
	* normal (2)	2				
	* superior (3)					
Line D closely parallels SR20 to the	* perpendicular (1)					
north and Line B is situated above	* linear (2)	2				
the highway along a steep bank north			SUBTOTAL	4		
of Line D.	Viewing Distance Zone					
Line D. its towers and cleared ROW	* background (1)					
dominate views to the north side of the	* Biddlearound (2)					
highway. Line 8 can be from a stationary	* foreground (3)	3				
and only slightly visible while travel-			SUBTOTAL	3	16	
ing along the highway.						
-	VIEWER SENSITIVI					
	VIEWING POTENTIAL / DURATION	IMPACT RA	TING	-		
	Opportunity Type					
	* Primary travel route	3				
	* Informal turnout/trail-	2				
	head					
			SUBTOTAL	5		
	Viewer Catégory .					
	* Pleasure driver	1				
	" Kecreationist	7				
-	temporary rest	2				
	- fishing	3				
	· · · · · · · · · · · · · · · · · · ·	-	SUBTOTAL	7		
	View Duration			•		
	<pre>* traveling (1)</pre>	1				
	<pre>still viewing (2)</pre>	2				
	<pre>* extended viewing (3)</pre>	3				
			SUBTOTAL	6	18	
		-	TOTAL		34	

8

-

···

.

· .

·

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 4: GOODELL CREEK

÷

Page 4 of 8

	VIEWER EXPOSU	VIEWER EXPOSURE		
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT RATING 1 - 3 (min - max)	SUBTOTAL	TOTAL
	Visibility of Toline Features		· · · ·	
VIEWPOINT LOCATION	.	-		
	* transmission towers	3		
SR20;(M.P. 120.2	= T-Lines	5		
Skagit River: R.M. 92.25	* ROW clearing	3	-	
	Observer Position / Viewing A	ngle	4	
	* infanian (1)			
VIEWSHED CHARACTERISTICS		2		
	normal (2)	2 eastward		
The energiesies lines are clicated	* superior (5)			
the transmission times are aligned	 perpendicular (1) timese (2) 	`		
atong both sides of Sk20, Line b to the	r linear (∠)	<u>ς</u> ευρτόται	,	
north and Line D to the south of the highwa	y. Vievies Distance Zone	SUBTOTAL	. 4	
The Annual State States and	viewing Distance Zone			
the transmission times, towers and	• back-set (1)	•		
cleared kow downnate views from the	- Dackground (1)			
Gendell Greek Tetert and	* induceground (2)	7		
Goodert Creek Target area.	~ toreground (3)	S SUBTOTAL	. 3	1
Only tops of two or three towers of the				
T-Line are slightly visible at a distance	VIEWER SENSITIVIT	Y		
from the proposed visitor's center site			_	
west of the Goodell campground.	VIEWING POTENTIAL / DURATION	IMPACT RATING		
A microwave distribution line, along	Opportunity Type		·	
Trapper's peak ridge north of the highway	* Primary travel route	3		
would not be visible from the highway or	* Informal turnout	2		
visitor's center.	* Formal campground site new particular site	earby		
	Goodell Campground	3		
	* Proposed NPS Visitor's ce	enter		
	loc, on south side of riv	ver. 1		
		SUBTOTAL	8	•
	Viewer Category			
	* Pleasure driver	1		
	* Recreationist			
	* picknicking/	3		
	temporary rest			
	- fishing	3		
	 informal hiking 	2		
	(no establ. trails)			
	* Formal scenic viewing			
	activity	3		
		SUBTOTAL	12	

-

-• . . · · · . . • .

TABLE 3-1 SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

VIEWSHED DESCRIPTION	VIEWER	VIEWER EXPOSURE			IMPACT SIGNIFICANC	
	VISIBILITY -	IMPAC 1 - 3	F RATING (min - max)	SUBTOTAL	TOTAL	
	View Duration					
	* traveling		2			
	extended viewing	while				
	traveling due to	parallel				
	alignment of T-li	nes and SR20.				
	<pre>* still viewing (2</pre>)	2			
	* extended viewing-	stili (3)	,			
	from NPS Visitor	's Center	3			
			SUBTOTAL	7		

.

.

·

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 5: GORGE DAM VIEWPOINT			F	Page ó of 8
	VIEWER EXPOS	SURE	IMPACT SIGN	IFICANCE
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT RATING 1 - 3 (min - max)	SUBTOTAL	TOTAL
VIEWPOINT LOCATION	Visibility of T-Line Feature			
	<pre>* transmission towers</pre>	3		
5000 M P 133	T Lines	3		
Skagit River: R.M. 96.5	KOW Creating	SURTOTAI	q	
·····	Observer Position / Viewing	Angle		
	* inferior (1)	1		
	* normal (2)	·		
VIEWSHED CHARACTERISTICS	* superior (3)			
	* perpendicular (1)			
	* linear (2)	2		
The site is situated south of SR2D and		SUBTOTAL	3	
overlooks Gorge Dam and its reservoir	Viewing Distance Zone			
to the southeast. The surrounding area	+ 1 1 1 / / / ·	· _		
hy dense eventsteen forest vegetation	 background (1) biddleaneund (2) 	2		
by dense evergreen forest vegetation.	- middleground (2)	2		
The transmission lines are located between	i or ogi ourier (3)	SURTOTAL	2	14
the viewpoint site and SR20 on the top of		00010112	-	.4
a ridge which separates the two. The T-Line crosses over the Skemit	VIEWER SENSITIVI	TY	<u> </u>	
River west of the dam and is clearly visible from the viewpoint, as are	VIEWING POTENTIAL / DURATION	IMPACT RATING		
the T-line towers along the north side	Opportunity Type			
of Gorge Lake.	* Primary travel route	3		
	* Formal turnout	3		
	Proposed formal scenic	3		
	A Lembo TUE	SURTOTAL	a	
	Viewer Category	GODICINE	,	
	* Pleasure driver	. 1		
	* Recreationist			
	- picknicking/	3		
-	temporary rest			
		SUBTOTAL	4	
	View Duration			
	<pre>* traveling (1) * still viewing (2)</pre>	2		
	* actending viewing (2)	٤		
	- future	3		
		SUBTOTAL	5	18
		TOTAL	· ·	32

TABLE 3-1

SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 6: DIABLO "Y"

Page 7 of 8

	VIEWER EXPOSI	URE	IMPACT SIGNI	FICANCE
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT RATING 1 - 3 (min - max)	SUBTOTAL	TOTAL
VIEWPOINT LOCATION	Visibility of T-line Feature:	s 8-Line D-Line	B / D	B / D
SR20;(M.P) Skagit River: R.H. 99.0	★ transmission towers ★ T-Lines ★ ROW clearing	3 2 3 2 3 1 Subtotal	9 / 5	
	. Observer Position / Viewing A	Ingle		
VIEWSHED CHARACTERISTICS	* inferior (1) * normal (2) * superior (3)	1 2	D-Line B-Line at lake	elevation
Line B crosses diagonally over the east end of Diablo Lake and continues up a ridge east of the lake. Line D crosses	" perpendicular (1) " linear (2)	SUBTOTAL	2 / 1	
over Diablo Lake further west of Line B and parallets the take along a steep rocky embankment. It later rejoins Line B at the east end of the take.	Viewing Distance Zone * background (1) * middleground (2)	B-Line D-Lin	•	
•	* foreground (3)	3 SUBTOTAL	• 3 / 2 1	4 / 8
The views of transmission lines of Line B are clearly visible from SR20. Views of	VIEWER SENSITIVIT	γ	<u> </u>	
Line D's lines and towers are minimized by the light colored backdrop of the	VIEWING POTENTIAL/DURATION	IMPACT RATING		
rocky embankment. Where the two lines converge at the east end of Lake Diablo, distant views of the transmission lines,	Opportunity Type * Primary travel route * Informal turnout	3 2		
by the west-facing ridge.	Viewer Category * Pleasure driver * Recreationist	SUBTOTAL 1	5	
	- fishing View Duration	3 Subtotal	4	
	<pre>* traveling (1) * still viewing (2) * extended viewing (3)</pre>	2		
		SUBTOTAL	2	11
		TOTAL	(B / D) 25	5 / 19

.

TABLE 3-1 SEATTLE CITY LIGHT T-LINE VEGETATION MANAGEMENT AESTHETIC TARGET AREA VISUAL IMPACT DETERMINATION

AREA 7: DIABLO OVERLOOK

Page 8 of 8

	VIEWER EXPOS	SURE	IMPACT SIG	NIFICANCE
VIEWSHED DESCRIPTION	VISIBILITY	IMPACT RATING 1 - 3 (min - mex)	SUBTOTAL	TOTAL
	Visibility of Trline Feature	3		
VIEWPOINT LOCATION				
· ·	* transmission towers	3		
SR20;(M.P)	* T-Lines	3		
Skagit River: R.M. 102.75	* ROW clearing	2 SUBTOTAL	8	
	Observer Position / Viewing	Angle		
	# inferior (1)			
VIEWSHED CHARACTERISTICS	* normal (2)			
	* superior (3)	3		
	* perpendicular (1)	-		
A single transmission line crosses	* linear (2)			
over the northern most tip of		SUBTOTAL	3	
Lake Diablo traversing over steep heavily forested terrain.	Viewing Distance Zone			
	* background (1)			
Distant views of the T-Line towers	* middleground (2)	2		
are clearly visible where it crosses	<pre>* foreground (3)</pre>			
over Diablo Lake from the viewpoint		SUBTOTAL	2	13
situated above the lake and at the				
south side. A portion of cleared land	VIEWER SENSITIVI	ΤY		
is visible west of the Lake where the			_	
The heavy vegetation screens the	VIEWING POTENTIAL / DURATION	IMPACT RATING		
remainder of the cleared areas,	Opportunity Type	•		
exposing only the tips of the towers	* Primary travel route	3		
and transmission lines which tend to	* Formal scenic viewpoint			
be highlighted by the dark background	Diable Overlook	3		
provided by the evergreens.		SUBTOTAL	6	
	Viewer Category			
		1		
	· Dicknicing/teen res	7		
	- boating/resort	3		
	- fishing	3		
	 hiking (Diablo Lake 	-		
	Trail)	3		
		SUBTOTAL	13	
	View Duration			
	<pre>* traveling (1)</pre>	1		
	<pre>* still viewing (2)</pre>	2		
	 extended viewing/ (3) 	-		
	DOBTING	SUBTOTAL	6	19
		1941296		30

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 3-19

·

•

3.4 DEVELOPMENT OF VISUAL IMPACT MITIGATION RECOMMENDATIONS

The objective of this task is to formulate from the visual impact analysis results management recommendations that can be integrated with other key issues of SCL's Vegetation Management Program. The ATAs represent model points along the ROW for the demonstration of the mitigation of visual impacts along some of the most heavily visited parts of the ROW. Using the techniques outlined here, SCL personnel can implement mitigation activities along the rest of the ROW as needed. The purpose of this document is to provide not only a thorough aesthetic evaluation, but also to provide a tool which can be utilized repeated-Accordingly, a range of Vegetation Mitigation Management ly. Prescriptions have been developed that can be used to reduce the visual impact characteristics of each of the ATAs. These prescriptions can be used in other areas.

Computer Aided Design (CAD) drawings (Figures 3-2 through 3-7) illustrate a variety of mitigation management prescriptions and their anticipated results. These figures graphically show how visual impacts can be minimized as a result of each of the vegetation management prescriptions. Table 3-2 provides an interpretive key to the figure's plant symbols. The table shows a plant symbol, a correlating plant size and the vegetative species that typically have growth characteristics which correspond to the desired plant height shown.

The graphic figures illustrate a range of viable vegetation management techniques which can be standardized as vegetation mitigation prescriptions for visual impact reduction. The mitigation prescriptions are intended to be developed to an appropriate level of detail which will allow their application along the project ROW or along any of the other SCL rights-of-way as similar impact scenarios occur. The mitigation prescriptions can be applied individually or combined as necessary to address the varying impact circumstances as they arise.

For ease of review, Table 3-2 and Figures 3-2 through 3-7 are presented at the end of the following discussion of the goals and objectives of the mitigation prescriptions.

3.5 VEGETATION MITIGATION PRESCRIPTIONS

3.5.1 Prescription Goals and Objectives

The mitigation prescriptions illustrated in Figures 3-2 through 3-7 demonstrate ways in which supplemental planting techniques

· ·
and/or natural infill techniques within the transmission line ROW can effectively screen views of transmission lines, towers and cleared corridors from SR20 and designated viewpoints. Plantings outside the ROW are also utilized where views of transmission line corridors cannot be effectively and/or economically screened by managing vegetation within the ROW. Establishing vegetative screening close to the viewers allows a larger section of the transmission line corridor to be screened using the minimum amount of vegetation. In such cases, the further the transmission line is from the viewer, the greater the portion of the corridor is screened from the viewer. Screening also lessens the impact of non-vegetative features by drawing the viewer's eye to closer objects, more visually attractive features or increasing the variety of features visible to the viewer.

Size and location of vegetation that is either planted or encouraged to grow within the transmission corridor is governed by the line sag and sway clearance requirements, from transmission lines (primary) and towers (secondary) of vegetation at mature size. The SCL standard for minimum clearance of the lines is 16 ft 6 inches for 230 kV lines and 18 ft for 240 kV lines.

The feathering treatment of vegetation along the ROW margins will minimize the generally abrupt visual contrast in the color, line and texture of the ROW, which typically contains a minimal amount of vegetation, with that of the adjacent and more dense forest vegetation. Use of variable trees and shrub heights will give the appearance of a natural infill of vegetation within the ROW. Application of this mitigation technique, at key locations in the project study area, will minimize the visual impact of the transmission structures and corridor on the natural and scenic visual character of the NRA. This objective can also be accomplished by utilizing a mix of vegetation with variable fast and slow growth characteristics.

Mitigation plans, which include integrated procedures to allow natural regrowth of vegetation as well as planned vegetation control to encourage browsing where appropriate, are utilized to achieve benefits for wildlife inhabiting or crossing the ROW area. The use of vegetation under the transmission lines which encourages wildlife foraging by providing suitable food and protective cover is suggested where maintaining the maximum amount of line clearance is most critical. Foraging activities will help keep much of the vegetation growth in these areas to a minimum. As a result, the frequency of vegetative maintenance required to control tree heights that could interfere with the lines would be reduced. The need for such maintenance activities could potentially be reduced from annual maintenance to a 3-year maintenance program.

SCL, TRANSMISSION LINE VEGETATION MGT. PLAN, FINAL REPORT, PAGE 3-21

• · ·

.

• .

•

.

Effective pruning procedures to keep vegetation heights from endangering transmission lines will need to continue within the transmission ROW, utilizing the criteria established by the mitigation prescriptions as a general guide for pruning techniques. Pruning procedures include selective branch trimming, branch removal, topping or cutting back of brush or tree species without causing plant death or full plant removal. Pruning tolerances of the mitigation prescriptions allow for an optional three-year growth period beyond the fall line clearance height for trees which could potentially damage transmission lines and towers. This allowance will minimize the frequency of maintenance reguired to control tree height.

The incorporation of the various vegetation management prescription techniques into SCL's Integrated Vegetation Management Program will potentially reduce the need for herbicide uses. Where vegetation establishment needs to be kept to a minimum, such as maintenance access routes and around the tower bases, herbicide uses can be evaluated.

.

.

•

TABLE 3-2 PLANTING KEY

SYMBOL	TYPE/SIZE	EXAMPLE
	EVERGREEN TREES TALL (OVER 80') MEDIUM (40-80')	DOUGLAS FIR WESTERN HEMLOCK WESTERN RED CEDAR LODGEPOLE PINE
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	DECIDUOUS TREES TALL (OVER 80') MEDIUM (40'-80')	BIG LEAF MAPLE WHITE POPLAR PAPER BIRCH BLACK COTTONWOOD RED MAPLE RED ALDER
	LOW (25'-40')	VINE MAPLE ROCKY MOUNTAIN MAPLE EUROPEAN ASH WILLOWS
	WILDLIFE FORAGING SHRUBS TALL (8'-15')	THIMBLEBERRY HARDHACK OCEANSPRAY GOOSEBERRY WESTERN SERVICE BERRY SALMON BERRY RED OSIER DOGWOOD RED ELDERBERRY
	MEDIUM (3'-8')	RED HUCKLEBERRY SPIREA
	WLDLIFE FORAGING SHRUBS LOW (1'-3')	KINNIKINNIK LONG-LEAVED OREGON GRAPE MOUNTAIN BOX

. .

· · ·



.

ĩ



NG VEGETATION
ISMISSION TOWER
ALL LINE
UB
TENANCE ROAD
ATION ALONG THE OUTER MOST NDERING EDGE TREATMENT
Y BECOMING LESS OBVIOUS TO

FIGURE 33	
TYPE-B CORRIDOR EDGE PLANTING	3-25





n K



.

.

. ł



.

í E

ı.

3.5.2 Aesthetic Target Area Prescription Plans

Figures 3-8 through 3-14 are vegetation management prescription plans specific to the project ATA sites. The target area plans illustrate locations of local landmarks, roads, trails, rivers and the SCL transmission lines. The plans also document which towers are visible as one travels along SR 20, or, in the case of Diablo Overlook and Gorge Dam Viewpoint, from a stationary location.

The illustration text describes how the viewer sees the corridor itself while traveling east-bound or west-bound on SR 20. Sections of the transmission corridor are broken into areas of common view characteristics with regard to slope aspect, length of exposed corridor from SR 20, at various angles, be it perpendicular to or linear/in-line with the viewer. Each view section is given a mitigation prescription applicable to the type of views possible from SR 20. -.

.

•

.

. .

. ·

.



WESTBOUND VIEW CHARACTERISTICS • D-UNE VISIBLE • LONG LINEAR VIEW OF D-LINE CORRIDOR, SHORT DURATION DUE TO SCREENING BY EXISTING VEGETATION. • NOT VISIBLE OF NOT SIGNIFICANT FOR SHORT DURATION • B-LINE NOT VISIBLE • TYPE: A AND D • TYPE: A AND D N/A PRESCRIPTIONS EXISTING LEGEND existnic Trees TOWERS NOT IN VIEWSHED TOWERS WITHIN VIEWSHED О æ VISUALLY DOMINANT TOWERS TRANSMISSION LINES CONTRACT ON PROJECTED MAINTENANCE AREAS (1989-1990) SKAGT RIVER existing Trees 20 ሩዮ 1200 600 EASTBOUND VIEW CHARACTERISTICS • D-CORRIDOR VISIBLE, MEDIUM • D-CORRIDOR NOT VISIBLE • SMALL AREA AROUND TOWER B • NOT VISIBLE OR NOT SIGNIFICANT SCALE IN FEET DURATION • TYPE: A AND D N/A PRESCRIPTIONS SEATTLE CITY LIGHT TRANSMISSION RIGHT-OF-WAY VEGETATION MANAGEMENT PLAN



ž





-





. .

.

•

i de



I

BCAT-OUSE DIABLO LIAKE RESORT DIABLO DAM SR 20 EXISTING TREES DIABLO LAKE EXISTING TREE LEGEND TOWERS NOT IN VIEWSHED O Ô TOWERS WITHIN MEWSHED VISUALLY DOMINANT TOWERS ⊛ TRANSMISSION LINES PROJECTED MAINTENANCE AREAS (1989-1990) 1000 2000 SCALE IN FEET SR 20 SR 20 SINGLE POINT VIEW CHARACTERISTICS O LINES VISIBLE, CORRIDOR NOT VISIBLE O LINES VISIBLE, CORRIDOR NOT VISIBLE O LINES AND DAM VISIBLE O VISIBLE CORRIDOR O TYPE: F SEATTLE CITY LIGHT TRANSMISSION RIGHT-OF-WAY VEGETATION MANAGEMENT PLAN

GORGE LAKE POWERHOUSE

в<u>87</u> N



1. 1

3.6 PROGRAM IMPLEMENTATION BY SEATTLE CITY LIGHT

The viability of implementing any or all of the recommended prescriptions will depend on additional consideration of issues concerning SCL's specific concerns, as discussed under Operational Safety Constraints, and the ability to establish native vegetative communities in the ROW. Consideration of the latter requires a more detailed and site-specific analysis of slope stability, soil type and other factors that influence the establishment of native vegetation species. Information concerning species of native vegetation associated with the project ROW was compiled in 1987. The plant species list, presented for ease of reference in Appendix I, lists plants inventoried along the Skagit ROW in the project study area and along all of the SCL transmission network north of Seattle.

Of equal importance is the consideration of the SCL projected workload and maintenance forecasts which dictate the annual vegetation maintenance activity for the project study area ROW corridors. Figure 3-15 overlays the planned vegetation maintenance programs for the 1989 and 1990 season. Much of the work targeted for the 1989 season was complete by mid-summer (Stanchfield 1989).

Knowledge of planned future activity will enable SCL to evaluate the visual resource considerations of the area targeted for vegetation maintenance activity and assign a vegetation mitigation prescription to that area. The prescription would then serve as a goal for the transmission system's maintenance crew to meet. Decisions can then be reached in advance of any activity concerning the appropriateness of the mitigation prescription as well as a determination of any cost-benefit issues of concern.

. . .

•

.

·




.

ŕ

.

·

REFERENCES

- Computer Augmented Plant Selector (Software Program). 1987. Terisan, third edition.
- Envirosphere Company. 1985. Report to Seattle City Light, Distribution Division. Inventory of transmission right-ofway vegetation. Bellevue, Washington.
- Federal Energy Regulatory Commission (FERC). October 31, 1988. Director, Division of Project Review. Letter to Randall W. Hardy, Seattle City Light. Seattle, Washington.
- Green Trails Maps. 1985. 15-minute map series no. 47 and no. 48.
- Seattle City Light. 1983. Department policy and procedure: maintenance of the transmission rights-of-way. DPP 500 P I-506.
- _____. Date unknown. Aerial photos of Ross Lake National Recreation Area transmission line.

_____. Helicopter video of transmission line within the Ross Lake National Recreation Area.

August, 1977. Skagit River Project No. 553. Exhibit K - Transmission R/W Bothell Sub to Newhalem, Sheets 102 to 106 and Sheets T-42A to T-45B.

- . 1951. Skagit transmission Line No. 1 Plan and Profile, Sheets 52-72 and 52 - 73, Sheets 5201 and 5204 -5209.
- U.S. Department of Agriculture (USDA), Forest Service. 1977. National forest landscapes management, vol. 2, chapter 4, roads.

_____. 1975. National forest landscape management, vol. 2, chapter 2: utilities.

_____. April, 1974. National forest landscape management, volume 2: the visual management system.

.

- U.S. Department of the Interior (USDI). 1970. Environmental criteria for electric transmission systems. Washington, D.C.
- U.S. Geological Survey (USGS). 1965. 7.5-minute map series: Ross Dam Quadrangle.

_____. 1963. 7.5-minute map series: Diablo Dam Quadrangle.

__. 1953. 15-minute map series: Marblemount Quadrangle.

.

.

.

`

· .



•

• · ·

. . .

. • APPENDIX F

WASHINGTON PARK WILDERNESS

ACT OF 1988

(PUBLIC LAW 100-668)

·

· ·

TITLE II—NORTH CASCADES NATIONAL PARK SERVICE COMPLEX WILDERNESS

3EC. 201. DESIGNATION.

(a) WILDERNESS.—In furtherance of the purposes of the Wilderness Act (16 U.S.C. 1131 et seq.; 78 Stat. 890), certain lands in the North Cascades National Park, Ross Lake National Recreation Area, and Lake Chelan National Recreation Area, Washington, which—

(1) comprise approximately six hundred and thirty-four thousand six hundred and fourteen acres of wilderness, and approximately five thousand two hundred and twenty-six acres of potential wilderness additions, and

(2) are depicted on a map entitled "Wilderness Boundary, North Cascades National Park Service Complex, Washington", numbered 168-60-186 and dated August 1988,

are hereby designated as wilderness and therefore as components of the National Wilderness Preservation System. Such lands shall be known as the Stephen Mather Wilderness.

SEC. 202. HYDROELECTRIC PROJECTS.

Section 505 of the Act of October 2, 1963 (82 Stat. 930; 16 U.S.C. 90d-4) is amended as follows: strike "in the recreation areas", and insert in lieu thereof "in the lands and waters within the Skagit River Hydroelectric Project, Federal Energy and Regulatory Commission Project 553, including the proposed Copper Creek, High Ross, and Thunder Creek elements of the Project; and the Newhalem Project, Federal Energy and Regulatory Commission Project 2705, within the Ross Lake National Recreation Area; the lands and waters within the Ross Lake Chelan Project, Federal Energy and Regulatory Commission Project 637; the Company Creek small hydroelectric project at Stehekin within the Lake Chelan National Recreation Area; and existing hydrologic monitoring stations necessary for the proper operation of the hydroelectric projects listed herein".

SEC. 203. LAND ACQUISITION FOR ADMINISTRATIVE FACILITIES.

Section 301(a) of the Act of October 2, 1968 (82 Stat. 927; 16 U.S.C. 90b) is hereby amended to add a new subsection as follows:

"(b) The Secretary is hereby authorized to acquire, with the consent of the owner, lands outside of the authorized boundaries of North Cascades National Park Service Complex for the purpose of

102 STAT. 3963

construction and operation of a backcountry information center not to exceed five acres. The Secretary of the Interior is further authorized to acquire with the consent of the owner, lands for the construction of a headquarters and administrative site or sites, for the North Cascades National Park, Ross Lake National Recreation

Area, and Lake Chelan National Recreation Area not to exceed ten acres. The lands so acquired shall be managed as part of the park.".

SEC. 204. AUTHORIZATION OF APPROPRIATIONS.

There are hereby authorized to be appropriated to the Secretary of the Interior such sums as may be necessary to complete the land acquisitions authorized pursuant to section 203 of this Act.

SEC. 205. RENEWABLE NATURAL RESOURCE USE IN RECREATION AREAS.

Section 402(a) of the Act of October 2, 1958 (82 Stat. 928; 16 U.S.C. 90c-1) is hereby amended to read as follows:

"The Secretary shall administer the recreation areas in a manner which in his judgment will best provide for (1) public outdoor recreation benefits and (2) conservation of scenic, scientific, historic, and other values contributing to public enjoyment. Within that portion of the Lake Chelan National Recreation Area which is not designated as wilderness, such management, utilization, and disposal of renewable natural resources and the continuation of existing uses and developments as will promote, or are compatible with, or do not significantly impair public recreation and conservation of the scenic, scientific, historic, or other values contributing to public enjoyment, are authorized. In administering the recreation areas, the Secretary may utilize such statutory authorities pertaining to the administration of the national park system, and such statutory authorities otherwise available to him for the conservation and management of natural resources as he deems appropriate for recreation and preservation purposes and for resource development compatible therewith. Within the Ross Lake National Recreation Area the removal and disposal of trees within power line rights-ofway are authorized as necessary to protect transmission lines, towers, and equipment;": Provided, That to the extent practicable, such removal and disposal of trees shall be conducted in such a manner as to protect scenic viewsheds.".

SEC. 206. MINERAL RESOURCE USE IN RECREATION AREAS.

Section 402(b) of the Act of October 2, 1968 (82 Stat. 928; 16 U.S.C. 90c-1b) is hereby amended to read as follows:

"The lands within the recreation areas, subject to valid existing rights, are hereby withdrawn from all forms of appropriation or disposal under the public land laws, including location, entry, and patent under the United States mining laws, and disposition under the United States mineral leasing laws: *Provided, however*, That within that portion of the Lake Chelan National Recreation Area which is not designated as wilderness, sand, rock and gravel may be made available for sale to the residents of Stehekin for local use so long as such sale and disposal does not have significant adverse effects on the administration of the Lake Chelan National Recreation Area.".

102 STAT. 3964

	APPENDIX G	
	PROXIMITY TO OVERHEAD POWER LINES	
	(WAC 296-24-960)	
5 -		
		:
	· · · ·	

,

-

.

.

•

.

. . WAC 295-24-960' Proximity to overhead power lines. (1) General requirements – high voltage lines.

(a) Minimum clearance.

(i) No work shall be performed, no material shall be piled, stored or otherwise handled, no scaffolding, commercial signs, or structures shall be erected or dismantled, nor any tools, machinery or equipment operated within the specified minimum distances from any energized high voltage electrical conductor capable of energizing the material or equipment; except where the electrical distribution and transmission lines have been deenergized and visibly grounded at point of work, or where insulating barriers not a part of or an attachment to the equipment have been erected, to prevent physical contact with the lines, equipment shall be operated proximate to, under, over, by, or near powerlines only in accordance with the following:

(ii) For lines rated 50 kv. or below, minimum clearance between the lines and any part of the equipment or load shall be 10 feet.

(iii) For lines rated over 50 kv. minimum, clearance between the lines and any part of the equipment or load shall be 10 feet plus 0.4 inch for each 1 kv. over 50 kv., or twice the length of the line insulator but never less. than 10 feet.

(b) Overhead electric lines. Where overhead electric conductors are encountered in proximity to a work area, the employer shall be responsible for:

(i) Ascertaining the voltage and minimum clearance distance required, and

(ii) Maintaining the minimum clearance distance, and

(iii) Ensuring that the requirements of subsection (1) of this section are complied with.

(c) Not covered: Employees working under chapters 296-32 and 296-45 WAC.

(2) Low voltage lines. When work is being carried out in proximity to energized electrical service conductors operating at 750 volts or less, such work shall be performed in a manner to prevent contact by any worker with the energized conductors.

{Statutory Authority: RCW 49.17.040 and 49.17.050. 82-13-045 (Order 82-22), § 296-24-960, filed 6/11/82; 82-02-003 (Order 31-32), § 296-24-960, filed 12/24/81.}

•

• .

.

. .

APPENDIX H

SAFETY STANDARDS FOR

ELECTRICAL CONSTRUCTION CODE

(WAC 296-44-21230)

·

-

Title 296 WAC: Labor and Industries, Department of



Fig. 212-1

Clearances to Other Objects

WAC 296-44-21230 Vertical clearance of wires. conductors, cables, and live parts of equipment above ground, rails, or water. The vertical clearance of all wires, conductors, cables, and live parts of equipment above ground in generally accessible places, or above the top of the rails or water, shall not be less than the following:

(1) Basic clearances for wires, conductors, and cables. The clearances in Table 212-1 apply under the following conditions:

(a) Conductor temperature of 60°F, no wind, with final unloaded sag in the wire, conductors, or cables, or with initial unloaded sag in cases where these facilities are maintained approximately at initial unloaded sags.

(b) Span lengths not greater than the following:

Loading District	Span Lengths (feet)
Heavy	¹ 175
Medium	250
Light	350

One hundred fifty feet in heavy-loading district and two hundred twenty-five feet in medium-loading district for threestand conductors, each wire of which is 0.09 inches or less in diameter.

(Statutory Authority: RCW 49.17.040 and 49.17.050. 86-16-007 (Order 86-26), § 296-44-21221, filed 7/25/86.]

Table 212-1 Minimum Vertical Clearance of Wires, Conductors, and Cables Above Ground, Rails, or Water (Voltages are phase to ground for effectively grounded circuits and those other circuits where all ground faults are cleared by promptly deenergizing the faulted section, both initially and following subsequent breaker operations. See the definition section for voltages of other systems.)

Nature of Surface under- neath wires, conductors, or cables	Communication conductors and cables, guys, messengers, surge protection wires; neutral conductors meeting WAC 296-44-21209 (5)(a), supply cables meeting WAC 296-44-21209 (3)(a) and supply cables of 0 to 750 V meeting WAC 296-44-21209 (3)(b) or 296-44-21209 (3)(c) ¹¹ (ft)	Open supply line conductors of 0 to 750 V and supply cables over 750 V meeting WAC 296-44-21209 (3)(b) or 296-44-21209 (3)(c) (ft)	Open line co 750 V to 22 kV (ft)	supply inductors 22 to 50 kV (ft)	Trolle elect railroad associat or me: 0 to 750 V to ground (ft)	ey and rified contact cors and ed span ssenger es 750 V to 50 kV to ground (ft)
	Where wires,	conductors, or cables cross over	or overhang			
1. Track rails of railroads (except electrified railroads using over-head trolley conductors) ^{2 16 20}	³ ¹⁵ 27	³ 27	³ 28	29	422	122
2. Roads, streets, alleys; nonresidential driveways, parking lots, and other areas subject to truck traffic ^{21/22}	6 13 2 ³ 18	18	20	21	⁵ 18	⁵ 20
3. Residential driveways; commercial areas not subjec to truck traffic	²⁴ t2	**15	20	21	⁵ 18	⁵ 20
[Title 296 WAC-p 942]						(1986 F.J.)

4. Other land traversed by vehicles such as cultivated, grazing, forest, orchard, etc.	18	18	20	21		
5. Spaces or ways accessible to pedestrians only	⁴ ⁷ 15	8a 1415	15	16	16	18
 Water areas not suitable for sailboating or where sailboating is prohibited ¹⁹ 	15	15	17	17	·	
7. Water areas suitable for sailboating including lakes, ponds, reservoirs, tidal waters, rivers, streams, and canals with an unobstructed surface area of; ^{17,18,19}						
(a) Less than 20 acres	18	18	20	21	-	
(b) 20 to 200 acres	26	26	28	29	-	
(d) Over 2000 acres	38	32	40	41		
8. Public or private land and water areas posted for rigging or launching sailboats	Clearance ab than in 7 abo served by the	ove ground shall be 5 ft greate we, for the type of water areas launching site	er ;			

Where wires, conductors, or cables run along and within the limits of highways or other road rights-of-way but do not overhang the roadway

					_
13 23 25 18	18	20	21	⁵ 18	⁵ 20
	•				
10 12 14	¹⁰ 15	18	19	⁵ 18	⁵ 20
	13 23 25 18 10 12 14	¹³ ²³ ²⁵ 18 ¹⁸ ¹⁰ ¹² 14 ¹⁰ 15	¹³ ²³ ²⁵ 18 18 20 ¹⁰ ¹² 14 ¹⁰ 15 18	¹³ ²³ ²⁵ 18 18 20 21 ¹⁰ ¹² 14 ¹⁰ 15 18 19	¹³ ²³ ²⁵ 18 18 20 21 ⁵ 18 ¹⁰ ¹² 14 ¹⁰ 15 18 19 ⁵ 18

Where subways, tunnels, or bridges require it, less clearations above ground or raits than required by Table 232-1 majore used locally. The trolley and electrified railroad contact conductor should be graded very gradually from the regular construction down to the reduced elevation.

For wire, conductors, or cables crossing over mine, logging, and similar railways which handle only cars lower than standard freight cars, the clearance may be reduced by an amount equal to the difference in height between the highest loaded car handled and twenty feet, but the clearances shall not be reduced below that required for street crossings.

- These clearances may be reduced to twenty-five feet where paralleled by trolley-contact conductor on the same street or highway.
- In communities where twenty-one feet has been established, this clearance may be continued if carefully maintained. The elevation of the contact conductor should be the same in the crossing and next adjacent spans, (See WAC 296-44-31792 (4)(b) for conditions which must be met where uniform height above rail is impractical.)
- In communities where sixteen feet has been established for trolley and electrified railroad contact conductors 0 to 750 V to ground, or eighteen feet for trolley and electrified railroad contact conductors exceeding 750 V, or where local conditions make it impractical to obtain the clearance given in the table, these reduced clearances may be used if carefully maintained.
- If a communication service drop or a guy which is effectively grounded or is insulated against the highest voltage to which it is exposed, up to 8.7 kV, crosses residential streets and roads, the clearance may be reduced to sixteen feet at the side of the traveled way provided the clearance at the center of the traveled way is at least eighteen feet. This reduction in clearance does not apply to arterial streets and highways which are primarily for through traffic, usually on a continuous route.

This clearance may be reduced to the following values:

- (a) For insulated communication conductors and communication cables & (b) For conductors of other communication circuits 10 (c) For guys 8
- (d) For supply cables meeting WAC 296-44-21209 (3)(a).
- This clearance may be reduced to the following values:
 - (a) Twelve feet for supply conductors limited to 300 V to ground
 - (b) Ten feet for drip loops of service drop conductors limited to 150 V to ground and meeting WAC 296-44-21209 (3)(b) or (c) and the portion of the associated service drop span located within fifteen feet of the service entrance to buildings.
- ⁹ Spaces and ways accessible to pedestrians only are areas where vehicular traffic is not normally encountered or not reasonably anticipated.
 - Where a supply or communication line along a road is located relative to fences, ditches, embankments, etc., so that the ground under the line would not be expected to be traveled except by pedestrians, this clearance may be reduced to the following values:

296-44-21209 (3)(b) or (c)

	feet
(a) Insulated communication conductor and	
communication cables	8
(b) Conductors of other communication circuits	10
(c) Supply cables of any voltage meeting WAC	
296-44-21209 (3)(a) and supply cables	
limited to 150 V to ground meeting WAC	

10

10

ŧΙ

(d) Supply	conductors	limited	ta	300	۷	lo	
ground							

	(e) Guys.	•							8
No	clearance	from	ground	is	required	for	anchor	guys	not

- crossing track rails, streets, driveways, roads, or pathways.
 This clearance may be reduced to thirteen feet for communication conductors.
- ¹³ Where this construction crosses over or runs along alleys, driveways, or parking lots, this clearance may be reduced to fifteen feet for spans limited to one hundred fifty feet.
- Where supply circuits of 600 V or less, with transmitted power of 5000 W or less, are run along fenced (or otherwise guarded) private rights-of-way in accordance with the provisions specified in WAC 296-44-19409 (2)(b) this clearance may be reduced to ten feet.
- The value may be reduced to twenty-five feet for guys, for cables carried on messengers, and for supply cables meeting WAC 296-44-21209 (3)(a). This value may be reduced to twenty-five feet for conductors effectively grounded throughout their length and associated with supply circuits of 0 to 22 kV, only if such conductors are stranded, are of corrosion-resistant material, and conform to the strength and tension requirements for messengers given in WAC 296-44-27821(9).
- 16 Adjacent to tunnels and overhead bridges which restrict the height of loaded rail cars to less than twenty feet, these clearances may be reduced by the difference between the highest loaded rail car handled and twenty feet, if mutually agreed to by the parties at interest.
- 17 For controlled impoundments, the surface area and corresponding clearances shall be based upon the design high water level. For other waters, the surface area shall be that enclosed by its annual high water mark, and clearances shall be based on the normal flood level. The clearance over rivers, streams, and canais shall be based upon the largest surface area of any one mile long segment which includes the crossing. The clearance over a canal, river, or stream normally used to provide access for sailboats to a larger body of water shall be the same as that reouired for the larger body of water.
- quired for the larger body of water. Where an overwater obstruction restricts vessel height to less than the following:

For a surface area	A reference vessel height
in acres of	in feet of
less than 20	16
20 to 200	24
200 to 2000	30
over 2000	3 6

the required clearance may be reduced by the difference between the reference vessel height given above and the overwater obstruction height, except that the reduced clearance shall not be less than that required for the surface area on the line crossing side of the obstruction.

- Where the United States Army Corps of Engineers, or the state, or a surrogate thereof has issued a crossing permit, clearances of that permit shall govern.
- 20 See WAC 296-44-21253(8) for the required horizontal and diagonal clearances to rail cars.
- These clearances do not allow for the future road resurfacing.
- Provide the purpose of this rule, trucks are defined as any vehicle exceeding eight feet in height. Areas not subject to truck traffic are areas where truck traffic is not normally encountered or not reasonably anticipated.
- For communications cables supported on a messenger, and with span lengths not exceeding one hundred fifty feet, the clearance may be reduced to seventeen feet above or along local streets or roads. This reduction does not apply for arterial streets or highways which are primarily for through traffic, usually on a continuous route.
- This clearance may be reduced to ten feet for communication conductors and cables, guys, messengers and supply cables meeting WAC 296-44-21209 (3)(a).
- ²⁵ Communication cables supported on a steel messenger may have a 60°F clearance of fifteen feet where span lengths do not exceed one hundred lifty feet and poles are back of curbs or other deterrents to vehicular traffic.

(2) Additional clearances for wires, conductors and cables. Greater clearances than specified in Table 212-1, (subsection (1) of this section) shall be provided where required by (a) and (b) of this subsection. Increases are cumulative where more than one apply.

- Note 1: Additional clearances are not required for guys.
- Note 2: Additional clearances are not required for communication cables supported on messengers and communication wires which do not overhang the traveled way, but run along and within the limits of public highways or other public rightsof-way for traffic.



(a) Voltages exceeding 50 kilovolts.

(i) For voltages between 50 and 470 kilovolts, the clearance specified in Table 212-1, (subsection (1) of this section) shall be increased at the rate of 0.4 in per kilovolt in excess of 50 kilovolts. For voltages exceeding 470 kV, the clearance shall be determined by the alternate method given by subsection (4) of this section. All clearances for lines over 50 kV shall be based on the maximum operating voltage.

Note: For voltages exceeding 98 kV alternating current to ground or 139 kV direct current to ground, clearances less than those required above are permitted for systems with known maximum switching surge factors (see subsection (4) of this section).

296-44-212.

(ii) The additional clearance for voltages exceeding 50 kV specified in (a)(i) of this subsection shall be increased three percent for each one thousand fect in excess of thirty-three hundred feet (1000 m) above mean sea level.

(iii) For voltages exceeding 98 kV alternating current to ground, or 139 kV direct current to ground, either the clearances shall be increased or the electric field, or the effects thereof, shall be reduced by other means, as required, to limit the current due to electrostatic effects to 5.0 milliamperes, rms, if the largest anticipated truck, vehicle, or equipment under the line were shortcircuited to ground. For this determination, the conductors shall be at a final unloaded sag at 120° F.

(b) Sag increase.

(i) No additional clearance is required for trolley and electrified railroad contact conductors.

(ii) No additional clearance is required where span lengths are less than those listed in subsection (1)(b) of this section, and the maximum conductor temperature for which the supply line is designed to operate is 120° F or less.

(iii) Where supply lines are designed to operate at or below a conductor temperature of 120°F and spans are longer than specified in subsection (1)(b) of this section, the minimum clearance at midspan shall be increased by the following amounts.

(A) General.

For spans exceeding the limits specified in WAC 296-44-21230 (1)(b), the clearance specified in Table 212-1 shall be increased by 0.1 foot for each ten feet of the excess of span length over such limits. See (b)(iii)(C) of this subsection.

(B) Railroad crossings.

For spans exceeding the limits specified in subsection (1)(b) of this section, the clearance specified in Table 212-1 shall be increased by the following amounts for each ten feet by which the crossing span length exceeds such limits. See (b)(iii)(C) of this subsection.

	Amount o	of increase	
Loading district	Large conductors (ft)	Small conductors (ft)	
Heavy and medium Light	0.15	0.30 0.15	

A small conductor is a conductor having an overall diameter of metallic material equal to or less than the following values;

	Outside of con	diameter ductor
Material	Solid (inches)	Stranded (inches)
All copper	0.160	0.250
Other than all copper	0.250	0.275

(C) Limits.

The maximum additional clearance need not exceed the arithmetic difference between final unloaded sag at a

[Title 296 WAC-p 946]

conductor temperature of 60°F (15°C), no wind, and final sag at the following conductor temperature and condition, whichever difference is greater, computed for the crossing span.

(1) 32°F no wind, with radial thickness of ice, if any, specified in WAC 296-44-26309(2) for the loading district concerned.

(II) 120°F (50°C), no wind.

(iv) Where supply lines are designed to operate at conductor temperature above 120° F regardless of span length, the minimum clearance at midspan specified in subsections (1) and (2)(a) of this section shall be increased by the difference between final unloaded sag at a conductor temperature of 60°F no wind, and final sag at the following conductor temperature and condition, whichever difference is greater, computed for the crossing span.

(A) 32°F no wind, with radial thickness of ice, if any, specified in WAC 296-44-26309(2) for the loading district concerned.

(B) The maximum conductor temperature for which the supply line is designed to operate, with no horizontal displacement.

Note: The phase and neutral conductors of a supply line should be considered separately when determining the sag increases of each due to temperature rise.

(v) Where minimum clearance is not at midspan, the additional clearances specified in (b)(iii) and (iv) of this subsection may be reduced by multiplying by the following factors:

Distance from nearer support of crossing span to point of crossing in percentage of crossing span length	Factors ¹
5	0.19
10	0.36
15	0.51
20	0.64
25	0.75
30	0.84
35	0.91
40	0.96
45	0.99
50	1.00

Interpolate for intermediate values.

In applying this rule, the "point of crossing" is the location under the conductors of any topographical feature which is the determinant of the clearance.

(3) Clearance to live parts of equipment mounted on structures.

(a) Basic clearances. The vertical clearance above ground for unguarded live parts such as potheads, transformer bushings, surge arresters, and short lengths of supply conductors connected thereto, which are not subject to variation in sag, shall be as shown in Table 212-2.

Table 212-2. Minimum Vertical Clearance of Rigid Live Parts Above Ground

(Voltages are phase to ground for effectively grounded circuits and those other circuits where all ground faults are cleared by promptly de-energizing the faulted section, both initially and following subsequent breaker operations. See the definition section for voltages of other systems.)

Nature of surface below live parts		0 to 750 V	750 V to 22 kV	22 to 50 kV
1.	Where live parts overhang: a. Roads, streets, alieys; nonresidential driveways;			
	parking lots and other areas subject to truck traffic ^{4.5} b. Residential driveways;	16	i 8	19
	commercial areas not subject to truck traffic ^{4,5} c. Other land traversed by vehicles such as cultivated	'13	18	19
	land, grazing land, forest, orchard, etc.	io	18	19
	to pedestrians only.	3 413	13	14
2.	Where live parts are along and within the limits of highways or other road rights-of-way but do not overhang the roadway: a. Roads, streets, and alleys b. Roads in rural districts where it is unlikely that	² 16	18	19
	vehicles will be crossing under the line.	213	16	17

This clearance may be reduced to the following values:

		lcei
(a)	Live parts limited to 300 V to ground	12
(b)	Live parts limited to 150 V to ground and	
	drip loops of service drop conductors lim-	
	ited to 150 V to ground and meeting WAC	
	296-44-21209 (3)(b) or (c).	10

- Where a supply line along a road is limited to 300 V to ground and is located relative to fences, ditches, embankm ints, etc., so that the ground under the line would not be expected to be traveled except by pedestrians, this clearance may be reduced to twelve feet.
- ³ Where supply circuits of 600 V or less, with transmitted power of 5000 W or less, are run along fenced (or otherwise guarded) private rights-of-way in accordance with the provisions specified in WAC 296-44-19409 (2)(b), this clearance may be reduced to ten feet.
- For the purpose of this rule, trucks are defined as any vehicle exceeding eight feet in height.
- These clearances do not allow for future road resurfacing.
- Spaces and ways accessible to pedestrians only are areas where vehicular traffic is not normally encountered or not reasonably anticipated.

(b) Additional clearances for voltages exceeding 50 kilovolts.

(i) For voltages between 50 and 470 kilovolts, the clearance specified in Table 212-2 ((a) of this subsection) shall be increased at the rate of 0.4 in per kilovolt in excess of 50 kV. For voltages exceeding 470 kV, the clearances shall be determined by the alternate method given by subsection (4) of this section. All clearances for

lines over 50 kV shall be based on the maximum operating voltage.

Note: For voltages exceeding 98 kV atternating current to ground c 139 kV direct current to ground, clearances less than those re quired above are permitted for systems with known maximur switching surge factors. (See subsection (4) of this section.)

(ii) The additional clearance for voltages exceeding 5° kV specified in (b)(i) of this subsection shall be in creased three percent for each one thousand feet in excess of thirty-three hundred feet above mean sea level.

(iii) For voltages exceeding 98 kV alternating curren to ground, or 139 kV direct current to ground either the clearances shall be increased or the electric field, or the effects thereof, shall be reduced by other means, as re quired, to limit the current due to electrostatic effects to 5.0 milliamperes, rms, if the largest anticipated truck vehicle, or equipment under the line were short-circuited to ground.

(4) Alternate clearances for voltages exceeding 98 kilovolts alternating current to ground or 139 kilovolt direct current to ground. The clearances specified in subsections (1), (2) and (3) of this section may be reduced for circuits with known switching surge factor: but shall not be less than the values computed by adding the reference height to the electrical component o clearance.

(a) Sag conditions of line conductors. Minimum vertical clearances shall be maintained under the following conductor temperatures and conditions:

(i) 32°F no wind, with radial thickness of ice specified in WAC 296-44-26309(2) for the loading district concerned.

(ii) 120°F, no wind.

(iii) Maximum conductor temperature, for which the line is designed to operate, if greater than 120°F, with no horizontal displacement.

(b) Reference heights are shown in Table 212-3.

(c) Electrical component of clearance.

(i) The clearance computed by the following equation and listed in Table 212-4 shall be added to the reference heights specified in Table 212-3.

$$D = 3.28 \left[\frac{V \cdot (PU) \cdot a}{500 K} \right]^{1.667} bc \qquad (ft)$$

where

- V maximum alternating current crest operating voltage to ground or maximum direct current operating voltage to ground in kilovolts;
- PU maximum switching surge factor expressed in per-unit peak voltage to ground and defined as a switching surge level for circuit breakers corresponding to ninety-eight percent probability that the maximum switching surge generated per breaker operation

2

Title 296 WAC: Labor and Industries, Department of

does not exceed this surge level, or the maximum anticipated switching surge level generated by other means, whichever is greater;

- a = 1.15, the allowance for three standard deviations;
- b = 1.03, the allowance for nonstandard atmospheric conditions;
- c = 1.2, the margin of safety;
- K = 1.15, the configuration factor for conductor-to-plane gap.

(ii) The value of D shall be increased three percent for each one thousand feet in excess of fifteen hundred feet above mean sea level.

(iii) Either the clearances shall be increased or the electric field, or the effects thereof, shall be reduced by other means, as required, to limit the current due to electrostatic effects to 5.0 milliamperes, rms, if the largest anticipated truck, vehicle, or equipment under the line were shortcircuited to ground. For this determination, the conductors shall be at a final unloaded sag at 120°F.

(d) imit. The clearances derived from (b) and (c) of this subsection shall be not less than the clearances given in Tables 212-1 or 212-2 computed for 98 kilovolts alternating current to ground in accordance with subsection (2)(a) or (3)(b) of this section, respectively.

Table 212-3 Reference Heights

Nature of surface underneath lines		
Ŀ.	Track rails of railroads (except electrified railroads us-	
	ing overhead trolley conductors)	22
ъ	Streets, alleys, roads, driveways, and parking lots	14
ç	Spaces and ways accessible to pedestrians only ²	9
đ	Other land, such as cultivated, grazing, forest or or-	
	chard, which is traversed by vehicles	14
c	Water areas not suitable for sailboating or where	
	sailboating is prohibited	14
ſ	Water areas suitable for sailboating including lakes,	
	ponds, reservoirs, tidal waters, rivers, streams, and ca-	
	nals with unobstructed surface area ¹⁴	
	(1) less than 20 acres	18
	(2) 20 to 200 acres	26
	(3) 200 to 2000 acres	32
	(4) over 2000 acres	38
B	In public or private land and water areas posted for	
	figging or launching sailboats, the reference height	
	shall be five feet greater than in f. above, for the type	
	of water areas serviced by the launching site.	

See WAC 296-44-21253(8) for the required horizontal and diagonal clearances to rail cars.

Spaces and ways accessible to pedestrians only are areas where vehicular traffic is not normally encountered or not reasonably anticipated.

For controlled impoundments, the surface area and corresponding clearances shall be based upon the design high water level. For other waters, the surface area shall be that enclosed by its annual high water mark, and clearances shall be based on the normal flowd level. The clearance over rivers, streams, and canais shall be based upon the largest surface area of any onemile-long segment which includes the crossing. The clearance over a canal or similar waterway providing access for sailboats to a larger body of water shall be the same as that required for the larger body of water. Where an overwater obstruction restricts vessel height to less than the following:

F	A reference vessel height of	
For a surface of	it	
(1) less than 20 acres	16	
(2) 20 to 200 acres	24	
(3) 200 to 2000 acres	30	
(4) over 2000 acres (800 ha)	36	

The required clearance may be reduced by the difference between the reference vessel height given above and the overwater obstruction height, except that the reduced clearance shall not be less than that required for the surface area on the line crossing side of the obstruction.

Table 212-4 Electrical Component of Clearance

Above Ground or Rail in (c)(i) of this subsection (Add three percent for each one thousand feet in excess of fifteen hundred feet above mean sea level. Increase clearance to limit electrostatic effects in accordance with (c)(iii) of t is subsection.)

Maximum operating voltage	Switching surge	Switching	Electrical component of clearance (ft)	
pnase-to-phase (kV)	(per unit)	(kV)		
242	4.5 or less	839 or less	¹ 8.6	
362	2.8 or less	839 or less	¹ 8.6	
550	1.9 or less	839 or less	18.6	
	2.0	898	10.8	
· · · · · · · · · · · · · · · · · · ·	2.2	983	12.7	
	2.4	1079	14.6	
	26	1168	16.7	
800	1.6	1045	13.9	
	1.8	1176	16.9	
	2.0	1306	20.1	
	2.1 or more	1372 or more	² 21.8	

¹ Limited by (d) of this subsection.

² Limited by subsections (1) and (2) of this section.

[Statutory Authority: RCW 49.17.040 and 49.17.050, 86-16-007 (Order 86-26), § 296-44-21230, filed 7/25/86.]

WAC 296-44-21241 Clearances between wires, conductors, and cables carried on different supporting structures. (1) General.

Crossings should be made on a common supporting structure, where practical. In other cases, the clearance between any two crossing or adjacent wires, conductors, or cables carried on different supporting structures shall not be any less at any location in the spans than that required by WAC 296-44-21241. The minimum clearance shall be as illustrated by a clearance envelope developed under WAC 296-44-21241 (1)(b) applied at the positions on or within conductor movement envelopes developed under WAC 296-44-21241 (1)(a) at which the two wires, conductors, or cables would be closest together. For purposes of this determination, the relevant positions of the wires, conductors, or cables on or within their respective conductor movement envelopes are those which can occur when (a) both are simultaneously subjected to the same ambient air temperature and wind

••

• •

· .